

To: Fort Peck Project Office

Attn: Project Engineer/REHC

From: Reservoir Control Center

Fort Peck Combined Reservoir Regulation and Power Production Order No. **ST-1, 1993**. This order will apply when referenced in the daily Reservoir Regulation and Power Production orders.

Unless otherwise specified in current reservoir regulation and power production orders, supplementary releases will be made only as necessary to maintain an instantaneous minimum release of 3,000 cfs.

If it appears that an outage involving both powerplants will be at least one hour in duration, supplemental releases through the outlet works to meet the instantaneous minimum release should begin as soon as possible. Supplemental outlet works releases to meet the instantaneous minimum release are not required for powerplant outages of less than one hour in duration. The dispatcher will be notified as far in advance as possible of intent to make supplementary releases.

WORM