

To: Fort Randall Project Office

Attn: Project Manager/REHC

From: Reservoir Control Center

Fort Randall combined Reservoir Regulation and Power Productions Order No. **ST-5, 1983**. This order will apply when referenced in the daily Reservoir Regulation and Power Production orders.

a) Power plant may be operated at zero load for up to 22 consecutive hours except when minimum hourly generation is specified in the daily orders. If the power plant is at zero load for 22 consecutive hours at least 35 MW for one hour should occur before resuming zero generation.

b) Maximum allowable generation: There is no limit on maximum allowable daily energy generation unless indicated on the current order.

SVEUM