

To: Garrison Office

Attn: Project Engineer

From: Reservoir Control Center

Re: Garrison Combined Reservoir Regulation and Power Production Order

No. St-2, 1983. This order will apply when referenced in the Daily Reservoir Regulation and Power Production Orders.

1. Minimum energy generation shall be maintained to avoid low pumping stages below Garrison as follows:

Period	Minimum Energy for Period
4 hours	300 MWh
5 hours	400 MWh
6 hours	550 MWh
7 hours	700 MWh
8 hours	850 MWh

The WAPA power systems dispatcher shall be advised whenever it appears that loading is falling below the above minimums so that plant loading can be increased. The above minimums have been furnished to WAPA.

2. Unless otherwise specified in daily reservoir regulation and power production orders supplementary releases will be made only as necessary to maintain daily average discharge of 6,000 cfs. The WAPA dispatcher will be notified as far in advance as possible of the intent to make supplementary releases.

Sveum