

SEP 1, 2011 / BASIC CONDITION / 61.8 MAF / BALANCED
 NAV SEASON 10-DAY EXTENSION
 Elevations & Storages are for Date Shown
 Avg Discharge & Energy are Monthly Values
 Date of Study: September 1, 2011

	31-Aug-11	30-Sep	2011 31-Oct	30-Nov	31-Dec	2012 31-Jan	29-Feb
FORT PECK -----							
ELEV FTMSL	2241.9	2238.0	2237.4	2237.0	2236.1	2234.9	2234.0
DISCH KCFS	24.5	23.5	9.0	9.0	10.0	12.0	12.0
GARRISON -----							
ELEV FTMSL	1844.4	1843.3	1842.1	1840.6	1839.7	1838.4	1837.5
DISCH KCFS	74.0	42.9	26.0	26.0	19.0	24.0	24.0
OAHE -----							
ELEV FTMSL	1613.3	1609.1	1609.5	1608.5	1607.1	1607.1	1607.5
DISCH KCFS	80.0	67.9	24.5	30.9	25.3	23.6	22.7
BIG BEND -----							
ELEV FTMSL	1419.3	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	80.0	66.8	24.2	30.6	25.1	23.6	22.7
FORT RANDALL ----							
ELEV FTMSL	1361.1	1355.0	1344.9	1337.4	1339.0	1344.6	1349.8
DISCH KCFS	87.0	77.6	36.6	38.4	23.7	18.2	17.0
GAVINS POINT ----							
ELEV FTMSL	1206.6	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
DISCH KCFS	90.0	80.0	40.0	40.0	25.5	20.0	20.0
SYSTEM -----							
STORAGE 1000 AF	63640	60516	59323	57939	57147	56816	56817
ENERGY GWh	5901	1562	969	1007	812	809	741
PEAK POWER MW		2348	2343	2296	2293	2313	2320

SEP 1, 2011 / LOWER BASIC / 59.9 MAF / BALANCED
 NAV SEASON 10-DAY EXTENSION

	31-Aug-11	30-Sep	2011 31-Oct	30-Nov	31-Dec	2012 31-Jan	29-Feb
FORT PECK -----							
ELEV FTMSL	2241.9	2238.0	2237.4	2236.6	2235.8	2234.8	2234.0
DISCH KCFS	24.5	21.8	8.0	8.0	8.0	10.0	10.0
GARRISON -----							
ELEV FTMSL	1844.4	1842.9	1842.1	1841.2	1840.1	1838.6	1837.5
DISCH KCFS	74.0	41.0	20.0	20.0	18.0	22.0	22.0
OAHE -----							
ELEV FTMSL	1613.3	1609.4	1610.0	1609.2	1608.1	1607.6	1607.5
DISCH KCFS	80.0	63.5	17.2	22.6	22.6	24.1	23.4
BIG BEND -----							
ELEV FTMSL	1419.3	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	80.0	62.3	16.8	22.2	22.3	24.1	23.4
FORT RANDALL ----							
ELEV FTMSL	1361.1	1355.0	1344.9	1337.4	1339.2	1344.7	1349.9
DISCH KCFS	87.0	72.5	29.1	29.8	20.7	18.7	17.5
GAVINS POINT ----							
ELEV FTMSL	1206.6	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
DISCH KCFS	90.0	74.5	32.0	31.1	22.0	20.0	20.0
SYSTEM -----							
STORAGE 1000 AF	63640	60450	59462	58320	57512	57016	56802
ENERGY GWh	5320	1550	755	790	723	784	719
PEAK POWER MW		2351	2346	2302	2300	2317	2320

SEP 1, 2011 / UPPER BASIC / 62.1 MAF / BALANCED
 NAV SEASON 10-DAY EXTENSION

	31-Aug-11	30-Sep	2011 31-Oct	30-Nov	31-Dec	2012 31-Jan	29-Feb
FORT PECK -----							
ELEV FTMSL	2241.9	2238.6	2237.7	2237.0	2236.2	2234.9	2234.0
DISCH KCFS	24.5	23.6	12.5	12.4	11.0	13.0	13.0
GARRISON -----							
ELEV FTMSL	1844.4	1843.6	1842.1	1840.7	1839.8	1838.4	1837.5
DISCH KCFS	74.0	44.6	32.0	31.2	22.0	26.0	26.0
OAHE -----							
ELEV FTMSL	1613.3	1609.8	1609.8	1608.5	1607.6	1607.3	1607.5
DISCH KCFS	80.0	66.6	33.1	39.0	26.2	27.2	26.1
BIG BEND -----							
ELEV FTMSL	1419.3	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0
DISCH KCFS	80.0	65.6	32.8	38.8	26.1	27.2	26.1
FORT RANDALL ----							
ELEV FTMSL	1361.1	1355.0	1344.9	1337.5	1339.2	1344.7	1349.9
DISCH KCFS	87.0	77.1	45.4	46.9	24.6	22.0	20.6
GAVINS POINT ----							
ELEV FTMSL	1206.6	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
DISCH KCFS	90.0	80.0	49.0	49.0	27.0	24.0	24.0
SYSTEM -----							
STORAGE 1000 AF	63640	60949	59494	58000	57322	56879	56807
ENERGY GWh	6571	1560	1198	1202	870	910	831
PEAK POWER MW		2353	2344	2296	2296	2314	2320

	31AUG11	2011	VALUES IN 1000 AF EXCEPT AS INDICATED							2012
	INI-SUM	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	29FEB	
--FORT PECK--										
NAT INFLOW	2235	450	400	192	90	102	329	312	360	
DEPLETION	-903	-177	-130	-67	-31	-36	-151	-166	-145	
EVAPORATION	352	115	98	44	21	23	51			
MOD INFLOW	2786	512	432	215	100	115	429	478	505	
RELEASE	4530	1398	553	268	125	143	615	738	690	
STOR CHANGE	-1744	-886	-121	-53	-25	-28	-186	-260	-185	
STORAGE	16537	15651	15529	15476	15452	15424	15238	14978	14793	
ELEV FTMSL	2241.9	2238.0	2237.4	2237.2	2237.1	2237.0	2236.1	2234.9	2234.0	
DISCH KCFS	24.5	23.5	9.0	9.0	9.0	9.0	10.0	12.0	12.0	
POWER										
AVE POWER MW		166	124	124	124	124	137	160	159	
PEAK POW MW		164	165	165	164	164	164	163	162	
ENERGY GWH	632.1	119.2	92.3	44.6	20.8	23.8	101.9	118.9	110.7	
--GARRISON--										
NAT INFLOW	2512	700	550	199	93	106	247	261	356	
DEPLETION	-731	-219	-48	-112	-52	-60	-108	-77	-55	
CHAN STOR	120	10	140				-10	-20		
EVAPORATION	404	132	114	51	23	27	57			
REG INFLOW	7489	2195	1178	528	247	282	903	1056	1101	
RELEASE	9723	2552	1599	774	361	413	1168	1476	1381	
STOR CHANGE	-2233	-357	-421	-245	-114	-131	-266	-420	-279	
STORAGE	20348	19991	19570	19324	19210	19079	18814	18394	18115	
ELEV FTMSL	1844.4	1843.3	1842.1	1841.3	1841.0	1840.6	1839.7	1838.4	1837.5	
DISCH KCFS	74.0	42.9	26.0	26.0	26.0	26.0	19.0	24.0	24.0	
POWER										
AVE POWER MW		499	331	329	329	328	240	300	298	
PEAK POW MW		498	486	482	481	479	476	472	468	
ENERGY GWH	1451.2	359.0	245.9	118.4	55.2	63.0	178.5	223.5	207.6	
--OAHE--										
NAT INFLOW	372	130	70	35	16	19		12	90	
DEPLETION	92	28	-9	2	1	1	15	21	33	
CHAN STOR	189	115	66				27	-20		
EVAPORATION	396	130	110	50	23	26	56			
REG INFLOW	9796	2640	1633	757	353	404	1124	1447	1438	
RELEASE	11701	4041	1507	830	420	589	1556	1449	1308	
STOR CHANGE	-1905	-1401	126	-74	-67	-185	-432	-2	129	
STORAGE	20744	19343	19469	19395	19328	19143	18712	18710	18839	
ELEV FTMSL	1613.3	1609.1	1609.5	1609.3	1609.1	1608.5	1607.1	1607.1	1607.5	
DISCH KCFS	80.0	67.9	24.5	27.9	30.3	37.1	25.3	23.6	22.7	
POWER										
AVE POWER MW		725	319	363	393	480	327	303	293	
PEAK POW MW		714	719	717	716	713	706	706	708	
ENERGY GWH	1721.5	522.0	237.5	130.7	66.0	92.2	243.2	225.7	204.1	
--BIG BEND--										
EVAPORATION	77	25	22	10	5	5	11			
REG INFLOW	11624	4016	1486	821	415	584	1545	1449	1308	
RELEASE	11583	3975	1486	821	415	584	1545	1449	1308	
STORAGE	1580	1621	1621	1621	1621	1621	1621	1621	1621	
ELEV FTMSL	1419.3	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	
DISCH KCFS	80.0	66.8	24.2	27.6	29.9	36.8	25.1	23.6	22.7	
POWER										
AVE POWER MW		311	118	138	149	183	126	116	109	
PEAK POW MW		511	538	538	538	538	538	538	529	
ENERGY GWH	677.0	223.8	88.0	49.6	25.1	35.0	93.5	86.0	75.9	
--FORT RANDALL--										
NAT INFLOW	262	140	18	9	4	5	12	25	49	
DEPLETION	19	7	1	1	0	1	3	3	3	
EVAPORATION	85	33	25	9	4	4	10			
REG INFLOW	11742	4075	1478	820	415	583	1546	1471	1354	
RELEASE	12709	4619	2253	1142	531	607	1455	1121	980	
STOR CHANGE	-967	-544	-776	-322	-116	-24	91	350	374	
STORAGE	4074	3530	2755	2433	2317	2292	2383	2733	3107	
ELEV FTMSL	1361.1	1355.0	1344.9	1339.9	1337.9	1337.4	1339.0	1344.6	1349.8	
DISCH KCFS	87.0	77.6	36.6	38.4	38.3	38.3	23.7	18.2	17.0	
POWER										
AVE POWER MW		361	294	283	271	267	172	138	135	
PEAK POW MW		350	319	296	287	285	292	318	338	
ENERGY GWH	1002.0	259.7	218.9	101.8	45.5	51.2	128.3	102.5	94.1	
--GAVINS POINT--										
NAT INFLOW	740	150	140	60	28	32	100	100	130	
DEPLETION	18	-5	2	5	2	3	10	1		
CHAN STOR	130	18	76	-3	0	0	27	10	2	
EVAPORATION	27	9	8	3	2	2	4			
REG INFLOW	13533	4783	2460	1190	555	635	1568	1230	1112	
RELEASE	13548	4760	2460	1190	555	635	1568	1230	1150	
STOR CHANGE	-15	23							-38	
STORAGE	357	380	380	380	380	380	380	380	342	
ELEV FTMSL	1206.6	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0	
DISCH KCFS	90.0	80.0	40.0	40.0	40.0	40.0	25.5	20.0	20.0	
POWER										
AVE POWER MW		109	116	116	116	116	89	71	70	
PEAK POW MW		111	116	116	116	116	117	117	114	
ENERGY GWH	416.6	78.4	86.7	41.9	19.6	22.4	66.6	52.5	48.7	
--GAVINS POINT - SIOUX CITY--										
NAT INFLOW	1182	400	300	100	47	53	150	40	92	
DEPLETION	88	24	11	6	3	3	13	14	14	
REGULATED FLOW AT SIOUX CITY										
KAF	14642	5136	2749	1284	599	685	1705	1256	1228	
KCFS		86.3	44.7	43.2	43.2	43.2	27.7	20.4	21.4	
--TOTAL--										
NAT INFLOW	7303	1970	1478	595	278	317	838	750	1077	
DEPLETION	-1417	-342	-173	-165	-77	-88	-218	-204	-150	
CHAN STOR	440	143	282	-2	0	-1	46	-29	2	
EVAPORATION	1341	443	376	168	77	88	189			
STORAGE	63640	60516	59323	58629	58307	57939	57147	56816	56817	
SYSTEM POWER										
AVE POWER MW		2169	1303	1353	1382	1498	1092	1087	1065	
PEAK POW MW		2348	2343	2314	2303	2296	2293	2313	2320	
ENERGY GWH	5900.5	1562.0	969.3	487.1	232.1	287.6	812.1	809.1	741.2	
DAILY GWH		52.1	31.3	32.5	33.2	35.9	26.2	26.1	25.6	
INI-SUM	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	29FEB		

TIME OF STUDY 11:20:12

NAV SEASON 10-DAY EXTENSION
VALUES IN 1000 AF EXCEPT AS INDICATED

STUDY NO 8

	31AUG11	30SEP	2011	15NOV	22NOV	30NOV	31DEC	31JAN	29FEB	2012
	INI-SUM		31OCT							
--FORT PECK--										
NAT INFLOW	1788	360	320	154	72	82	263	250	288	
DEPLETION	-847	-195	-155	-60	-28	-32	-120	-138	-119	
EVAPORATION	439	144	122	55	26	29	63			
MOD INFLOW	2196	411	353	158	74	85	320	388	407	
RELEASE	3948	1298	492	238	111	127	492	615	575	
STOR CHANGE	-1752	-887	-139	-80	-37	-42	-172	-227	-168	
STORAGE	16537	15650	15511	15431	15394	15352	15180	14953	14785	
ELEV FTMSL	2241.9	2238.0	2237.4	2237.0	2236.8	2236.6	2235.8	2234.8	2234.0	
DISCH KCFS	24.5	21.8	8.0	8.0	8.0	8.0	8.0	10.0	10.0	
POWER										
AVE POWER MW		166	110	110	110	110	110	136	136	
PEAK POW MW		164	165	164	164	164	164	163	162	
ENERGY GWH	558.5	119.3	82.0	39.6	18.5	21.1	81.7	101.5	94.7	
--GARRISON--										
NAT INFLOW	2010	560	440	159	74	85	198	209	285	
DEPLETION	-752	-202	-54	-117	-55	-62	-115	-84	-63	
CHAN STOR	140	26	134					-20		
EVAPORATION	509	166	143	64	30	34	73			
REG INFLOW	6341	1920	977	450	210	240	732	888	923	
RELEASE	8582	2437	1230	595	278	317	1107	1353	1265	
STOR CHANGE	-2241	-517	-253	-145	-68	-77	-375	-464	-342	
STORAGE	20348	19831	19578	19433	19365	19288	18914	18449	18107	
ELEV FTMSL	1844.4	1842.9	1842.1	1841.7	1841.4	1841.2	1840.1	1838.6	1837.5	
DISCH KCFS	74.0	41.0	20.0	20.0	20.0	20.0	18.0	22.0	22.0	
POWER										
AVE POWER MW		499	255	254	253	253	228	276	274	
PEAK POW MW		497	487	483	482	481	477	472	468	
ENERGY GWH	1296.2	358.9	189.5	91.4	42.6	48.6	169.3	205.3	190.6	
--OAHE--										
NAT INFLOW	298	104	56	28	13	15		10	72	
DEPLETION	92	28	-9	2	1	1	15	21	33	
CHAN STOR	196	123	81			0	8	-16		
EVAPORATION	501	164	140	63	30	34	72			
REG INFLOW	8483	2472	1237	558	260	298	1028	1326	1304	
RELEASE	10396	3779	1058	584	305	457	1388	1480	1344	
STOR CHANGE	-1913	-1307	178	-26	-45	-159	-360	-154	-40	
STORAGE	20744	19437	19615	19589	19544	19385	19025	18871	18831	
ELEV FTMSL	1613.3	1609.4	1610.0	1609.9	1609.7	1609.2	1608.1	1607.6	1607.5	
DISCH KCFS	80.0	63.5	17.2	19.6	22.0	28.8	22.6	24.1	23.4	
POWER										
AVE POWER MW		727	225	257	287	375	293	311	302	
PEAK POW MW		717	721	720	720	717	711	708	708	
ENERGY GWH	1563.0	523.3	167.5	92.4	48.3	71.9	218.1	231.5	210.0	
--BIG BEND--										
EVAPORATION	96	31	27	12	6	7	14			
REG INFLOW	10300	3749	1031	572	300	450	1374	1480	1344	
RELEASE	10259	3708	1031	572	300	450	1374	1480	1344	
STORAGE	1580	1621	1621	1621	1621	1621	1621	1621	1621	
ELEV FTMSL	1419.3	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	
DISCH KCFS	80.0	62.3	16.8	19.2	21.6	28.4	22.3	24.1	23.4	
POWER										
AVE POWER MW		290	82	97	108	142	112	118	112	
PEAK POW MW		511	538	538	538	538	538	538	529	
ENERGY GWH	599.4	208.8	61.3	34.8	18.2	27.2	83.3	87.8	78.0	
--FORT RANDALL--										
NAT INFLOW	209	112	14	7	3	4	10	20	39	
DEPLETION	19	7	1	1	0	1	3	3	3	
EVAPORATION	107	41	31	12	5	5	12			
REG INFLOW	10342	3772	1013	566	298	447	1369	1497	1380	
RELEASE	11300	4314	1787	888	414	473	1271	1147	1006	
STOR CHANGE	-958	-543	-774	-322	-116	-26	99	350	374	
STORAGE	4074	3531	2757	2436	2319	2294	2392	2742	3116	
ELEV FTMSL	1361.1	1355.0	1344.9	1339.9	1337.9	1337.4	1339.2	1344.7	1349.9	
DISCH KCFS	87.0	72.5	29.1	29.8	29.8	29.8	20.7	18.7	17.5	
POWER										
AVE POWER MW		362	234	225	218	215	151	141	139	
PEAK POW MW		351	319	296	287	285	293	318	339	
ENERGY GWH	907.8	260.3	174.3	81.1	36.6	41.3	112.4	105.0	96.7	
--GAVINS POINT--										
NAT INFLOW	592	120	112	48	22	26	80	80	104	
DEPLETION	18	-5	2	5	2	3	10	1		
CHAN STOR	129	27	80	-1	0	0	17	4	2	
EVAPORATION	34	11	10	4	2	2	5			
REG INFLOW	11969	4456	1968	925	432	493	1353	1230	1112	
RELEASE	11984	4433	1968	925	432	493	1353	1230	1150	
STOR CHANGE	-15	23							-38	
STORAGE	357	380	380	380	380	380	380	380	342	
ELEV FTMSL	1206.6	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0	
DISCH KCFS	90.0	74.5	32.0	31.1	31.1	31.1	22.0	20.0	20.0	
POWER										
AVE POWER MW		110	108	106	106	106	77	71	70	
PEAK POW MW		112	117	117	117	117	117	117	114	
ENERGY GWH	395.3	79.4	80.6	38.3	17.9	20.4	57.6	52.5	48.7	
--GAVINS POINT - SIOUX CITY--										
NAT INFLOW	946	320	240	80	37	43	120	32	74	
DEPLETION	88	24	11	6	3	3	13	14	14	
REGULATED FLOW AT SIOUX CITY										
KAF	12842	4729	2197	999	466	533	1460	1248	1210	
KCFS		79.5	35.7	33.6	33.6	33.6	23.7	20.3	21.0	
--TOTAL--										
NAT INFLOW	5843	1576	1182	476	222	254	671	601	862	
DEPLETION	-1382	-343	-204	-163	-76	-87	-194	-183	-132	
CHAN STOR	466	176	296	-1	0	-1	25	-32	2	
EVAPORATION	1687	556	473	211	98	111	239			
STORAGE	63640	60450	59462	58890	58624	58320	57512	57016	56802	
SYSTEM POWER										
AVE POWER MW		2153	1015	1049	1083	1201	971	1053	1033	
PEAK POW MW		2351	2346	2319	2308	2302	2300	2317	2320	
ENERGY GWH	5320.1	1550.1	755.3	377.6	182.0	230.6	722.5	783.6	718.6	
DAILY GWH		51.7	24.4	25.2	26.0	28.8	23.3	25.3	24.8	
INI-SUM		30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	29FEB	

TIME OF STUDY 11:20:37 NAV SEASON 10-DAY EXTENSION STUDY NO 5
VALUES IN 1000 AF EXCEPT AS INDICATED

31AUG11	2011	2011	2011	2011	2011	2011	2011	2011	2011	2011
INI-SUM	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	29FEB		
--FORT PECK--										
NAT INFLOW	2682	540	480	231	108	123	395	374	432	
DEPLETION	-935	-194	-176	-74	-34	-39	-141	-163	-114	
EVAPORATION	234	87	74	18	8	9	38			
MOD INFLOW	3383	647	582	286	134	153	498	537	546	
RELEASE	5133	1405	769	372	174	190	676	799	748	
STOR CHANGE	-1750	-758	-187	-85	-40	-38	-178	-262	-202	
STORAGE	16537	15779	15592	15507	15467	15429	15251	14988	14787	
ELEV FTMSL	2241.9	2238.6	2237.7	2237.3	2237.2	2237.0	2236.2	2234.9	2234.0	
DISCH KCFS	24.5	23.6	12.5	12.5	12.5	12.0	11.0	13.0	13.0	
POWER										
AVE POWER MW		166	165	165	165	161	149	163	162	
PEAK POW MW		165	165	165	165	164	164	163	162	
ENERGY GWH	705.6	119.3	122.9	59.3	27.7	30.9	110.9	121.5	113.1	
--GARRISON--										
NAT INFLOW	3014	840	660	239	112	127	296	313	427	
DEPLETION	-697	-220	-31	-110	-51	-58	-107	-74	-46	
CHAN STOR	111	8	107			5	10	-20		
EVAPORATION	268	100	86	20	9	11	43			
REG INFLOW	8687	2374	1481	700	327	371	1046	1167	1221	
RELEASE	10926	2655	1968	952	444	460	1353	1599	1496	
STOR CHANGE	-2239	-281	-486	-252	-117	-90	-307	-432	-275	
STORAGE	20348	20067	19581	19329	19212	19122	18815	18383	18109	
ELEV FTMSL	1844.4	1843.6	1842.1	1841.3	1841.0	1840.7	1839.8	1838.4	1837.5	
DISCH KCFS	74.0	44.6	32.0	32.0	32.0	29.0	22.0	26.0	26.0	
POWER										
AVE POWER MW		499	406	405	404	366	277	325	323	
PEAK POW MW		498	486	482	481	480	476	471	468	
ENERGY GWH	1617.8	359.0	302.1	145.6	67.9	70.2	206.5	241.9	224.7	
--OAHE--										
NAT INFLOW	446	156	84	42	20	22		14	108	
DEPLETION	92	28	-9	2	1	1	15	21	33	
CHAN STOR	181	109	49			12	27	-16		
EVAPORATION	265	99	84	20	9	10	43			
REG INFLOW	11196	2793	2025	972	454	483	1323	1576	1571	
RELEASE	13108	3965	2035	1070	532	717	1611	1675	1502	
STOR CHANGE	-1911	-1172	-10	-98	-79	-234	-288	-99	69	
STORAGE	20744	19572	19563	19465	19386	19151	18863	18764	18833	
ELEV FTMSL	1613.3	1609.8	1609.8	1609.5	1609.2	1608.5	1607.6	1607.3	1607.5	
DISCH KCFS	80.0	66.6	33.1	36.0	38.4	45.2	26.2	27.2	26.1	
POWER										
AVE POWER MW		727	431	468	497	583	339	351	336	
PEAK POW MW		718	720	718	717	713	708	707	708	
ENERGY GWH	1955.2	523.5	320.5	168.3	83.5	112.0	252.0	261.1	234.2	
--BIG BEND--										
EVAPORATION	51	18	16	4	2	2	9			
REG INFLOW	13057	3947	2019	1067	531	715	1602	1675	1502	
RELEASE	13016	3906	2019	1067	531	715	1602	1675	1502	
STORAGE	1580	1621	1621	1621	1621	1621	1621	1621	1621	
ELEV FTMSL	1419.3	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	1420.0	
DISCH KCFS	80.0	65.6	32.8	35.8	38.2	45.1	26.1	27.2	26.1	
POWER										
AVE POWER MW		305	160	178	189	223	130	133	125	
PEAK POW MW		511	538	538	538	538	538	538	529	
ENERGY GWH	760.8	219.9	119.1	64.1	31.8	42.7	96.9	99.2	87.0	
--FORT RANDALL--										
NAT INFLOW	315	168	22	11	5	6	14	30	59	
DEPLETION	19	7	1	1	0	1	3	3	3	
EVAPORATION	58	25	19	4	2	2	7			
REG INFLOW	13256	4042	2021	1073	534	718	1608	1702	1558	
RELEASE	14214	4586	2794	1394	649	742	1512	1352	1184	
STOR CHANGE	-958	-544	-773	-321	-116	-24	96	350	374	
STORAGE	4074	3530	2757	2436	2320	2296	2392	2742	3116	
ELEV FTMSL	1361.1	1355.0	1344.9	1339.9	1337.9	1337.5	1339.2	1344.7	1349.9	
DISCH KCFS	87.0	77.1	45.4	46.9	46.8	46.8	24.6	22.0	20.6	
POWER										
AVE POWER MW		361	333	308	292	286	179	166	163	
PEAK POW MW		350	319	296	287	285	293	318	339	
ENERGY GWH	1092.6	259.7	247.8	110.7	49.0	54.9	133.4	123.5	113.5	
--GAVINS POINT--										
NAT INFLOW	889	180	168	73	34	39	120	120	156	
DEPLETION	18	-5	2	5	2	3	10	1		
CHAN STOR	123	19	59	-3	0	0	41	5	3	
EVAPORATION	18	6	6	1	1	1	3			
REG INFLOW	15191	4783	3013	1458	680	778	1660	1476	1343	
RELEASE	15206	4760	3013	1458	680	778	1660	1476	1381	
STOR CHANGE	-15	23							-38	
STORAGE	357	380	380	380	380	380	380	380	342	
ELEV FTMSL	1206.6	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0	
DISCH KCFS	90.0	80.0	49.0	49.0	49.0	49.0	27.0	24.0	24.0	
POWER										
AVE POWER MW		109	116	116	116	116	95	84	83	
PEAK POW MW		111	116	116	116	116	117	117	114	
ENERGY GWH	438.7	78.4	85.9	41.6	19.4	22.2	70.4	62.7	58.1	
--GAVINS POINT - SIOUX CITY--										
NAT INFLOW	1418	480	360	120	56	64	180	48	110	
DEPLETION	88	24	11	6	3	3	13	14	14	
REGULATED FLOW AT SIOUX CITY										
KAF	16536	5216	3362	1572	734	838	1827	1510	1477	
KCFS		87.7	54.7	52.8	52.8	52.8	29.7	24.6	25.7	
--TOTAL--										
NAT INFLOW	8764	2364	1774	715	334	381	1005	899	1292	
DEPLETION	-1415	-360	-202	-169	-79	-90	-207	-198	-110	
CHAN STOR	417	136	215	-2	0	16	80	-31	3	
EVAPORATION	894	334	285	67	31	35	143			
STORAGE	63640	60949	59494	58737	58386	58000	57322	56879	56807	
SYSTEM POWER										
AVE POWER MW		2166	1611	1638	1662	1734	1170	1223	1193	
PEAK POW MW		2353	2344	2315	2303	2296	2296	2314	2320	
ENERGY GWH	6570.6	1559.9	1198.4	589.7	279.3	332.9	870.1	909.8	830.5	
DAILY GWH		52.0	38.7	39.3	39.9	41.6	28.1	29.3	28.6	
INI-SUM	30SEP	31OCT	15NOV	22NOV	30NOV	31DEC	31JAN	29FEB		