

The regulation forecast is subject to change daily as actual events occur.

Forecasted release reductions or increases are subject to change based on forecasted temperature and river conditions and releases may be adjusted during winter freeze-in period. Intrasystem regulation may also require release adjustments.

REGULATION FORECAST: 01/21/15

		FTPK				GARR				OAHE				BEND				FTRA				GAPT				SYSTEM				
		24EL	24ID	24OD	24GE	24EL	24ID	24OD	24GE	24EL	24ID	24OD	24GE	24EL	24ID	24OD	24GE	24EL	24ID	24OD	24GE	24EL	24ID	24OD	24GE	GE	SG	DSG		
W	21	2233.4	8.0	6.5	2.12	1839.5	16.3	21.0	6.37	1606.9	24.3	23.0	6.87	1420.4	23.0	26.0	3.13	1342.1	29.8	16.5	3.29	1207.4	19.5	19.0	1.73	23.52	55991	18	W	21
T	22	2233.5	8.0	6.5	2.12	1839.5	16.2	22.0	6.68	1606.9	24.5	22.5	6.72	1420.3	22.5	25.5	3.07	1342.5	29.2	16.5	3.30	1207.4	19.4	19.0	1.73	23.62	56006	15	T	22
F	23	2233.5	8.0	6.5	2.12	1839.4	16.2	22.0	6.67	1606.9	24.8	22.5	6.72	1420.2	22.5	25.5	3.06	1342.9	29.0	16.5	3.31	1207.4	19.1	19.0	1.73	23.63	56021	15	F	23
	24	2233.5	8.0	6.5	2.12	1839.4	16.3	22.0	6.67	1606.9	25.0	22.5	6.72	1420.6	22.5	11.0	1.37	1342.9	14.4	16.5	3.31	1207.4	19.1	19.0	1.73	21.93	56037	15		24
	25	2233.5	8.0	6.5	2.12	1839.4	16.4	22.0	6.67	1606.9	24.8	22.0	6.57	1421.0	22.0	10.0	1.25	1342.7	13.2	16.5	3.31	1207.4	19.1	19.0	1.73	21.66	56052	15		25
M	26	2233.5	8.0	6.5	2.12	1839.3	16.5	23.0	6.97	1606.9	24.5	21.5	6.42	1420.9	21.5	24.5	2.95	1343.1	27.6	16.5	3.32	1207.4	19.0	19.0	1.73	23.52	56064	12	M	26
T	27	2233.5	8.0	6.5	2.12	1839.3	16.5	23.0	6.97	1607.0	24.8	21.5	6.42	1420.8	21.5	24.5	2.94	1343.4	27.5	17.0	3.42	1207.4	19.0	19.0	1.73	23.62	56075	11	T	27
W	28	2233.5	8.0	6.5	2.13	1839.3	16.5	23.0	6.97	1607.0	25.0	21.5	6.42	1420.7	21.5	24.5	2.94	1343.7	27.3	17.0	3.43	1207.4	19.2	19.0	1.73	23.62	56087	12	W	28
T	29	2233.6	8.0	6.5	2.13	1839.2	16.5	23.0	6.97	1607.0	24.8	21.5	6.42	1420.6	21.5	24.5	2.93	1344.0	27.2	17.0	3.44	1207.5	19.4	19.0	1.74	23.63	56099	12	T	29
F	30	2233.6	8.0	6.5	2.13	1839.2	16.5	23.0	6.97	1607.0	24.6	21.5	6.43	1420.5	21.5	24.5	2.93	1344.4	27.1	17.0	3.45	1207.5	19.4	19.0	1.74	23.63	56110	11	F	30
	31	2233.6	7.9	6.5	2.13	1839.1	16.5	23.0	6.96	1607.1	24.5	21.0	6.28	1420.8	21.0	14.0	1.71	1344.3	16.4	16.5	3.35	1207.5	19.3	19.0	1.74	22.16	56121	11		31
	1	2233.6	7.8	6.5	2.13	1839.1	16.5	23.0	6.96	1607.1	24.3	19.0	5.68	1421.0	19.0	12.0	1.47	1344.3	14.3	16.5	3.35	1207.5	19.0	19.0	1.74	21.33	56131	10		1
M	2	2233.6	7.8	6.5	2.13	1839.0	16.5	23.0	6.96	1607.1	24.1	21.5	6.43	1420.9	21.5	24.5	2.92	1344.6	26.6	17.0	3.46	1207.5	18.7	19.0	1.74	23.63	56138	7	M	2
T	3	2233.6	7.7	6.5	2.13	1839.0	16.4	23.0	6.96	1607.1	23.9	21.5	6.43	1420.8	21.5	24.5	2.92	1344.9	26.5	17.0	3.47	1207.5	19.0	19.0	1.74	23.64	56145	7	T	3
W	4	2233.6	7.6	6.5	2.13	1839.0	16.2	23.0	6.96	1607.1	23.8	21.5	6.43	1420.7	21.5	24.5	2.92	1345.1	26.4	17.0	3.48	1207.5	19.2	19.0	1.74	23.64	56151	6	W	4
T	5	2233.6	7.6	6.5	2.13	1838.9	16.1	23.0	6.96	1607.1	23.8	21.5	6.43	1420.6	21.5	24.5	2.91	1345.4	26.2	17.0	3.48	1207.5	19.1	19.0	1.74	23.64	56157	6	T	5
F	6	2233.7	7.5	6.5	2.13	1838.9	15.9	23.0	6.95	1607.2	23.8	21.5	6.43	1420.5	21.5	24.5	2.91	1345.7	26.1	17.0	3.49	1207.5	19.1	19.0	1.74	23.65	56162	5	F	6
	7	2233.7	7.4	6.5	2.13	1838.8	15.7	23.0	6.95	1607.2	23.8	20.0	5.98	1420.8	20.0	11.0	1.34	1345.5	12.4	17.0	3.49	1207.5	19.0	19.0	1.74	21.63	56165	4		7
	8	2233.7	7.4	6.5	2.13	1838.8	15.5	23.0	6.95	1607.2	23.8	18.0	5.38	1421.0	18.0	12.0	1.46	1345.4	13.3	17.0	3.48	1207.5	19.0	19.0	1.74	21.14	56168	3		8
M	9	2233.7	7.3	6.5	2.13	1838.7	15.3	23.0	6.95	1607.2	23.8	22.0	6.58	1420.9	22.0	25.0	2.96	1345.7	26.2	17.0	3.49	1207.5	19.0	19.0	1.74	23.85	56171	2	M	9
T	10	2233.7	7.2	6.5	2.13	1838.7	15.1	23.0	6.95	1607.2	23.8	22.0	6.58	1420.8	22.0	25.0	2.96	1346.0	26.0	17.0	3.50	1207.5	18.9	19.0	1.74	23.85	56172	1	T	10
W	11	2233.7	7.2	6.5	2.13	1838.6	14.9	23.0	6.94	1607.3	23.8	22.0	6.58	1420.7	22.0	25.0	2.96	1346.2	25.9	17.0	3.51	1207.5	18.9	19.0	1.74	23.85	56172	0	W	11
T	12	2233.7	7.2	6.5	2.13	1838.6	14.7	23.0	6.94	1607.3	23.8	22.0	6.58	1420.6	22.0	25.0	2.95	1346.5	25.8	17.0	3.52	1207.5	18.9	19.0	1.74	23.85	56172	0	T	12
F	13	2233.7	7.1	6.5	2.13	1838.5	14.6	23.0	6.94	1607.3	23.8	22.0	6.58	1420.5	22.0	25.0	2.95	1346.7	25.8	17.0	3.52	1207.5	18.8	19.0	1.74	23.86	56171	-1	F	13

Project:

- 24EL Midnight Elevation (feet above sea level)
- 24ID Daily Average Inflow (kcfs)
- 24OD Daily Average Release (kcfs)
- 24GE Daily Power Generation (1000 MWh)

System:

- GE Daily Power Generation (1000 MWh)
- SG Midnight Storage (kAF)
- DSG Daily Storage Change (kAF)

Units:

- kcfs thousand cubic feet per second
- MWh megawatt hour
- kAF thousand acre feet

The midnight elevation (24EL) will be shown in color when a reservoir enters one of the following zones.

ex. **1234.5** - Exclusive Flood Control Zone (24EL)

ex. **1234.5** - Surcharge (24EL)