

Date of Study: 01Jun2021

01Jun2021 / Basic Condition / 17.9 MAF / Balanced  
 Full Serv 1st Half / 1.0 Kcfs Blw Full Serv 2nd Half / Nav End Date: Dec 01  
 Elevations & Storages are for Date Shown  
 Avg Discharge & Energy are Monthly Values

	2021								2022	
	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
<b>Fort Peck</b>										
Elev NGVD29	2233.0	2233.1	2233.0	2232.6	2232.0	2231.5	2231.1	2230.1	2229.0	2228.2
Disch kcfs	8.4	9.5	9.5	9.5	8.0	6.5	6.5	9.2	10.5	10.5
<b>Garrison</b>										
Elev NGVD29	1835.1	1837.0	1838.4	1837.4	1836.3	1835.9	1835.1	1834.1	1833.2	1832.7
Disch kcfs	21.9	22.0	22.0	22.0	18.7	15.0	15.0	17.7	20.5	20.5
<b>Oahe</b>										
Elev NGVD29	1605.8	1606.2	1605.0	1602.8	1600.9	1599.9	1599.4	1600.2	1601.2	1602.6
Disch kcfs	26.0	25.0	29.5	31.7	28.5	19.1	16.9	12.7	15.9	15.4
<b>Big Bend</b>										
Elev NGVD29	1420.8	1420.6	1420.7	1420.7	1420.5	1421.0	1420.7	1420.4	1420.9	1420.7
Disch kcfs	25.3	25.1	29.2	31.2	28.4	18.4	17.0	12.9	15.4	15.4
<b>Fort Randall</b>										
Elev NGVD29	1355.2	1355.2	1355.2	1355.0	1353.6	1344.6	1337.1	1339.4	1344.5	1349.9
Disch kcfs	25.8	26.6	29.0	31.0	30.2	29.2	24.2	11.1	10.8	9.3
<b>Gavins Point</b>										
Elev NGVD29	1206.5	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	29.5	30.0	30.6	32.1	31.6	31.0	26.9	12.5	12.5	12.5
<b>System</b>										
Storage KAF	55200	55876	55924	54887	53766	52622	51730	51539	51693	52122
Energy GWh	6475	806	933	970	850	699	601	511	585	519
Ave Cap MW		2466	2467	2457	2443	2426	2385	2376	2391	2412

01Jun2021 / Lower Basic Condition / 14.5 MAF / Balanced  
 Full Serv 1st Half / 1.9 Kcfs Blw Full Serv 2nd Half / Nav End Date: Dec 01

	2021								2022	
	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
<b>Fort Peck</b>										
Elev NGVD29	2233.0	2231.9	2231.0	2229.9	2228.9	2228.1	2227.3	2225.7	2224.3	2223.0
Disch kcfs	8.4	9.5	9.5	9.5	7.9	6.5	6.5	9.5	10.0	10.0
<b>Garrison</b>										
Elev NGVD29	1835.1	1835.7	1836.0	1834.5	1833.1	1832.4	1831.4	1830.2	1829.2	1828.4
Disch kcfs	21.9	22.0	22.0	22.0	18.4	14.5	14.5	16.9	19.0	19.0
<b>Oahe</b>										
Elev NGVD29	1605.8	1605.1	1602.9	1600.5	1598.1	1596.8	1596.2	1596.8	1597.4	1598.1
Disch kcfs	26.0	28.2	32.8	32.5	29.0	19.7	16.8	13.2	16.4	16.8
<b>Big Bend</b>										
Elev NGVD29	1420.8	1420.6	1420.7	1420.7	1420.5	1421.0	1420.7	1420.4	1420.9	1420.7
Disch kcfs	25.3	28.3	32.4	32.0	28.9	19.1	16.9	13.4	15.9	16.8
<b>Fort Randall</b>										
Elev NGVD29	1355.2	1355.2	1355.1	1355.0	1353.6	1344.6	1337.2	1339.5	1344.5	1350.1
Disch kcfs	25.8	28.7	32.0	31.6	30.6	29.9	24.0	11.5	11.2	10.0
<b>Gavins Point</b>										
Elev NGVD29	1206.5	1206.1	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	29.5	30.0	32.4	32.1	31.6	31.2	26.1	12.5	12.5	12.5
<b>System</b>										
Storage KAF	55200	54898	54165	52821	51456	50065	49007	48652	48581	48691
Energy GWh	6528	854	988	974	847	699	585	506	564	511
Ave Cap MW		2457	2446	2431	2413	2392	2349	2337	2348	2365

01Jun2021 / Upper Basic Condition / 21.8 MAF / Balanced  
 Full Serv 1st Half / Full Serv 2nd Half / Nav End Date: Dec 01

	2021								2022	
	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
<b>Fort Peck</b>										
Elev NGVD29	2233.0	2234.4	2235.3	2235.2	2234.7	2234.4	2234.2	2233.6	2232.8	2232.3
Disch kcfs	8.4	9.5	9.5	9.5	8.4	7.0	7.0	9.0	10.5	10.5
<b>Garrison</b>										
Elev NGVD29	1835.1	1839.0	1841.7	1840.9	1839.9	1839.4	1838.5	1837.7	1836.6	1836.1
Disch kcfs	21.9	23.0	23.0	23.0	20.5	18.0	18.0	18.3	22.5	22.5
<b>Oahe</b>										
Elev NGVD29	1605.8	1607.3	1606.6	1604.8	1603.3	1603.0	1603.1	1603.5	1604.5	1606.1
Disch kcfs	26.0	22.4	29.1	31.7	28.6	19.3	17.6	15.0	17.9	16.2
<b>Big Bend</b>										
Elev NGVD29	1420.8	1420.6	1420.7	1420.7	1420.5	1421.0	1420.7	1420.4	1420.9	1420.9
Disch kcfs	25.3	22.5	28.7	31.2	28.5	18.7	17.7	15.2	17.4	16.2
<b>Fort Randall</b>										
Elev NGVD29	1355.2	1355.3	1355.2	1354.9	1353.6	1344.5	1337.1	1339.4	1344.5	1349.4
Disch kcfs	25.8	24.9	29.0	31.2	30.5	29.6	24.9	13.4	13.1	11.4
<b>Gavins Point</b>										
Elev NGVD29	1206.5	1206.1	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	29.5	30.0	31.6	33.1	32.6	32.0	28.1	15.4	15.4	15.4
<b>System</b>										
Storage KAF	55200	57108	57961	57135	56155	55184	54442	54296	54435	54982
Energy GWh	6798	777	945	992	884	747	655	570	657	571
Ave Cap MW		2477	2485	2480	2470	2456	2419	2409	2424	2447

Date of Study: 01Jun2021

01Jun2021 / Basic Condition / 17.9 MAF / Balanced  
Values in 1000 acre-ft Except as Indicated  
F-Sum: Sum of Forecasted Values. \*: Previous Month's Data

	2021								2022	
	*31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
	F-Sum									
<b>Fort Peck</b>										
Reach Inflow	3670	900	460	280	290	350	380	330	315	365
Depletion	-587	316	-151	-304	-154	-32	-1	-70	-122	-69
Reg Inflow	4257	584	611	584	444	382	381	400	437	434
Evap	434	1	47	85	98	73	71	49	6	3
Release	4793	565	584	584	476	400	387	568	646	583
Stor Change	-971	18	-20	-85	-131	-91	-77	-218	-215	-152
Storage	*14581	14599	14579	14494	14363	14273	14195	13977	13762	13610
Elev NGVD29	*2233.0	2233.1	2233.0	2232.6	2232.0	2231.5	2231.1	2230.1	2229.0	2228.2
Disch kcfs	*8.4	9.5	9.5	9.5	8.0	6.5	6.5	9.2	10.5	10.5
Ave Power MW		131	131	131	110	89	89	126	142	141
Ave Cap MW		217	217	217	216	216	215	215	213	212
Energy GWh	792.3	94.4	97.3	97.2	79.0	66.3	64.0	93.5	105.6	94.9
<b>Garrison</b>										
Reach Inflow	5480	1800	1200	400	340	500	360	250	265	365
Depletion	30	499	-8	-135	-76	-10	-29	-71	-86	-54
Reg Inflow	10234	1865	1792	1119	917	909	776	856	996	1002
Evap	493	-30	14	96	122	119	104	70	-2	0
Release	10433	1309	1353	1353	1115	922	893	1091	1260	1138
Stor Change	-692	587	426	-330	-320	-132	-221	-305	-262	-135
Storage	*17016	17602	18028	17699	17379	17247	17026	16721	16459	16323
Elev NGVD29	*1835.1	1837.0	1838.4	1837.4	1836.3	1835.9	1835.1	1834.1	1833.2	1832.7
Disch kcfs	*21.9	22.0	22.0	22.0	18.7	15.0	15.0	17.7	20.5	20.5
Ave Power MW		276	278	278	236	190	189	222	254	253
Ave Cap MW		561	568	568	564	561	558	555	550	547
Energy GWh	1584.1	198.5	207.0	207.2	170.3	141.1	136.1	165.0	189.0	169.9
<b>Oahe</b>										
Reach Inflow	892	280	170	75	110	70	65	9	13	100
Depletion	84	38	50	20	0	-10	-7	-6	-4	2
Reg Inflow	11247	1551	1473	1408	1249	1002	964	1086	1278	1236
Evap	477	-28	15	80	118	107	95	78	8	5
Release	11737	1488	1815	1947	1694	1172	1007	781	976	858
Stor Change	-967	92	-357	-619	-563	-277	-137	226	294	374
Storage	*18161	18253	17896	17276	16714	16436	16300	16526	16820	17194
Elev NGVD29	*1605.8	1606.2	1605.0	1602.8	1600.9	1599.9	1599.4	1600.2	1601.2	1602.6
Disch kcfs	*26.0	25.0	29.5	31.7	28.5	19.1	16.9	12.7	15.9	15.4
Ave Power MW		300	351	372	331	221	195	148	185	182
Ave Cap MW		702	699	691	681	673	668	670	675	681
Energy GWh	1665.7	215.8	261.3	276.4	238.0	164.3	140.3	109.8	137.6	122.1
<b>Big Bend</b>										
Reg Inflow	11731	1485	1815	1946	1695	1177	1008	781	975	849
Evap	99	3	19	24	21	15	10	5	1	0
Release	11639	1494	1793	1919	1687	1134	1013	793	949	858
Storage	*1680	1668	1671	1674	1660	1688	1674	1657	1682	1673
Elev NGVD29	*1420.8	1420.6	1420.7	1420.7	1420.5	1421.0	1420.7	1420.4	1420.9	1420.7
Disch kcfs	*25.3	25.1	29.2	31.2	28.4	18.4	17.0	12.9	15.4	15.4
Ave Power MW		116	134	143	130	86	80	61	73	73
Ave Cap MW		480	476	474	477	487	489	493	491	491
Energy GWh	653.6	83.7	99.6	106.2	93.9	64.3	57.5	45.4	54.1	48.8
<b>Fort Randall</b>										
Reach Inflow	344	120	45	35	35	2	2	15	30	60
Depletion	110	24	49	32	12	-2	-2	-2	-1	-1
Reg Inflow	11866	1583	1795	1913	1712	1156	1012	809	981	905
Evap	125	-1	13	27	34	30	14	5	1	1
Release	12172	1583	1785	1903	1796	1798	1442	681	666	518
Stor Change	-431	1	-3	-17	-118	-672	-444	123	314	386
Storage	*3425	3426	3423	3405	3288	2616	2172	2295	2608	2994
Elev NGVD29	*1355.2	1355.2	1355.2	1355.0	1353.6	1344.6	1337.1	1339.4	1344.5	1349.9
Disch kcfs	*25.8	26.6	29.0	31.0	30.2	29.2	24.2	11.1	10.8	9.3
Ave Power MW		231	252	268	260	242	185	85	86	78
Ave Cap MW		381	381	381	379	362	327	316	335	355
Energy GWh	1232.7	166.5	187.3	199.1	187.1	179.9	133.4	62.9	64.1	52.5
<b>Gavins Point</b>										
Reach Inflow	1205	230	170	130	115	115	110	100	100	135
Depletion	155	27	65	37	3	3	9	11	1	-1
Reg Inflow	13282	1776	1886	1993	1911	1913	1603	770	768	661
Evap	30	1	6	5	6	6	4	2	0	0
Release	13262	1785	1882	1977	1882	1907	1599	769	769	694
Stor Change	-11	-11	-1	11	24	-0	1	-0	-1	-33
Storage	*339	328	327	339	362	362	363	363	362	328
Elev NGVD29	*1206.5	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	*29.5	30.0	30.6	32.1	31.6	31.0	26.9	12.5	12.5	12.5
Ave Power MW		66	108	113	113	112	97	46	46	46
Ave Cap MW		125	125	125	127	127	127	127	127	126
Energy GWh	546.5	47.5	80.5	84.0	81.5	83.2	70.1	34.4	34.4	30.9
<b>Sioux City</b>										
Reach Inflow	1030	230	160	120	100	95	85	70	60	110
Depletion	250	51	125	77	10	-5	-4	-2	-1	-1
Reg Flow	14080	1963	1915	2016	1973	2009	1729	841	830	805
Reg Flow kcfs		33.0	31.2	32.8	33.2	32.7	29.0	13.7	13.5	14.5
<b>Total</b>										
Reach Inflow	12621	3560	2205	1040	990	1132	1002	774	783	1135
Depletion	42	954	131	-273	-204	-56	-34	-139	-213	-123
Evap	1659	-54	113	318	399	350	298	210	15	10
Storage	*55202	55877	55924	54887	53766	52622	51730	51539	51693	52123
Ave Power MW		1120	1254	1304	1180	939	835	687	786	773
Ave Cap MW		2466	2467	2457	2443	2426	2385	2376	2391	2412
Energy GWh	6474.8	806.5	933.0	970.1	849.7	699.0	601.5	511.1	584.7	519.1
Daily GWh		26.9	30.1	31.3	28.3	22.5	20.0	16.5	18.9	18.5

Date of Study: 01Jun2021

01Jun2021 / Lower Basic Condition / 14.5 MAF / Balanced  
Values in 1000 acre-ft Except as Indicated  
F-Sum: Sum of Forecasted Values. \*: Previous Month's Data

	2021								2022	
	*31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
	F-Sum									
<b>Fort Peck</b>										
Reach Inflow	2671	585	299	196	217	280	304	264	252	274
Depletion	-534	257	-147	-266	-135	-30	-1	-65	-94	-52
Reg Inflow	3205	328	446	462	352	310	305	329	346	326
Evap	418	1	46	83	95	70	68	47	6	3
Release	4744	565	584	584	470	400	387	584	615	555
Stor Change	-1958	-238	-184	-205	-213	-159	-150	-302	-275	-233
Storage	*14581	14343	14159	13954	13741	13582	13432	13130	12856	12623
Elev NGVD29	*2233.0	2231.9	2231.0	2229.9	2228.9	2228.1	2227.3	2225.7	2224.3	2223.0
Disch kcfs	*8.4	9.5	9.5	9.5	7.9	6.5	6.5	9.5	10.0	10.0
Ave Power MW		131	130	129	107	88	87	126	132	131
Ave Cap MW		217	216	214	213	212	211	209	208	206
Energy GWh	772.1	94.1	96.5	96.0	76.9	65.2	62.9	94.1	98.3	88.1
<b>Garrison</b>										
Reach Inflow	3859	1170	780	280	255	400	288	200	212	274
Depletion	-104	263	-92	-134	-59	21	-0	-36	-45	-23
Reg Inflow	8703	1471	1456	998	809	778	675	796	868	852
Evap	472	-30	13	92	117	114	100	67	-2	0
Release	10131	1309	1353	1353	1097	892	863	1041	1168	1055
Stor Change	-1900	192	90	-447	-406	-227	-288	-313	-299	-203
Storage	*17016	17208	17298	16851	16446	16218	15931	15618	15318	15115
Elev NGVD29	*1835.1	1835.7	1836.0	1834.5	1833.1	1832.4	1831.4	1830.2	1829.2	1828.4
Disch kcfs	*21.9	22.0	22.0	22.0	18.4	14.5	14.5	16.9	19.0	19.0
Ave Power MW		275	275	275	229	180	179	207	230	229
Ave Cap MW		558	560	557	550	546	542	538	533	528
Energy GWh	1514.7	197.8	204.9	204.3	164.9	134.0	129.0	154.3	171.5	154.1
<b>Oahe</b>										
Reach Inflow	557	140	93	49	83	52	49	7	10	75
Depletion	84	38	50	20	0	-10	-7	-6	-4	2
Reg Inflow	10615	1411	1396	1382	1205	954	918	1040	1181	1128
Evap	457	-28	14	78	114	102	90	74	8	4
Release	12374	1678	2014	1996	1728	1213	997	810	1007	931
Stor Change	-2216	-239	-633	-693	-636	-361	-168	155	166	193
Storage	*18161	17922	17289	16597	15961	15599	15431	15586	15752	15945
Elev NGVD29	*1605.8	1605.1	1602.9	1600.5	1598.1	1596.8	1596.2	1596.8	1597.4	1598.1
Disch kcfs	*26.0	28.2	32.8	32.5	29.0	19.7	16.8	13.2	16.4	16.8
Ave Power MW		336	384	374	331	223	189	149	186	191
Ave Cap MW		699	691	679	668	658	652	653	656	660
Energy GWh	1723.2	241.6	285.8	278.6	238.0	166.1	135.7	111.0	138.1	128.2
<b>Big Bend</b>										
Reg Inflow	12364	1674	2015	1996	1728	1218	998	810	1006	919
Evap	99	3	19	24	21	15	10	5	1	0
Release	12275	1682	1993	1969	1722	1173	1003	822	980	931
Storage	*1680	1669	1671	1675	1660	1689	1675	1658	1683	1670
Elev NGVD29	*1420.8	1420.6	1420.7	1420.7	1420.5	1421.0	1420.7	1420.4	1420.9	1420.7
Disch kcfs	*25.3	28.3	32.4	32.0	28.9	19.1	16.9	13.4	15.9	16.8
Ave Power MW		130	148	146	133	89	79	63	75	79
Ave Cap MW		477	473	474	476	486	489	493	490	490
Energy GWh	687.3	93.6	110.1	108.8	95.7	66.4	57.0	47.1	55.8	52.8
<b>Fort Randall</b>										
Reach Inflow	216	60	25	23	26	1	2	11	23	45
Depletion	110	24	49	32	12	-2	-2	-2	-1	-1
Reg Inflow	12367	1708	1976	1953	1737	1196	1001	834	1004	958
Evap	125	-1	13	27	34	30	14	6	1	1
Release	12658	1708	1969	1940	1824	1836	1428	705	690	558
Stor Change	-416	1	-6	-15	-120	-670	-441	123	312	399
Storage	*3425	3426	3421	3406	3286	2616	2175	2298	2611	3010
Elev NGVD29	*1355.2	1355.2	1355.1	1355.0	1353.6	1344.6	1337.2	1339.5	1344.5	1350.1
Disch kcfs	*25.8	28.7	32.0	31.6	30.6	29.9	24.0	11.5	11.2	10.0
Ave Power MW		249	277	273	264	247	184	88	89	84
Ave Cap MW		381	381	381	379	362	327	317	335	355
Energy GWh	1281.2	179.1	205.8	202.8	189.8	183.5	132.1	65.3	66.4	56.5
<b>Gavins Point</b>										
Reach Inflow	799	115	93	84	86	86	83	75	75	101
Depletion	155	27	65	37	3	3	9	11	1	-1
Reg Inflow	13354	1777	1995	1990	1910	1924	1560	770	768	661
Evap	30	1	6	5	6	6	4	2	0	0
Release	13335	1785	1992	1974	1880	1918	1554	769	769	694
Stor Change	-11	-9	-3	11	24	-0	2	-1	-1	-33
Storage	*339	330	327	338	362	361	363	362	361	328
Elev NGVD29	*1206.5	1206.1	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	*29.5	30.0	32.4	32.1	31.6	31.2	26.1	12.5	12.5	12.5
Ave Power MW		66	114	113	113	112	95	46	46	46
Ave Cap MW		125	125	125	127	127	127	127	127	126
Energy GWh	549.3	47.5	84.5	83.9	81.4	83.7	68.3	34.4	34.4	31.1
<b>Sioux City</b>										
Reach Inflow	671	115	88	78	75	71	64	52	45	83
Depletion	250	51	125	77	10	-5	-4	-2	-1	-1
Reg Flow	13794	1848	1950	1975	1946	1996	1663	823	815	777
Reg Flow kcfs		31.1	31.7	32.1	32.7	32.5	28.0	13.4	13.2	14.0
<b>Total</b>										
Reach Inflow	8773	2185	1379	710	742	892	788	609	616	851
Depletion	-40	660	51	-234	-168	-23	-5	-100	-144	-75
Evap	1601	-54	111	310	387	337	286	200	14	10
Storage	*55202	54898	54165	52820	51455	50067	49006	48652	48582	48691
Ave Power MW		1186	1327	1310	1176	939	813	680	759	760
Ave Cap MW		2457	2446	2431	2413	2392	2349	2337	2348	2365
Energy GWh	6527.9	853.7	987.5	974.4	846.8	699.0	585.0	506.1	564.4	510.8
Daily GWh		28.5	31.9	31.4	28.2	22.5	19.5	16.3	18.2	18.2

Date of Study: 01Jun2021

01Jun2021 / Upper Basic Condition / 21.8 MAF / Balanced  
Values in 1000 acre-ft Except as Indicated  
F-Sum: Sum of Forecasted Values. \*: Previous Month's Data

	2021								2022	
	*31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
	F-Sum									
<b>Fort Peck</b>										
Reach Inflow	4772	1305	667	364	348	420	456	396	378	438
Depletion	-402	457	-161	-297	-140	-19	-6	-84	-99	-54
Reg Inflow	5174	848	828	661	488	439	462	480	477	492
Evap	448	1	47	87	101	75	74	51	7	4
Release	4863	565	584	584	501	430	417	553	646	583
Stor Change	-137	282	196	-10	-114	-67	-29	-125	-176	-94
Storage	*14581	14863	15059	15049	14934	14868	14839	14714	14538	14444
Elev NGVD29	*2233.0	2234.4	2235.3	2235.2	2234.7	2234.4	2234.2	2233.6	2232.8	2232.3
Disch kcfs	*8.4	9.5	9.5	9.5	8.4	7.0	7.0	9.0	10.5	10.5
Ave Power MW		132	132	132	117	97	97	124	145	144
Ave Cap MW		218	219	220	219	219	219	218	218	217
Energy GWh	814.5	94.7	98.1	98.3	84.2	72.3	69.9	92.6	107.6	96.9
<b>Garrison</b>										
Reach Inflow	7366	2610	1740	520	408	600	432	300	318	438
Depletion	39	626	29	-136	-98	-35	-58	-109	-109	-71
Reg Inflow	12181	2549	2295	1240	1028	1065	906	946	1060	1092
Evap	522	-31	14	101	129	125	110	74	-2	0
Release	11354	1369	1414	1414	1220	1107	1071	1127	1383	1250
Stor Change	305	1211	866	-275	-321	-167	-275	-255	-322	-158
Storage	*17016	18227	19093	18818	18497	18330	18055	17801	17479	17321
Elev NGVD29	*1835.1	1839.0	1841.7	1840.9	1839.9	1839.4	1838.5	1837.7	1836.6	1836.1
Disch kcfs	*21.9	23.0	23.0	23.0	20.5	18.0	18.0	18.3	22.5	22.5
Ave Power MW		290	295	296	263	231	230	233	283	282
Ave Cap MW		565	577	580	577	575	572	569	565	562
Energy GWh	1748.9	208.4	219.2	220.1	189.5	171.8	165.7	173.5	210.9	189.7
<b>Oahe</b>										
Reach Inflow	1246	406	238	101	149	94	88	12	18	140
Depletion	84	38	50	20	0	-10	-7	-6	-4	2
Reg Inflow	12515	1733	1602	1496	1386	1211	1166	1129	1406	1387
Evap	496	-29	15	82	122	111	99	82	8	5
Release	11933	1332	1790	1947	1705	1189	1049	923	1099	899
Stor Change	87	430	-203	-534	-441	-89	17	123	299	484
Storage	*18161	18591	18387	17854	17413	17324	17342	17465	17764	18248
Elev NGVD29	*1605.8	1607.3	1606.6	1604.8	1603.3	1603.0	1603.1	1603.5	1604.5	1606.1
Disch kcfs	*26.0	22.4	29.1	31.7	28.6	19.3	17.6	15.0	17.9	16.2
Ave Power MW		270	350	376	338	228	208	178	213	195
Ave Cap MW		705	706	700	692	687	685	687	691	698
Energy GWh	1720.0	194.5	260.3	280.0	243.3	170.0	149.9	132.7	158.3	130.9
<b>Big Bend</b>										
Reg Inflow	11936	1330	1790	1946	1706	1194	1050	923	1099	900
Evap	99	3	19	24	21	15	10	5	1	0
Release	11833	1339	1767	1919	1698	1150	1054	935	1072	899
Storage	*1680	1668	1671	1674	1660	1688	1674	1657	1683	1683
Elev NGVD29	*1420.8	1420.6	1420.7	1420.7	1420.5	1421.0	1420.7	1420.4	1420.9	1420.9
Disch kcfs	*25.3	22.5	28.7	31.2	28.5	18.7	17.7	15.2	17.4	16.2
Ave Power MW		105	132	143	131	88	83	72	82	76
Ave Cap MW		483	476	474	477	487	488	491	488	490
Energy GWh	664.9	75.4	98.2	106.2	94.5	65.2	59.8	53.4	60.9	51.2
<b>Fort Randall</b>										
Reach Inflow	483	174	63	47	47	3	3	20	42	84
Depletion	110	24	49	32	12	-2	-2	-2	-1	-1
Reg Inflow	12213	1482	1787	1926	1735	1174	1053	955	1117	985
Evap	125	-1	13	27	33	30	14	5	1	1
Release	12555	1479	1780	1920	1814	1821	1481	823	803	634
Stor Change	-466	5	-6	-22	-113	-677	-442	127	313	349
Storage	*3425	3430	3423	3401	3289	2612	2170	2297	2610	2959
Elev NGVD29	*1355.2	1355.3	1355.2	1354.9	1353.6	1344.5	1337.1	1339.4	1344.5	1349.4
Disch kcfs	*25.8	24.9	29.0	31.2	30.5	29.6	24.9	13.4	13.1	11.4
Ave Power MW		217	251	270	262	245	190	102	103	95
Ave Cap MW		381	381	381	379	362	327	316	335	354
Energy GWh	1267.9	156.0	186.8	200.8	188.8	182.0	136.8	75.8	76.9	64.0
<b>Gavins Point</b>										
Reach Inflow	1670	334	238	176	155	155	149	135	140	189
Depletion	155	27	65	37	3	3	9	11	1	-1
Reg Inflow	14113	1777	1947	2054	1971	1974	1674	949	946	821
Evap	30	1	6	5	6	6	4	2	0	0
Release	14095	1785	1943	2038	1941	1969	1670	947	947	855
Stor Change	-12	-10	-1	11	24	-0	0	0	-1	-35
Storage	*339	329	328	339	362	362	362	362	361	327
Elev NGVD29	*1206.5	1206.1	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	*29.5	30.0	31.6	33.1	32.6	32.0	28.1	15.4	15.4	15.4
Ave Power MW		66	111	116	116	115	102	57	57	57
Ave Cap MW		125	125	125	127	127	127	127	127	126
Energy GWh	582.0	47.6	82.7	86.2	83.8	85.7	73.1	42.4	42.4	38.1
<b>Sioux City</b>										
Reach Inflow	1430	334	224	162	135	128	115	94	84	154
Depletion	250	51	125	77	10	-5	-4	-2	-1	-1
Reg Flow	15306	2067	2039	2119	2067	2104	1825	1043	1032	1010
Reg Flow kcfs		34.7	33.2	34.5	34.7	34.2	30.7	17.0	16.8	18.2
<b>Total</b>										
Reach Inflow	16967	5162	3170	1370	1242	1401	1242	958	980	1443
Depletion	235	1222	158	-267	-213	-68	-67	-192	-213	-125
Evap	1719	-55	115	328	413	363	310	219	16	10
Storage	*55202	57107	57962	57135	56156	55184	54442	54295	54434	54982
Ave Power MW		1079	1271	1333	1228	1004	910	767	883	849
Ave Cap MW		2477	2485	2480	2470	2456	2419	2409	2424	2447
Energy GWh	6798.2	776.6	945.3	991.7	884.1	747.1	655.3	570.3	657.1	570.8
Daily GWh		25.9	30.5	32.0	29.5	24.1	21.8	18.4	21.2	20.4