

Date of Study: 01Oct2024

01Oct2024 / Basic Condition / 23.5 MAF / Balanced  
Full Serv -0.5 kcfs 2nd Half / Nav End Date: Dec 01  
Elevations & Storages are for Date Shown. Elevations in Local Project Datum (LPD)  
Avg Discharge & Energy are Monthly Values

	2024 30Sep	31Oct	30Nov	31Dec	2025 31Jan	28Feb
<b>Fort Peck</b>						
Elev feet	2227.0	2226.9	2227.0	2226.8	2226.5	2226.5
Disch kcfs	6.9	4.0	4.0	6.0	7.0	7.0
<b>Garrison</b>						
Elev feet	1838.7	1837.6	1836.5	1834.8	1832.7	1831.2
Disch kcfs	18.2	14.0	14.0	17.8	21.5	21.5
<b>Oahe</b>						
Elev feet	1601.4	1598.5	1597.3	1598.1	1599.4	1600.9
Disch kcfs	30.2	25.8	18.6	13.0	15.7	15.3
<b>Big Bend</b>						
Elev feet	1420.8	1420.5	1420.7	1420.7	1420.5	1420.5
Disch kcfs	29.7	25.9	18.3	12.8	16.0	15.3
<b>Fort Randall</b>						
Elev feet	1351.3	1344.9	1337.4	1339.2	1344.9	1350.2
Disch kcfs	33.6	33.0	26.0	11.2	10.8	9.4
<b>Gavins Point</b>						
Elev feet	1207.7	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	33.5	34.0	28.3	12.5	12.5	12.5
<b>System</b>						
Storage KAF	53484	51868	50780	50515	50541	50877
Energy GWh	2884	774	596	475	552	487
Ave Cap MW		2436	2393	2380	2393	2411

01Oct2024 / Lower Basic Condition / 23.0 MAF / Balanced  
Full Serv -0.5 kcfs 2nd Half / Nav End Date: Dec 01

	2024 30Sep	31Oct	30Nov	31Dec	2025 31Jan	28Feb
<b>Fort Peck</b>						
Elev feet	2227.0	2226.6	2226.3	2225.8	2225.1	2224.7
Disch kcfs	6.9	4.0	4.0	5.0	6.0	6.0
<b>Garrison</b>						
Elev feet	1838.7	1837.5	1836.2	1834.3	1831.8	1829.9
Disch kcfs	18.2	14.0	14.0	16.4	21.0	21.0
<b>Oahe</b>						
Elev feet	1601.4	1598.5	1597.1	1597.5	1598.5	1599.7
Disch kcfs	30.2	26.0	18.9	13.4	16.4	16.2
<b>Big Bend</b>						
Elev feet	1420.8	1420.5	1420.7	1420.7	1420.5	1420.4
Disch kcfs	29.7	26.1	18.7	13.2	16.6	16.2
<b>Fort Randall</b>						
Elev feet	1351.3	1344.9	1337.4	1339.1	1344.9	1350.2
Disch kcfs	33.6	33.3	26.3	11.6	11.3	10.2
<b>Gavins Point</b>						
Elev feet	1207.7	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	33.5	34.0	28.3	12.5	12.5	12.5
<b>System</b>						
Storage KAF	53484	51729	50472	50012	49796	49829
Energy GWh	2874	778	601	461	547	488
Ave Cap MW		2435	2390	2375	2384	2399

01Oct2024 / Upper Basic Condition / 24.0 MAF / Balanced  
Full Serv -0.5 kcfs 2nd Half / Nav End Date: Dec 01

	2024 30Sep	31Oct	30Nov	31Dec	2025 31Jan	28Feb
<b>Fort Peck</b>						
Elev feet	2227.0	2227.2	2227.5	2227.5	2227.5	2227.8
Disch kcfs	6.9	4.0	4.0	6.5	7.5	7.5
<b>Garrison</b>						
Elev feet	1838.7	1837.8	1836.9	1835.5	1833.6	1832.3
Disch kcfs	18.2	14.0	14.0	17.3	22.5	22.5
<b>Oahe</b>						
Elev feet	1601.4	1598.6	1597.6	1598.4	1600.0	1602.1
Disch kcfs	30.2	25.4	18.1	12.4	14.9	14.0
<b>Big Bend</b>						
Elev feet	1420.8	1420.5	1420.7	1420.7	1420.5	1420.4
Disch kcfs	29.7	25.5	17.9	12.1	15.2	14.0
<b>Fort Randall</b>						
Elev feet	1351.3	1344.9	1337.4	1339.1	1344.9	1350.2
Disch kcfs	33.6	32.7	25.5	10.7	10.2	8.6
<b>Gavins Point</b>						
Elev feet	1207.7	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	33.5	34.0	28.3	12.5	12.5	12.5
<b>System</b>						
Storage KAF	53484	51992	51055	50951	51181	51802
Energy GWh	2856	766	588	465	553	483
Ave Cap MW		2437	2396	2385	2401	2423

Date of Study: 01Oct2024

01Oct2024 / Basic Condition / 23.5 MAF / Balanced

Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)

F-Sum: Sum of Forecasted Values. \*: Previous Month's Data

	2024				2025	
	*30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
	F-Sum					
<b>Fort Peck</b>						
Reach Inflow	1550	280	320	300	300	350
Depletion	-223	-31	-1	-75	-86	-31
Reg Inflow	1773	311	321	375	386	381
Evap	193	69	67	47	6	3
Release	1672	246	238	369	430	389
Stor Change	-92	-4	16	-41	-51	-12
Storage	*13366	13362	13378	13337	13286	13274
Elev feet	*2227.0	2226.9	2227.0	2226.8	2226.5	2226.5
Disch kcfs	*6.9	4.0	4.0	6.0	7.0	7.0
Ave Power MW		45	45	68	79	79
Ave Cap MW		210	210	210	210	209
Energy GWh	228.7	33.8	32.7	50.5	58.7	52.9
<b>Garrison</b>						
Reach Inflow	1290	260	250	200	230	350
Depletion	-439	-150	-118	-81	-58	-32
Reg Inflow	3379	659	606	633	710	771
Evap	299	123	107	71	-2	0
Release	5303	861	833	1093	1322	1194
Stor Change	-2223	-324	-334	-531	-610	-423
Storage	*18105	17781	17447	16916	16306	15882
Elev feet	*1838.7	1837.6	1836.5	1834.8	1832.7	1831.2
Disch kcfs	*18.2	14.0	14.0	17.8	21.5	21.5
Ave Power MW		181	180	225	269	266
Ave Cap MW		569	565	559	550	542
Energy GWh	810.2	134.5	129.5	167.8	199.8	178.7
<b>Oahe</b>						
Reach Inflow	148	15	25	8	10	90
Depletion	-10	-9	-5	-3	-1	7
Reg Inflow	5434	885	863	1081	1329	1277
Evap	286	106	92	76	8	4
Release	5302	1584	1105	796	968	849
Stor Change	-153	-805	-334	209	353	423
Storage	*16872	16067	15733	15942	16295	16719
Elev feet	*1601.4	1598.5	1597.3	1598.1	1599.4	1600.9
Disch kcfs	*30.2	25.8	18.6	13.0	15.7	15.3
Ave Power MW		306	218	153	187	184
Ave Cap MW		670	659	659	665	672
Energy GWh	761.8	227.5	157.1	114.1	139.5	123.7
<b>Big Bend</b>						
Reg Inflow	5306	1585	1112	793	967	848
Evap	31	15	10	5	1	0
Release	5298	1590	1091	785	983	849
Storage	*1681	1661	1672	1675	1659	1658
Elev feet	*1420.8	1420.5	1420.7	1420.7	1420.5	1420.5
Disch kcfs	*29.7	25.9	18.3	12.8	16.0	15.3
Ave Power MW		119	85	60	75	71
Ave Cap MW		499	504	508	506	506
Energy GWh	297.6	88.4	61.2	44.5	55.5	48.0
<b>Fort Randall</b>						
Reach Inflow	112	2	-0	15	35	60
Depletion	-8	-2	-2	-2	-1	-1
Reg Inflow	5422	1594	1112	790	1017	908
Evap	51	29	14	6	1	1
Release	5457	2032	1546	690	665	524
Stor Change	-86	-467	-448	95	351	383
Storage	*3102	2635	2188	2283	2633	3016
Elev feet	*1351.3	1344.9	1337.4	1339.2	1344.9	1350.2
Disch kcfs	*33.6	33.0	26.0	11.2	10.8	9.4
Ave Power MW		262	192	83	83	77
Ave Cap MW		360	328	317	335	355
Energy GWh	508.9	195.1	138.3	62.0	62.1	51.5
<b>Gavins Point</b>						
Reach Inflow	460	60	80	90	100	130
Depletion	23	3	9	11	1	-1
Reg Inflow	5980	2090	1690	770	769	661
Evap	12	6	4	2	0	0
Release	6006	2089	1686	769	769	694
Stor Change	-39	-5	0	-0	-0	-33
Storage	*367	362	362	362	362	328
Elev feet	*1207.7	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	*33.5	34.0	28.3	12.5	12.5	12.5
Ave Power MW		127	107	49	49	49
Ave Cap MW		127	127	127	127	126
Energy GWh	276.3	94.5	76.7	36.2	36.2	32.7
<b>Sioux City</b>						
Reach Inflow	415	90	80	70	65	110
Depletion	-13	-6	-4	-2	-1	-1
Reg Flow	6481	2183	1817	841	835	805
Reg Flow kcfs		35.5	30.5	13.7	13.6	14.5
<b>Total</b>						
Reach Inflow	3975	707	755	683	740	1090
Depletion	-669	-194	-121	-151	-145	-57
Evap	872	348	294	206	14	10
Storage	*53484	51868	50780	50515	50541	50877
Ave Power MW		1040	827	639	742	725
Ave Cap MW		2436	2393	2380	2393	2411
Energy GWh	2883.6	773.7	595.6	475.1	551.8	487.5
Daily GWh		25.0	19.9	15.3	17.8	17.4

Date of Study: 01Oct2024

01Oct2024 / Lower Basic Condition / 23.0 MAF / Balanced  
Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)  
F-Sum: Sum of Forecasted Values. \*: Previous Month's Data

	2024				2025	
	*30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
	F-Sum					
<b>Fort Peck</b>						
Reach Inflow	1222	224	256	240	240	262
Depletion	-26	-16	14	-19	-10	6
Reg Inflow	1248	240	242	259	250	256
Evap	191	68	67	47	6	3
Release	1494	246	238	307	369	333
Stor Change	-437	-74	-62	-95	-125	-80
Storage	*13366	13292	13229	13134	13009	12929
Elev feet	*2227.0	2226.6	2226.3	2225.8	2225.1	2224.7
Disch kcfs	*6.9	4.0	4.0	5.0	6.0	6.0
Ave Power MW		45	45	56	67	67
Ave Cap MW		210	209	209	208	207
Energy GWh	203.6	33.8	32.7	42.0	50.1	45.1
<b>Garrison</b>						
Reach Inflow	1015	208	200	160	184	262
Depletion	-371	-152	-106	-54	-39	-20
Reg Inflow	2866	610	544	513	584	615
Evap	298	122	106	71	-2	0
Release	5160	861	833	1009	1291	1166
Stor Change	-2592	-373	-396	-567	-705	-551
Storage	*18105	17732	17336	16769	16064	15513
Elev feet	*1838.7	1837.5	1836.2	1834.3	1831.8	1829.9
Disch kcfs	*18.2	14.0	14.0	16.4	21.0	21.0
Ave Power MW		181	180	208	262	258
Ave Cap MW		569	564	557	547	538
Energy GWh	786.6	134.4	129.3	154.7	194.6	173.5
<b>Oahe</b>						
Reach Inflow	111	11	19	6	8	67
Depletion	-10	-9	-5	-3	-1	7
Reg Inflow	5256	881	857	1002	1291	1227
Evap	285	106	92	75	8	4
Release	5456	1598	1126	823	1007	902
Stor Change	-484	-823	-361	103	276	320
Storage	*16872	16049	15688	15792	16068	16388
Elev feet	*1601.4	1598.5	1597.1	1597.5	1598.5	1599.7
Disch kcfs	*30.2	26.0	18.9	13.4	16.4	16.2
Ave Power MW		308	222	158	194	194
Ave Cap MW		670	658	657	661	667
Energy GWh	781.3	229.3	159.8	117.6	144.2	130.4
<b>Big Bend</b>						
Reg Inflow	5459	1599	1133	819	1006	902
Evap	31	15	10	5	1	0
Release	5452	1604	1112	812	1021	902
Storage	*1681	1661	1672	1675	1659	1657
Elev feet	*1420.8	1420.5	1420.7	1420.7	1420.5	1420.4
Disch kcfs	*29.7	26.1	18.7	13.2	16.6	16.2
Ave Power MW		120	87	62	77	76
Ave Cap MW		499	504	508	505	506
Energy GWh	306.0	89.1	62.4	46.0	57.6	50.9
<b>Fort Randall</b>						
Reach Inflow	84	1	-0	11	26	45
Depletion	-8	-2	-2	-2	-1	-1
Reg Inflow	5547	1608	1133	812	1047	946
Evap	51	29	14	5	1	1
Release	5582	2048	1566	713	692	564
Stor Change	-86	-469	-446	94	354	381
Storage	*3102	2633	2186	2280	2634	3016
Elev feet	*1351.3	1344.9	1337.4	1339.1	1344.9	1350.2
Disch kcfs	*33.6	33.3	26.3	11.6	11.3	10.2
Ave Power MW		264	194	86	87	82
Ave Cap MW		360	328	317	335	355
Energy GWh	520.3	196.5	140.0	63.9	64.5	55.4
<b>Gavins Point</b>						
Reach Inflow	345	45	60	67	75	97
Depletion	23	3	9	11	1	-1
Reg Inflow	5978	2090	1689	771	769	659
Evap	12	6	4	2	0	0
Release	6006	2089	1686	769	769	694
Stor Change	-41	-5	-0	0	-0	-35
Storage	*367	362	361	362	362	326
Elev feet	*1207.7	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	*33.5	34.0	28.3	12.5	12.5	12.5
Ave Power MW		127	107	49	49	49
Ave Cap MW		127	127	127	127	126
Energy GWh	276.3	94.4	76.7	36.2	36.2	32.7
<b>Sioux City</b>						
Reach Inflow	311	67	60	52	49	83
Depletion	-13	-6	-4	-2	-1	-1
Reg Flow	6377	2161	1797	823	818	777
Reg Flow kcfs		35.1	30.2	13.4	13.3	14.0
<b>Total</b>						
Reach Inflow	3088	557	594	537	582	817
Depletion	-404	-182	-94	-68	-51	-8
Evap	869	348	293	205	14	10
Storage	*53484	51729	50472	50012	49796	49829
Ave Power MW		1045	834	619	736	726
Ave Cap MW		2435	2390	2375	2384	2399
Energy GWh	2874.2	777.6	600.8	460.5	547.2	488.0
Daily GWh		25.1	20.0	14.9	17.7	17.4

Date of Study: 01Oct2024

01Oct2024 / Upper Basic Condition / 24.0 MAF / Balanced  
Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)  
F-Sum: Sum of Forecasted Values. \*: Previous Month's Data

	2024				2025	
	*30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
	F-Sum					
<b>Fort Peck</b>						
Reach Inflow	1860	336	384	360	360	420
Depletion	-256	-16	8	-85	-104	-59
Reg Inflow	2116	352	376	445	464	479
Evap	193	69	68	47	6	3
Release	1761	246	238	400	461	417
Stor Change	161	38	71	-3	-4	59
Storage	*13366	13403	13474	13471	13468	13526
Elev feet	*2227.0	2227.2	2227.5	2227.5	2227.5	2227.8
Disch kcfs	*6.9	4.0	4.0	6.5	7.5	7.5
Ave Power MW		46	46	74	85	85
Ave Cap MW		210	211	211	211	211
Energy GWh	241.6	33.9	32.8	54.8	63.1	57.0
<b>Garrison</b>						
Reach Inflow	1548	312	300	240	276	420
Depletion	-507	-153	-127	-100	-81	-46
Reg Inflow	3791	715	665	719	810	882
Evap	300	123	107	72	-2	0
Release	5388	861	833	1061	1383	1250
Stor Change	-1897	-269	-275	-414	-572	-367
Storage	*18105	17836	17561	17147	16575	16208
Elev feet	*1838.7	1837.8	1836.9	1835.5	1833.6	1832.3
Disch kcfs	*18.2	14.0	14.0	17.3	22.5	22.5
Ave Power MW		181	180	220	283	280
Ave Cap MW		570	566	562	554	547
Energy GWh	827.3	134.9	129.9	163.9	210.3	188.3
<b>Oahe</b>						
Reach Inflow	205	20	34	11	14	126
Depletion	-10	-9	-5	-3	-1	7
Reg Inflow	5573	890	872	1052	1391	1368
Evap	287	106	92	76	8	4
Release	5089	1559	1076	760	916	778
Stor Change	198	-775	-296	216	467	586
Storage	*16872	16096	15800	16016	16483	17070
Elev feet	*1601.4	1598.6	1597.6	1598.4	1600.0	1602.1
Disch kcfs	*30.2	25.4	18.1	12.4	14.9	14.0
Ave Power MW		300	212	146	178	170
Ave Cap MW		670	659	660	667	677
Energy GWh	731.5	223.5	152.8	108.9	132.3	114.0
<b>Big Bend</b>						
Reg Inflow	5093	1561	1083	756	916	777
Evap	31	15	10	5	1	0
Release	5086	1565	1064	747	932	778
Storage	*1681	1661	1671	1675	1658	1657
Elev feet	*1420.8	1420.5	1420.7	1420.7	1420.5	1420.4
Disch kcfs	*29.7	25.5	17.9	12.1	15.2	14.0
Ave Power MW		117	83	57	71	66
Ave Cap MW		500	504	508	507	507
Energy GWh	285.9	87.0	59.8	42.3	52.7	44.0
<b>Fort Randall</b>						
Reach Inflow	155	3	-1	20	49	84
Depletion	-8	-2	-2	-2	-1	-1
Reg Inflow	5254	1571	1085	757	981	860
Evap	51	29	14	5	1	1
Release	5290	2009	1518	658	624	480
Stor Change	-86	-468	-447	93	356	379
Storage	*3102	2634	2187	2280	2636	3015
Elev feet	*1351.3	1344.9	1337.4	1339.1	1344.9	1350.2
Disch kcfs	*33.6	32.7	25.5	10.7	10.2	8.6
Ave Power MW		259	188	79	78	70
Ave Cap MW		360	328	317	335	355
Energy GWh	492.4	192.5	135.6	59.0	58.2	47.1
<b>Gavins Point</b>						
Reach Inflow	633	81	108	121	140	182
Depletion	23	3	9	11	1	-1
Reg Inflow	5978	2090	1690	771	768	659
Evap	12	6	4	2	0	0
Release	6006	2089	1686	769	769	694
Stor Change	-41	-5	-0	1	-1	-35
Storage	*367	362	362	362	361	326
Elev feet	*1207.7	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	*33.5	34.0	28.3	12.5	12.5	12.5
Ave Power MW		127	107	49	49	49
Ave Cap MW		127	127	127	127	126
Energy GWh	276.9	94.6	76.9	36.3	36.3	32.8
<b>Sioux City</b>						
Reach Inflow	569	121	108	94	91	154
Depletion	-13	-6	-4	-2	-1	-1
Reg Flow	6635	2215	1845	865	861	849
Reg Flow kcfs		36.0	31.0	14.1	14.0	15.3
<b>Total</b>						
Reach Inflow	4970	873	933	847	930	1386
Depletion	-771	-183	-121	-181	-186	-99
Evap	875	348	295	207	15	10
Storage	*53484	51992	51055	50951	51181	51802
Ave Power MW		1030	816	625	743	719
Ave Cap MW		2437	2396	2385	2401	2423
Energy GWh	2855.6	766.4	587.8	465.2	553.0	483.2
Daily GWh		24.7	19.6	15.0	17.8	17.3