

Date of Study: 02Dec2024

01Dec2024 / Basic Condition / 22.9 MAF / Balanced

Elevations & Storages are for Date Shown. Elevations in Local Project Datum (LPD)
Avg Discharge & Energy are Monthly Values

	2024 30Nov	31Dec	2025 31Jan	28Feb
Fort Peck				
Elev feet	2226.4	2225.7	2225.2	2225.3
Disch kcfs	4.5	5.5	6.5	6.5
Garrison				
Elev feet	1836.4	1834.4	1832.0	1830.4
Disch kcfs	14.1	17.6	22.0	22.0
Oahe				
Elev feet	1596.2	1597.1	1598.5	1600.2
Disch kcfs	22.3	12.4	15.7	15.3
Big Bend				
Elev feet	1420.9	1420.8	1420.5	1420.4
Disch kcfs	22.1	12.5	16.0	15.3
Fort Randall				
Elev feet	1338.3	1339.2	1344.8	1350.2
Disch kcfs	26.9	11.7	10.8	9.4
Gavins Point				
Elev feet	1207.8	1207.5	1207.5	1206.0
Disch kcfs	29.1	13.0	12.5	12.5
System				
Storage KAF	50405	49952	49868	50233
Energy GWh	1510	470	553	488
Ave Cap MW		2371	2381	2399

01Dec2024 / Lower Basic Condition / 22.8 MAF / Balanced

	2024 30Nov	31Dec	2025 31Jan	28Feb
Fort Peck				
Elev feet	2226.4	2225.2	2224.4	2224.3
Disch kcfs	4.5	5.5	5.5	5.0
Garrison				
Elev feet	1836.4	1834.4	1831.7	1829.5
Disch kcfs	14.1	16.7	21.5	21.5
Oahe				
Elev feet	1596.2	1596.8	1598.0	1599.3
Disch kcfs	22.3	12.8	16.3	16.2
Big Bend				
Elev feet	1420.9	1420.8	1420.5	1420.4
Disch kcfs	22.1	12.8	16.6	16.2
Fort Randall				
Elev feet	1338.3	1339.2	1344.9	1350.2
Disch kcfs	26.9	12.0	11.2	10.1
Gavins Point				
Elev feet	1207.8	1207.5	1207.5	1206.0
Disch kcfs	29.1	13.0	12.5	12.5
System				
Storage KAF	50405	49787	49493	49554
Energy GWh	1502	468	549	485
Ave Cap MW		2370	2377	2391

01Dec2024 / Upper Basic Condition / 23.0 MAF / Balanced

	2024 30Nov	31Dec	2025 31Jan	28Feb
Fort Peck				
Elev feet	2226.4	2225.9	2225.7	2226.3
Disch kcfs	4.5	5.5	6.5	7.0
Garrison				
Elev feet	1836.4	1834.7	1832.5	1831.1
Disch kcfs	14.1	17.4	22.0	22.5
Oahe				
Elev feet	1596.2	1597.2	1598.8	1601.0
Disch kcfs	22.3	11.9	14.8	13.9
Big Bend				
Elev feet	1420.9	1420.7	1420.5	1420.4
Disch kcfs	22.1	12.0	15.1	13.9
Fort Randall				
Elev feet	1338.3	1339.2	1344.8	1350.2
Disch kcfs	26.9	11.3	10.2	8.5
Gavins Point				
Elev feet	1207.8	1207.5	1207.5	1206.0
Disch kcfs	29.1	13.0	12.5	12.5
System				
Storage KAF	50405	50073	50176	50839
Energy GWh	1474	459	539	476
Ave Cap MW		2372	2384	2406

Date of Study: 02Dec2024

01Dec2024 / Basic Condition / 22.9 MAF / Balanced

Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)

F-Sum: Sum of Forecasted Values. *: Previous Month's Data

	2024	2025		
	*30Nov	31Dec	31Jan	28Feb
	F-Sum			
Fort Peck				
Reach Inflow	750	170	220	360
Depletion	-191	-75	-86	-31
Reg Inflow	941	245	306	391
Evap	56	47	6	3
Release	1099	338	400	361
Stor Change	-214	-140	-100	26
Storage	*13266	13126	13026	13052
Elev feet	*2226.4	2225.7	2225.2	2225.3
Disch kcfs	*4.5	5.5	6.5	6.5
Ave Power MW		62	73	73
Ave Cap MW		209	208	208
Energy GWh	149.5	46.2	54.3	49.0
Garrison				
Reach Inflow	700	140	200	360
Depletion	-171	-81	-58	-32
Reg Inflow	1964	561	650	753
Evap	70	71	-2	0
Release	3657	1082	1353	1222
Stor Change	-1763	-592	-702	-469
Storage	*17418	16826	16124	15655
Elev feet	*1836.4	1834.4	1832.0	1830.4
Disch kcfs	*14.1	17.6	22.0	22.0
Ave Power MW		221	272	269
Ave Cap MW		558	548	539
Energy GWh	547.6	164.8	202.3	180.6
Oahe				
Reach Inflow	120	10	10	100
Depletion	4	-3	-1	7
Reg Inflow	3749	1076	1358	1315
Evap	87	75	8	4
Release	2577	762	966	849
Stor Change	1086	240	385	461
Storage	*15440	15680	16065	16526
Elev feet	*1596.2	1597.1	1598.5	1600.2
Disch kcfs	*22.3	12.4	15.7	15.3
Ave Power MW		144	184	182
Ave Cap MW		654	660	668
Energy GWh	366.6	107.5	137.1	122.0
Big Bend				
Reg Inflow	2576	762	965	848
Evap	6	5	1	0
Release	2596	766	982	849
Storage	*1684	1676	1659	1658
Elev feet	*1420.9	1420.8	1420.5	1420.4
Disch kcfs	*22.1	12.5	16.0	15.3
Ave Power MW		58	74	71
Ave Cap MW		505	502	503
Energy GWh	145.7	43.1	55.0	47.6
Fort Randall				
Reach Inflow	105	10	35	60
Depletion	-3	-2	-1	-1
Reg Inflow	2695	771	1016	908
Evap	8	6	1	1
Release	1910	721	665	524
Stor Change	777	44	350	383
Storage	*2237	2282	2632	3014
Elev feet	*1338.3	1339.2	1344.8	1350.2
Disch kcfs	*26.9	11.7	10.8	9.4
Ave Power MW		94	90	83
Ave Cap MW		318	335	355
Energy GWh	193.0	70.2	67.2	55.7
Gavins Point				
Reach Inflow	300	70	100	130
Depletion	11	11	1	-1
Reg Inflow	2222	792	768	661
Evap	2	2	0	0
Release	2261	798	769	694
Stor Change	-42	-8	-1	-33
Storage	*370	362	362	328
Elev feet	*1207.8	1207.5	1207.5	1206.0
Disch kcfs	*29.1	13.0	12.5	12.5
Ave Power MW		51	49	49
Ave Cap MW		127	127	126
Energy GWh	107.9	38.1	36.7	33.1
Sioux City				
Reach Inflow	220	50	60	110
Depletion	-4	-2	-1	-1
Reg Flow	2490	856	830	805
Reg Flow kcfs		13.9	13.5	14.5
Total				
Reach Inflow	2195	450	625	1120
Depletion	-354	-151	-145	-57
Evap	228	204	14	10
Storage	*50405	49952	49868	50233
Ave Power MW		632	743	726
Ave Cap MW		2371	2381	2399
Energy GWh	1510.3	469.9	552.6	487.9
Daily GWh		15.2	17.8	17.4

Date of Study: 02Dec2024

01Dec2024 / Lower Basic Condition / 22.8 MAF / Balanced
Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)
F-Sum: Sum of Forecasted Values. *: Previous Month's Data

	2024	2025		
	*30Nov	31Dec	31Jan	28Feb
	F-Sum			
Fort Peck				
Reach Inflow	582	136	176	270
Depletion	-23	-19	-10	6
Reg Inflow	605	155	186	264
Evap	56	47	6	3
Release	954	338	338	278
Stor Change	-405	-230	-158	-17
Storage	*13266	13036	12877	12860
Elev feet	*2226.4	2225.2	2224.4	2224.3
Disch kcfs	*4.5	5.5	5.5	5.0
Ave Power MW		62	62	56
Ave Cap MW		209	207	207
Energy GWh	129.7	46.2	45.9	37.7
Garrison				
Reach Inflow	542	112	160	270
Depletion	-113	-54	-39	-20
Reg Inflow	1615	506	538	572
Evap	70	71	-2	0
Release	3544	1028	1322	1194
Stor Change	-1999	-593	-783	-623
Storage	*17418	16825	16042	15419
Elev feet	*1836.4	1834.4	1831.7	1829.5
Disch kcfs	*14.1	16.7	21.5	21.5
Ave Power MW		211	266	262
Ave Cap MW		558	548	537
Energy GWh	530.5	156.8	197.7	176.0
Oahe				
Reach Inflow	90	8	8	75
Depletion	4	-3	-1	7
Reg Inflow	3609	1024	1323	1262
Evap	86	75	8	4
Release	2689	784	1004	900
Stor Change	834	165	312	357
Storage	*15440	15605	15917	16274
Elev feet	*1596.2	1596.8	1598.0	1599.3
Disch kcfs	*22.3	12.8	16.3	16.2
Ave Power MW		149	191	191
Ave Cap MW		653	658	664
Energy GWh	381.0	110.6	141.9	128.6
Big Bend				
Reg Inflow	2687	785	1003	900
Evap	6	5	1	0
Release	2708	788	1020	900
Storage	*1684	1676	1659	1657
Elev feet	*1420.9	1420.8	1420.5	1420.4
Disch kcfs	*22.1	12.8	16.6	16.2
Ave Power MW		60	77	75
Ave Cap MW		505	502	502
Energy GWh	151.8	44.4	57.1	50.4
Fort Randall				
Reach Inflow	79	8	26	45
Depletion	-3	-2	-1	-1
Reg Inflow	2780	791	1045	944
Evap	8	6	1	1
Release	1992	739	691	562
Stor Change	779	46	353	381
Storage	*2237	2283	2636	3016
Elev feet	*1338.3	1339.2	1344.9	1350.2
Disch kcfs	*26.9	12.0	11.2	10.1
Ave Power MW		97	94	89
Ave Cap MW		318	335	355
Energy GWh	201.4	72.0	69.7	59.7
Gavins Point				
Reach Inflow	225	52	75	97
Depletion	11	11	1	-1
Reg Inflow	2221	792	769	661
Evap	2	2	0	0
Release	2261	798	769	694
Stor Change	-42	-8	-0	-34
Storage	*370	362	362	328
Elev feet	*1207.8	1207.5	1207.5	1206.0
Disch kcfs	*29.1	13.0	12.5	12.5
Ave Power MW		51	49	49
Ave Cap MW		127	127	126
Energy GWh	107.9	38.1	36.7	33.1
Sioux City				
Reach Inflow	165	37	45	83
Depletion	-4	-2	-1	-1
Reg Flow	2435	843	815	777
Reg Flow kcfs		13.7	13.2	14.0
Total				
Reach Inflow	1683	353	490	840
Depletion	-128	-68	-51	-8
Evap	228	204	14	10
Storage	*50405	49787	49493	49554
Ave Power MW		629	738	722
Ave Cap MW		2370	2377	2391
Energy GWh	1502.3	468.0	549.0	485.4
Daily GWh		15.1	17.7	17.3

Date of Study: 02Dec2024

01Dec2024 / Upper Basic Condition / 23.0 MAF / Balanced
Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)
F-Sum: Sum of Forecasted Values. *: Previous Month's Data

	2024	2025		
	*30Nov	31Dec	31Jan	28Feb
	F-Sum			
Fort Peck				
Reach Inflow	900	204	264	432
Depletion	-247	-85	-104	-59
Reg Inflow	1147	289	368	491
Evap	56	47	6	3
Release	1127	338	400	389
Stor Change	-36	-96	-38	99
Storage	*13266	13169	13131	13230
Elev feet	*2226.4	2225.9	2225.7	2226.3
Disch kcfs	*4.5	5.5	6.5	7.0
Ave Power MW		62	73	79
Ave Cap MW		209	209	209
Energy GWh	153.6	46.3	54.4	52.9
Garrison				
Reach Inflow	840	168	240	432
Depletion	-227	-100	-81	-46
Reg Inflow	2183	609	712	862
Evap	70	71	-2	0
Release	3669	1067	1353	1250
Stor Change	-1556	-530	-639	-387
Storage	*17418	16888	16250	15862
Elev feet	*1836.4	1834.7	1832.5	1831.1
Disch kcfs	*14.1	17.4	22.0	22.5
Ave Power MW		219	272	276
Ave Cap MW		559	550	542
Energy GWh	550.5	162.6	202.7	185.2
Oahe				
Reach Inflow	167	14	14	140
Depletion	4	-3	-1	7
Reg Inflow	3808	1061	1366	1381
Evap	87	75	8	4
Release	2414	730	911	773
Stor Change	1307	257	447	604
Storage	*15440	15697	16143	16747
Elev feet	*1596.2	1597.2	1598.8	1601.0
Disch kcfs	*22.3	11.9	14.8	13.9
Ave Power MW		139	174	166
Ave Cap MW		654	661	671
Energy GWh	344.4	103.1	129.7	111.6
Big Bend				
Reg Inflow	2414	731	911	772
Evap	6	5	1	0
Release	2435	735	927	773
Storage	*1684	1675	1658	1657
Elev feet	*1420.9	1420.7	1420.5	1420.4
Disch kcfs	*22.1	12.0	15.1	13.9
Ave Power MW		56	70	65
Ave Cap MW		505	503	504
Energy GWh	136.8	41.4	52.0	43.4
Fort Randall				
Reach Inflow	147	14	49	84
Depletion	-3	-2	-1	-1
Reg Inflow	2576	744	976	856
Evap	8	6	1	1
Release	1790	694	624	472
Stor Change	778	45	350	383
Storage	*2237	2282	2632	3015
Elev feet	*1338.3	1339.2	1344.8	1350.2
Disch kcfs	*26.9	11.3	10.2	8.5
Ave Power MW		91	85	75
Ave Cap MW		318	335	355
Energy GWh	181.0	67.6	63.1	50.2
Gavins Point				
Reach Inflow	417	94	140	182
Depletion	11	11	1	-1
Reg Inflow	2221	792	769	661
Evap	2	2	0	0
Release	2261	798	769	694
Stor Change	-42	-8	0	-34
Storage	*370	362	362	328
Elev feet	*1207.8	1207.5	1207.5	1206.0
Disch kcfs	*29.1	13.0	12.5	12.5
Ave Power MW		51	49	49
Ave Cap MW		127	127	126
Energy GWh	107.9	38.1	36.7	33.1
Sioux City				
Reach Inflow	306	67	84	154
Depletion	-4	-2	-1	-1
Reg Flow	2576	873	854	849
Reg Flow kcfs		14.2	13.9	15.3
Total				
Reach Inflow	2776	561	791	1424
Depletion	-466	-181	-186	-99
Evap	229	205	14	10
Storage	*50405	50073	50176	50839
Ave Power MW		617	724	709
Ave Cap MW		2372	2384	2406
Energy GWh	1474.1	459.1	538.6	476.4
Daily GWh		14.8	17.4	17.0