

Date of Study: 02Feb2024

01Feb2024 / Basic Condition / 18.8 MAF / Balanced  
Full Serv -1.4 kcfs 1st Half / Full Serv -3.6 kcfs 2nd Half / Nav End Date: Dec 01  
Elevations & Storages are for Date Shown. Elevations in Local Project Datum (LPD)  
Avg Discharge & Energy are Monthly Values

	2024												2025	
	31Jan	29Feb	31Mar	30Apr	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
<b>Fort Peck</b>														
Elev feet	2229.3	2229.7	2230.2	2229.7	2227.9	2227.2	2226.8	2225.9	2225.3	2225.5	2225.6	2225.1	2224.3	2223.8
Disch kcfs	5.6	5.0	5.0	8.4	13.7	16.2	9.1	9.0	6.8	4.5	4.5	7.5	9.0	9.0
<b>Garrison</b>														
Elev feet	1836.9	1834.4	1834.0	1833.4	1834.2	1836.6	1836.7	1835.5	1834.2	1833.4	1832.4	1831.1	1829.9	1829.1
Disch kcfs	18.3	24.9	16.0	17.9	19.5	21.0	21.0	21.0	18.5	16.0	16.0	17.2	20.0	20.0
<b>Oahe</b>														
Elev feet	1600.0	1602.1	1602.2	1601.9	1601.3	1601.1	1599.5	1597.4	1595.8	1595.3	1595.7	1596.5	1597.5	1598.8
Disch kcfs	16.3	14.5	20.3	22.6	26.0	27.5	29.8	29.9	26.3	17.7	14.2	12.8	15.8	15.0
<b>Big Bend</b>														
Elev feet	1420.8	1420.6	1421.0	1420.8	1420.4	1421.0	1420.6	1420.6	1420.9	1420.5	1420.7	1420.7	1420.5	1420.5
Disch kcfs	16.2	14.7	19.8	22.8	26.2	26.9	29.8	29.5	25.8	17.8	13.9	12.6	16.0	15.0
<b>Fort Randall</b>														
Elev feet	1345.2	1349.7	1354.8	1355.0	1355.3	1355.0	1355.1	1355.2	1353.2	1344.8	1337.4	1339.1	1344.9	1350.2
Disch kcfs	12.1	9.4	16.2	24.7	28.1	29.8	29.4	29.3	28.4	27.6	21.4	11.1	10.8	9.3
<b>Gavins Point</b>														
Elev feet	1207.4	1205.9	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.1
Disch kcfs	14.4	13.0	19.8	28.4	31.5	32.9	30.7	30.4	29.9	29.5	24.1	12.5	12.5	12.5
<b>System</b>														
Storage KAF	52547	52745	53205	52843	52549	53090	52579	51486	50445	49473	48857	48702	48802	49217
Energy GWh	9107	521	613	749	905	925	930	923	799	666	540	484	560	491
Ave Cap MW		2437	2452	2454	2449	2451	2451	2438	2423	2401	2364	2353	2368	2388

01Feb2024 / Lower Basic Condition / 12.4 MAF / Balanced  
Full Serv -2.1 kcfs 1st Half / Min Serv 2nd Half / Nav End Date: Nov 23

	2024												2025	
	31Jan	29Feb	31Mar	30Apr	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
<b>Fort Peck</b>														
Elev feet	2229.3	2229.1	2228.9	2227.5	2226.4	2226.5	2224.6	2222.6	2221.3	2220.8	2220.5	2219.3	2218.0	2216.8
Disch kcfs	5.6	5.0	5.0	8.7	10.6	9.5	9.5	9.5	7.0	4.5	4.5	8.0	9.0	9.0
<b>Garrison</b>														
Elev feet	1836.9	1834.0	1832.8	1831.9	1831.8	1832.4	1832.1	1830.9	1829.6	1828.6	1827.4	1825.9	1824.5	1823.4
Disch kcfs	18.3	24.9	16.0	17.0	18.5	19.0	19.0	19.0	17.0	15.0	15.0	16.7	19.0	19.0
<b>Oahe</b>														
Elev feet	1600.0	1601.9	1601.0	1599.6	1597.7	1595.9	1593.7	1591.2	1589.4	1589.5	1590.7	1591.3	1592.0	1592.9
Disch kcfs	16.3	15.5	22.9	24.9	28.4	29.7	28.8	28.5	24.5	14.1	9.8	13.2	16.3	16.1
<b>Big Bend</b>														
Elev feet	1420.8	1420.6	1421.0	1420.8	1420.4	1421.0	1420.6	1420.7	1420.9	1420.5	1420.7	1420.8	1420.5	1420.4
Disch kcfs	16.2	15.7	22.5	25.1	28.6	29.2	28.8	28.0	24.0	14.3	9.4	13.1	16.5	16.1
<b>Fort Randall</b>														
Elev feet	1345.2	1349.7	1354.8	1355.0	1355.3	1355.0	1355.1	1355.2	1353.2	1343.3	1337.5	1339.2	1344.9	1350.2
Disch kcfs	12.1	10.2	17.4	25.9	29.3	30.8	28.1	27.6	26.5	25.7	15.2	11.5	11.2	10.0
<b>Gavins Point</b>														
Elev feet	1207.4	1206.0	1206.0	1206.0	1206.0	1205.9	1206.0	1206.5	1207.5	1207.5	1207.6	1207.5	1207.5	1206.0
Disch kcfs	14.4	13.0	19.0	27.7	30.8	32.2	28.3	28.0	27.5	27.1	17.2	12.5	12.5	12.5
<b>System</b>														
Storage KAF	52547	52458	52247	51336	50584	50304	49265	47949	46770	45688	45246	44886	44765	44863
Energy GWh	8714	538	650	773	894	885	874	858	733	585	415	480	545	485
Ave Cap MW		2435	2442	2436	2422	2412	2402	2384	2367	2343	2304	2296	2307	2323

01Feb2024 / Upper Basic Condition / 26.0 MAF / Balanced  
Full Serv -0.7 kcfs 1st Half / Full Serv 2nd Half / Nav End Date: Dec 01

	2024												2025	
	31Jan	29Feb	31Mar	30Apr	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
<b>Fort Peck</b>														
Elev feet	2229.3	2230.0	2231.5	2232.0	2231.7	2233.3	2234.3	2234.0	2233.6	2233.5	2233.5	2233.1	2232.6	2232.4
Disch kcfs	5.6	5.0	5.0	8.7	14.0	16.5	8.6	8.0	7.0	6.0	6.0	8.5	9.5	9.5
<b>Garrison</b>														
Elev feet	1836.9	1834.7	1834.8	1835.1	1836.9	1840.7	1841.6	1840.4	1839.3	1839.0	1838.4	1837.5	1836.6	1836.1
Disch kcfs	18.3	24.9	18.0	19.0	21.0	22.0	22.0	22.0	19.5	17.0	17.0	18.4	21.0	21.0
<b>Oahe</b>														
Elev feet	1600.0	1602.5	1604.5	1606.0	1607.2	1608.6	1607.7	1605.7	1604.1	1603.6	1603.6	1604.1	1604.8	1606.1
Disch kcfs	16.3	12.9	15.4	16.8	20.3	22.7	29.8	31.6	28.2	19.5	16.9	14.9	17.7	16.5
<b>Big Bend</b>														
Elev feet	1420.8	1420.6	1421.0	1420.7	1420.4	1421.0	1420.6	1420.7	1420.9	1420.5	1420.7	1420.7	1420.5	1420.4
Disch kcfs	16.2	13.1	15.0	17.0	20.5	22.1	29.7	31.2	27.7	19.6	16.6	14.7	17.9	16.5
<b>Fort Randall</b>														
Elev feet	1345.2	1349.6	1354.8	1355.1	1355.3	1354.9	1355.1	1355.1	1353.3	1344.8	1337.4	1339.1	1344.9	1350.2
Disch kcfs	12.1	8.1	12.8	20.2	23.8	26.4	29.5	31.4	30.5	29.5	24.1	13.3	12.9	11.1
<b>Gavins Point</b>														
Elev feet	1207.4	1205.9	1206.0	1206.0	1206.0	1206.1	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	14.4	13.0	18.8	26.0	29.3	30.9	31.6	33.2	32.6	32.0	27.5	15.3	15.3	15.3
<b>System</b>														
Storage KAF	52547	52997	54366	55010	55850	57825	58010	57001	55968	55046	54445	54316	54463	55015
Energy GWh	9363	496	548	662	829	871	959	989	874	746	633	567	637	554
Ave Cap MW		2440	2464	2481	2491	2508	2514	2506	2494	2474	2438	2427	2443	2465



Date of Study: 02Feb2024

01Feb2024 / Lower Basic Condition / 12.4 MAF / Balanced  
Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)  
F-Sum: Sum of Forecasted Values. \*: Previous Month's Data

	2024												2025		
	*31Jan	29Feb	31Mar	30Apr	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb	
	F-Sum														
<b>Fort Peck</b>															
Reach Inflow	4192	225	280	273	560	780	358	189	202	264	280	264	248	270	
Depletion	127	-10	-1	32	122	201	85	-95	-61	2	10	-49	-75	-32	
Reg Inflow	4066	235	281	241	438	579	273	284	264	262	270	313	323	302	
Evap	397	4	8	-6	3	1	42	76	87	65	63	44	6	3	
Release	5998	288	307	515	649	565	584	584	417	277	268	492	553	500	
Stor Change	-2330	-56	-35	-268	-214	13	-354	-376	-240	-80	-61	-222	-236	-201	
Storage	*13833	13776	13742	13474	13260	13273	12919	12543	12303	12224	12162	11940	11704	11503	
Elev feet	*2229.3	2229.1	2228.9	2227.5	2226.4	2226.5	2224.6	2222.6	2221.3	2220.8	2220.5	2219.3	2218.0	2216.8	
Disch kcfs	*5.6	5.0	5.0	8.7	10.6	9.5	9.5	9.5	7.0	4.5	4.5	8.0	9.0	9.0	
Ave Power MW		63	63	108	127	117	117	116	85	54	54	95	107	106	
Ave Cap MW		213	213	212	210	209	208	206	203	202	202	201	199	198	
Energy GWh	882.7	44.0	46.9	77.6	94.6	84.6	87.0	86.0	60.9	40.5	39.1	71.0	79.3	71.1	
<b>Garrison</b>															
Reach Inflow	4960	255	358	292	560	1040	618	280	248	352	280	200	208	270	
Depletion	159	-28	21	10	135	318	120	-48	-59	-126	-100	-45	-28	-10	
Reg Inflow	10767	571	644	728	1106	1287	1081	912	765	755	647	708	781	780	
Evap	449	0	9	-11	-2	-29	13	88	113	109	95	64	-2	0	
Release	14108	1430	984	1012	1139	1131	1168	1168	1012	922	893	1027	1168	1055	
Stor Change	-3790	-859	-349	-273	-30	186	-99	-344	-360	-276	-341	-383	-386	-275	
Storage	*17567	16707	16359	16086	16055	16241	16142	15798	15438	15161	14821	14438	14052	13777	
Elev feet	*1836.9	1834.0	1832.8	1831.9	1831.8	1832.4	1832.1	1830.9	1829.6	1828.6	1827.4	1825.9	1824.5	1823.4	
Disch kcfs	*18.3	24.9	16.0	17.0	18.5	19.0	19.0	19.0	17.0	15.0	15.0	16.7	19.0	19.0	
Ave Power MW		304	196	206	224	230	230	229	204	179	178	196	220	218	
Ave Cap MW		558	549	544	543	543	544	541	535	530	525	518	511	506	
Energy GWh	2043.7	211.8	145.7	148.6	166.6	165.5	171.2	170.4	146.8	133.3	128.1	145.7	163.5	146.4	
<b>Oahe</b>															
Reach Inflow	995	22	159	105	110	170	93	52	83	52	53	11	9	75	
Depletion	155	8	22	17	25	38	50	20	0	-10	-7	-6	-4	2	
Reg Inflow	14961	1437	1153	1096	1216	1263	1212	1201	1108	985	952	1034	1177	1128	
Evap	401	5	8	-11	-14	-25	13	68	101	93	83	69	7	4	
Release	16437	891	1410	1483	1744	1769	1770	1750	1458	870	580	814	1002	896	
Stor Change	-1877	541	-265	-376	-514	-481	-571	-618	-451	22	288	150	169	229	
Storage	*16461	17002	16737	16361	15847	15366	14795	14176	13725	13748	14036	14186	14355	14584	
Elev feet	*1600.0	1601.9	1601.0	1599.6	1597.7	1595.9	1593.7	1591.2	1589.4	1589.5	1590.7	1591.3	1592.0	1592.9	
Disch kcfs	*16.3	15.5	22.9	24.9	28.4	29.7	28.8	28.5	24.5	14.1	9.8	13.2	16.3	16.1	
Ave Power MW		190	280	301	338	348	332	322	273	158	110	151	186	185	
Ave Cap MW		676	681	672	665	655	645	633	622	617	620	625	628	633	
Energy GWh	2314.7	132.2	208.4	216.8	251.2	250.7	247.1	239.5	196.6	117.9	79.4	112.1	138.2	124.5	
<b>Big Bend</b>															
Reg Inflow	16436	891	1405	1483	1743	1771	1769	1751	1461	872	582	812	1001	895	
Evap	106	0	1	3	3	3	19	24	21	15	10	5	1	0	
Release	16348	900	1380	1494	1758	1736	1772	1725	1427	877	561	804	1018	896	
Storage	*1675	1665	1689	1676	1657	1690	1668	1670	1683	1662	1673	1676	1658	1657	
Elev feet	*1420.8	1420.6	1421.0	1420.8	1420.4	1421.0	1420.6	1420.7	1420.9	1420.5	1420.7	1420.8	1420.5	1420.4	
Disch kcfs	*16.2	15.7	22.5	25.1	28.6	29.2	28.8	28.0	24.0	14.3	9.4	13.1	16.5	16.1	
Ave Power MW		74	105	118	133	136	134	131	112	68	45	62	78	77	
Ave Cap MW		507	502	501	499	498	498	499	501	507	510	508	506	506	
Energy GWh	928.5	51.8	78.1	84.6	99.1	97.7	99.8	97.2	80.9	50.4	32.5	46.4	58.4	51.4	
<b>Fort Randall</b>															
Reach Inflow	520	11	104	70	75	80	33	33	30	1	0	11	26	45	
Depletion	116	-1	-0	-0	6	24	50	32	12	-2	-2	-2	-1	-1	
Reg Inflow	16750	913	1484	1557	1824	1803	1745	1732	1448	882	574	806	1043	940	
Evap	118	1	2	-7	-2	-1	13	27	34	29	13	6	1	1	
Release	16274	589	1070	1544	1800	1833	1726	1695	1579	1580	902	707	691	558	
Stor Change	358	323	411	19	26	-29	6	9	-165	-727	-342	94	351	381	
Storage	*2658	2981	3392	3411	3437	3408	3414	3424	3259	2532	2190	2284	2635	3016	
Elev feet	*1345.2	1349.7	1354.8	1355.0	1355.3	1355.0	1355.1	1355.2	1353.2	1343.3	1337.5	1339.2	1344.9	1350.2	
Disch kcfs	*12.1	10.2	17.4	25.9	29.3	30.8	28.1	27.6	26.5	25.7	15.2	11.5	11.2	10.0	
Ave Power MW		90	157	236	266	279	255	251	240	222	122	92	94	88	
Ave Cap MW		355	372	381	381	381	381	381	379	359	321	317	335	355	
Energy GWh	1747.6	62.4	116.9	170.2	197.7	200.8	189.7	186.5	172.9	165.3	87.9	68.6	69.6	59.1	
<b>Gavins Point</b>															
Reach Inflow	1298	127	154	115	115	105	83	78	86	90	90	75	75	105	
Depletion	165	-1	-1	6	5	27	66	37	3	3	9	11	1	-1	
Reg Inflow	17399	715	1171	1649	1898	1916	1749	1738	1666	1672	1031	768	768	659	
Evap	33	0	0	1	2	1	6	5	6	6	4	2	0	0	
Release	17400	748	1170	1648	1897	1916	1742	1722	1636	1666	1025	768	769	694	
Stor Change	-34	-33	1	0	-1	-2	1	11	24	-1	3	-2	-1	-35	
Storage	*360	327	328	328	328	326	327	338	362	361	364	362	361	326	
Elev feet	*1207.4	1206.0	1206.0	1206.0	1206.0	1205.9	1206.0	1206.5	1207.5	1207.5	1207.6	1207.5	1207.5	1206.0	
Disch kcfs	*14.4	13.0	19.0	27.7	30.8	32.2	28.3	28.0	27.5	27.1	17.2	12.5	12.5	12.5	
Ave Power MW		51	72	104	114	118	106	105	105	104	66	49	49	49	
Ave Cap MW		126	125	125	125	125	125	125	127	127	127	127	127	126	
Energy GWh	796.9	35.4	53.8	74.7	84.9	85.3	78.8	78.1	75.2	77.1	47.8	36.3	36.4	32.9	
<b>Sioux City</b>															
Reach Inflow	1501	60	176	220	190	175	148	104	97	83	68	52	45	83	
Depletion	280	-1	-1	5	18	53	129	80	11	-6	-4	-2	-1	-1	
Reg Flow	18622	809	1314	1863	2059	2039	1770	1746	1724	1755	1136	814	815	777	
Reg Flow kcfs		14.1	21.4	31.3	33.5	34.3	28.8	28.4	29.0	28.5	19.1	13.2	13.2	14.0	
<b>Total</b>															
Reach Inflow	13467	701	1231	1075	1610	2350	1333	736	746	842	770	614	611	847	
Depletion	1002	-33	40	70	311	660	499	25	-95	-139	-93	-94	-108	-42	
Evap	1504	10	28	-30	-11	-49	106	290	362	317	269	189	13	9	
Storage	*52547	52458	52247	51336	50584	50304	49265	47949	46770	45688	45246	44886	44765	44863	
Ave Power MW		772	874	1073	1202	1229	1174	1153	1019	786	576	645	733	722	
Ave Cap MW		2435	2442	2436	2422	2412	2402	2384	2367	2343	2304	2296	2307	2323	
Energy GWh	8714.0	537.6	649.9	772.6	894.1	884.6	873.7	857.6	733.5	584.5	414.9	480.2	545.4	485.4	
Daily GWh		18.5	21.0	25.8	28.8	29.5	28.2	27.7	24.4	18.9	13.8	15.5	17.6	17.3	

Date of Study: 02Feb2024

01Feb2024 / Upper Basic Condition / 26.0 MAF / Balanced

Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)

F-Sum: Sum of Forecasted Values. \*: Previous Month's Data

	2024												2025	
	*31Jan F-Sum	29Feb	31Mar	30Apr	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
<b>Fort Peck</b>														
Reach Inflow	7858	360	581	609	1080	1740	797	351	324	396	420	396	372	432
Depletion	32	-64	-33	-8	281	410	26	-172	-109	-31	-14	-89	-106	-60
Reg Inflow	7826	424	614	617	799	1330	772	523	433	427	434	485	478	492
Evap	452	4	8	-6	3	1	47	86	100	74	73	51	7	4
Release	6754	288	307	515	863	983	528	492	418	369	357	523	584	528
Stor Change	620	133	298	108	-67	346	197	-55	-86	-17	4	-88	-113	-40
Storage	*13833	13965	14264	14372	14304	14650	14848	14792	14706	14690	14694	14605	14492	14452
Elev feet	*2229.3	2230.0	2231.5	2232.0	2231.7	2233.3	2234.3	2234.0	2233.6	2233.5	2233.5	2233.1	2232.6	2232.4
Disch kcfs	*5.6	5.0	5.0	8.7	14.0	16.5	8.6	8.0	7.0	6.0	6.0	8.5	9.5	9.5
Ave Power MW		63	64	110	175	185	110	103	90	77	77	109	121	121
Ave Cap MW		214	215	216	216	217	218	219	218	218	218	218	217	217
Energy GWh	1023.7	44.1	47.4	79.0	129.9	133.5	82.0	76.7	65.2	57.5	55.6	81.1	90.4	81.5
<b>Garrison</b>														
Reach Inflow	9489	408	742	652	1080	2320	1378	520	396	528	420	300	312	432
Depletion	158	-68	-104	-99	115	804	320	-59	-106	-181	-161	-125	-110	-69
Reg Inflow	16048	764	1153	1197	1828	2467	1662	1071	937	1077	938	927	997	1029
Evap	514	0	9	-11	-3	-32	14	101	128	125	110	74	-2	0
Release	15780	1430	1107	1131	1293	1309	1353	1353	1160	1045	1012	1130	1291	1166
Stor Change	-245	-667	37	78	537	1189	295	-383	-351	-92	-183	-277	-292	-138
Storage	*17567	16900	16937	17015	17552	18741	19036	18654	18303	18210	18028	17751	17459	17321
Elev feet	*1836.9	1834.7	1834.8	1835.1	1836.9	1840.7	1841.6	1840.4	1839.3	1839.0	1838.4	1837.5	1836.6	1836.1
Disch kcfs	*18.3	24.9	18.0	19.0	21.0	22.0	22.0	22.0	19.5	17.0	17.0	18.4	21.0	21.0
Ave Power MW		305	221	234	260	275	279	278	246	214	214	230	261	260
Ave Cap MW		560	555	556	561	571	579	579	575	573	571	569	565	562
Energy GWh	2381.1	212.2	164.7	168.2	193.2	198.0	207.5	207.2	177.1	159.5	154.1	171.0	193.9	174.5
<b>Oahe</b>														
Reach Inflow	2497	42	435	326	341	493	238	108	149	94	94	20	17	140
Depletion	155	8	22	17	25	38	50	20	0	-10	-7	-6	-4	2
Reg Inflow	18127	1456	1544	1435	1598	1764	1541	1441	1326	1150	1113	1143	1311	1304
Evap	486	5	8	-11	-16	-29	15	84	123	112	100	83	8	5
Release	15862	744	949	998	1246	1351	1830	1943	1679	1197	1005	916	1087	918
Stor Change	1779	708	587	449	369	443	-305	-586	-476	-159	8	144	216	381
Storage	*16461	17169	17756	18205	18574	19017	18712	18127	17651	17491	17500	17643	17859	18240
Elev feet	*1600.0	1602.5	1604.5	1606.0	1607.2	1608.6	1607.7	1605.7	1604.1	1603.6	1603.6	1604.1	1604.8	1606.1
Disch kcfs	*16.3	12.9	15.4	16.8	20.3	22.7	29.8	31.6	28.2	19.5	16.9	14.9	17.7	16.5
Ave Power MW		159	193	212	257	290	378	397	352	243	210	187	222	209
Ave Cap MW		677	691	697	705	711	712	705	696	690	688	690	694	699
Energy GWh	2413.9	110.9	143.6	152.4	191.4	208.8	281.4	295.4	253.3	180.6	151.5	138.9	165.1	140.6
<b>Big Bend</b>														
Reg Inflow	15861	746	946	998	1244	1352	1825	1943	1682	1198	1009	913	1087	918
Evap	106	0	1	3	3	3	19	24	21	15	10	5	1	0
Release	15773	755	921	1010	1259	1317	1829	1916	1647	1204	988	906	1103	918
Storage	*1675	1666	1690	1675	1657	1689	1666	1670	1683	1662	1673	1675	1658	1657
Elev feet	*1420.8	1420.6	1421.0	1420.7	1420.4	1421.0	1420.6	1420.7	1420.9	1420.5	1420.7	1420.7	1420.5	1420.4
Disch kcfs	*16.2	13.1	15.0	17.0	20.5	22.1	29.7	31.2	27.7	19.6	16.6	14.7	17.9	16.5
Ave Power MW		63	71	80	96	104	138	144	129	92	79	70	85	78
Ave Cap MW		508	507	506	503	502	498	497	499	504	506	507	505	506
Energy GWh	897.4	43.5	52.7	57.9	71.7	74.9	102.9	107.5	92.9	68.7	56.6	52.1	63.2	52.7
<b>Fort Randall</b>														
Reach Inflow	1349	21	285	217	232	232	84	67	54	3	0	20	49	84
Depletion	116	-1	-0	-0	6	24	50	32	12	-2	-2	-2	-1	-1
Reg Inflow	17003	780	1209	1219	1481	1535	1846	1959	1691	1209	1005	916	1152	1002
Evap	119	1	2	-7	-2	-1	13	27	34	30	14	5	1	1
Release	16525	465	788	1202	1463	1573	1811	1931	1813	1812	1435	818	796	618
Stor Change	359	314	419	24	20	-37	21	0	-156	-633	-444	92	355	382
Storage	*2658	2972	3391	3415	3435	3399	3420	3420	3264	2631	2187	2280	2634	3017
Elev feet	*1345.2	1349.6	1354.8	1355.1	1355.3	1354.9	1355.1	1355.1	1353.3	1344.8	1337.4	1339.1	1344.9	1350.2
Disch kcfs	*12.1	8.1	12.8	20.2	23.8	26.4	29.5	31.4	30.5	29.5	24.1	13.3	12.9	11.1
Ave Power MW		71	116	185	217	241	267	284	274	255	194	106	107	97
Ave Cap MW		355	372	381	381	381	381	381	379	362	328	316	335	355
Energy GWh	1765.9	49.4	86.6	133.5	161.7	173.3	198.8	211.5	197.6	189.8	139.4	79.0	80.0	65.4
<b>Gavins Point</b>														
Reach Inflow	2998	238	420	357	356	304	210	162	155	162	162	135	140	196
Depletion	165	-1	-1	6	5	27	66	37	3	3	9	11	1	-1
Reg Inflow	19350	713	1161	1548	1799	1842	1948	2057	1969	1974	1641	942	940	816
Evap	33	0	0	1	2	1	6	5	6	6	4	2	0	0
Release	19350	748	1158	1547	1799	1839	1943	2041	1940	1968	1636	941	941	850
Stor Change	-33	-35	3	0	-1	2	-1	10	23	1	1	-1	-1	-34
Storage	*360	325	328	328	328	329	328	338	361	362	363	362	361	328
Elev feet	*1207.4	1205.9	1206.0	1206.0	1206.0	1206.1	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	*14.4	13.0	18.8	26.0	29.3	30.9	31.6	33.2	32.6	32.0	27.5	15.3	15.3	15.3
Ave Power MW		51	72	98	109	114	117	122	122	121	105	60	60	59
Ave Cap MW		126	125	125	125	125	125	125	127	127	127	127	127	126
Energy GWh	881.6	35.4	53.4	70.5	80.8	82.0	86.7	90.6	88.0	90.1	75.4	44.4	44.4	39.9
<b>Sioux City</b>														
Reach Inflow	3743	112	480	682	589	507	378	216	176	148	122	94	84	154
Depletion	280	-1	-1	5	18	53	129	80	11	-6	-4	-2	-1	-1
Reg Flow	22807	861	1610	2224	2359	2294	2191	2174	2106	2123	1798	1037	1026	1004
Reg Flow kcfs		15.0	26.2	37.4	38.4	38.5	35.6	35.4	35.4	34.5	30.2	16.9	16.7	18.1
<b>Total</b>														
Reach Inflow	27933	1181	2943	2842	3679	5597	3085	1425	1253	1332	1218	966	974	1438
Depletion	905	-126	-116	-79	449	1356	640	-62	-189	-226	-179	-213	-221	-129
Evap	1711	10	29	-31	-13	-57	115	328	412	362	310	219	16	11
Storage	*52547	52997	54366	55010	55850	57825	58010	57001	55968	55046	54445	54316	54463	55015
Ave Power MW		712	737	919	1114	1209	1289	1329	1214	1003	879	762	856	825
Ave Cap MW		2440	2464	2481	2491	2508	2514	2506	2494	2474	2438	2427	2443	2465
Energy GWh	9363.5	495.5	548.5	661.5	828.7	870.6	959.2	988.8	874.0	746.2	632.6	566.6	636.8	554.5
Daily GWh		17.1	17.7	22.1	26.7	29.0	30.9	31.9	29.1	24.1	21.1	18.3	20.5	19.8