Date of Study: 02Feb2026

01Feb2026 / Basic Condition / 23.4 MAF / Balanced
Full Serv -5.5 kcfs 1st Half / Full Serv -2.8 kcfs 2nd Half / Nav End Date: Dec 01
Elevations & Storages are for Date Shown. Elevations in Local Project Datum (LPD)
Avg Discharge & Energy are Monthly Values

	2026 31Jan	28Feb	31Mar	30Apr	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	2027 31Jan	28Feb
Fort Peck														
Elev feet	2221.7	2221.9	2222.9	2223.3	2223.9	2227.1	2228.9	2229.8	2229.6	2229.7	2229.9	2229.4	2229.0	2228.9
Disch kcfs	5.0	5.0	5.0	6.0	6.5	7.0	7.0	7.0	7.0	4.5	4.5	7.0	7.5	7.5
Garrison														
Elev feet	1827.9	1826.6	1827.0	1827.9	1829.5	1835.5	1839.1	1839.0	1838.5	1837.8	1836.7	1835.5	1834.2	1833.3
Disch kcfs	16.1	16.0	16.0	16.0	19.0	20.0	20.0	20.0	17.5	15.0	15.0	16.4	19.5	19.5
Oahe														
Elev feet	1601.1	1601.4	1602.1	1603.1	1604.0	1605.1	1604.3	1602.6	1600.9	1600.4	1600.5	1601.0	1601.8	1603.1
Disch kcfs	14.4	16.3	19.6	17.9	19.2	20.9	26.2	27.9	25.9	16.9	14.4	12.8	15.7	14.5
Big Bend														
Elev feet	1420.7	1420.7	1420.8	1420.5	1421.0	1420.7	1420.4	1420.8	1420.6	1420.7	1420.6	1420.6	1421.0	1421.0
Disch kcfs	14.6	16.3	19.5	18.1	18.8	21.1	26.2	27.1	25.8	16.6	14.3	12.8	15.3	14.5
Fort Randall														
Elev feet	1344.3	1349.8	1354.7	1355.2	1355.0	1355.1	1355.3	1354.9	1353.4	1344.8	1337.1	1339.3	1344.6	1349.5
Disch kcfs	10.8	10.5	14.4	18.9	20.8	22.2	25.8	27.5	27.9	26.9	21.9	11.0	10.8	9.4
Gavins Point														
Elev feet	1206.2	1206.0	1206.0	1206.0	1206.0	1206.1	1206.1	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	13.1	12.5	16.2	20.6	22.9	24.3	27.0	28.8	29.4	28.7	24.5	12.5	12.5	12.5
System														
Storage KAF	48746	48881	49790	50410	51198	53884	55107	54759	53967	52998	52232	52063	52157	52561
Energy GWh	8205	448	576	590	677	708	832	866	796	647	545	485	552	482
Ave Cap MW		2391	2409	2426	2437	2460	2483	2484	2475	2455	2417	2403	2418	2437

01Feb2026 / Lower Basic Condition / 15.7 MAF / Balanced
Min Serv 1st Half / Min Serv 2nd Half / Nav End Date: Nov 19

	2026 31Jan	28Feb	31Mar	30Apr	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	2027 31Jan	28Feb
Fort Peck														
Elev feet	2221.7	2221.5	2221.5	2221.4	2221.4	2222.7	2222.8	2222.7	2221.7	2221.2	2220.9	2220.3	2219.6	2219.1
Disch kcfs	5.0	5.0	5.0	5.0	6.5	7.0	7.0	7.0	7.0	4.5	4.5	6.5	7.5	7.5
Garrison														
Elev feet	1827.9	1826.4	1825.9	1825.8	1826.4	1830.8	1833.1	1832.6	1831.9	1830.9	1829.5	1827.9	1826.4	1825.2
Disch kcfs	16.1	16.0	15.0	15.0	18.0	19.0	19.0	19.0	16.5	14.0	14.0	16.0	18.0	18.0
Oahe														
Elev feet	1601.1	1601.1	1600.2	1599.4	1598.6	1597.9	1596.3	1594.0	1591.9	1591.9	1593.0	1593.5	1593.9	1594.7
Disch kcfs	14.4	17.1	23.0	22.1	23.6	25.1	27.1	28.1	25.3	13.4	8.9	13.2	16.2	15.4
Big Bend														
Elev feet	1420.7	1420.7	1420.8	1420.6	1421.0	1420.7	1420.4	1420.9	1420.6	1420.7	1420.8	1420.5	1421.0	1421.0
Disch kcfs	14.6	17.1	22.9	22.3	23.2	25.3	27.1	27.3	25.2	13.2	8.7	13.4	15.8	15.4
Fort Randall														
Elev feet	1344.3	1349.8	1354.7	1355.2	1355.0	1355.0	1355.3	1354.9	1353.4	1342.4	1337.1	1339.4	1344.6	1349.4
Disch kcfs	10.8	11.0	17.0	22.4	24.4	25.6	26.2	27.4	27.2	25.9	13.4	11.4	11.2	10.1
Gavins Point														
Elev feet	1206.2	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.6	1207.5	1207.5	1206.0
Disch kcfs	13.1	12.5	17.6	23.2	25.3	26.5	26.5	28.0	28.3	27.3	15.5	12.5	12.5	12.5
System														
Storage KAF	48746	48674	48698	48436	48386	49645	49884	49134	48103	46954	46480	46150	46056	46178
Energy GWh	8051	460	626	646	741	762	815	833	751	569	386	468	528	465
Ave Cap MW		2389	2398	2400	2397	2404	2413	2407	2393	2368	2327	2321	2332	2346

01Feb2026 / Upper Basic Condition / 32.0 MAF / Balanced
Full Serv -4.8 kcfs 1st Half / Full Serv 2nd Half / Nav End Date: Dec 10

	2026 31Jan	28Feb	31Mar	30Apr	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	2027 31Jan	28Feb
Fort Peck														
Elev feet	2221.7	2222.3	2224.2	2226.1	2227.8	2232.4	2234.5	2235.6	2235.2	2235.1	2235.0	2234.6	2234.1	2234.0
Disch kcfs	5.0	5.0	5.0	6.0	7.8	8.5	8.5	8.5	8.5	6.5	6.5	8.0	9.0	9.0
Garrison														
Elev feet	1827.9	1826.9	1828.3	1830.0	1832.2	1840.4	1844.7	1843.7	1842.7	1841.9	1840.8	1840.0	1838.5	1837.5
Disch kcfs	16.1	16.0	17.1	20.0	26.3	28.5	28.5	28.5	23.8	19.0	19.0	17.5	23.5	23.5
Oahe														
Elev feet	1601.1	1601.8	1603.8	1606.5	1609.3	1612.2	1612.1	1611.3	1610.2	1609.2	1608.1	1607.0	1606.8	1607.4
Disch kcfs	14.4	15.1	18.0	16.8	19.0	21.9	32.8	33.1	30.7	24.0	24.8	21.9	24.4	22.5
Big Bend														
Elev feet	1420.7	1420.7	1420.8	1420.6	1421.0	1420.7	1420.4	1420.9	1420.6	1420.7	1420.9	1420.5	1421.0	1421.0
Disch kcfs	14.6	15.1	17.9	16.9	18.5	22.1	32.8	32.3	30.6	23.7	24.4	22.1	23.9	22.5
Fort Randall														
Elev feet	1344.3	1349.8	1354.7	1355.2	1354.9	1355.2	1355.3	1354.9	1353.4	1346.1	1337.9	1339.3	1344.6	1349.5
Disch kcfs	10.8	9.7	13.6	18.5	21.4	23.9	32.9	33.0	32.8	32.5	32.5	21.2	19.5	17.9
Gavins Point														
Elev feet	1206.2	1206.0	1206.0	1206.0	1206.0	1206.1	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	13.1	12.5	16.5	21.3	24.6	27.0	35.0	35.0	35.0	35.0	35.0	24.0	22.0	22.0
System														
Storage KAF	48746	49129	50884	52539	54342	58731	60529	60165	59256	58109	56885	56257	55976	56147
Energy GWh	10274	431	563	614	766	838	1088	1092	984	856	821	720	802	700
Ave Cap MW		2393	2420	2449	2474	2515	2541	2545	2538	2519	2482	2456	2466	2482

Date of Study: 02Feb2026

01Feb2026 / Basic Condition / 23.4 MAF / Balanced
Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)
F-Sum: Sum of Forecasted Values. *: Previous Month's Data

	2026 *31Jan F-Sum	28Feb	31Mar	30Apr	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	2027 31Jan	28Feb
Fort Peck														
Reach Inflow	6235	300	560	540	800	1100	500	350	320	380	380	330	310	365
Depletion	-449	-9	63	109	291	78	-331	-338	-148	-6	15	-54	-81	-37
Reg Inflow	6684	309	497	431	509	1022	831	688	468	386	365	384	391	402
Evap	430	3	7	-5	3	1	44	81	95	71	70	49	6	3
Release	4889	278	307	357	401	417	430	430	417	277	268	430	461	417
Stor Change	1365	29	182	79	105	605	357	177	-44	38	27	-95	-77	-18
Storage	*12386	12415	12597	12675	12780	13385	13742	13919	13875	13914	13941	13846	13769	13751
Elev feet	*2221.7	2221.9	2222.9	2223.3	2223.9	2227.1	2228.9	2229.8	2229.6	2229.7	2229.9	2229.4	2229.0	2228.9
Disch kcfs	*5.0	5.0	5.0	6.0	6.5	7.0	7.0	7.0	7.0	4.5	4.5	7.0	7.5	7.5
Ave Power MW		67	68	82	89	96	97	98	98	64	64	98	105	105
Ave Cap MW		203	204	205	206	208	211	213	214	214	214	214	213	213
Energy GWh	820.8	45.3	50.5	58.7	66.0	69.2	72.5	73.0	70.8	47.3	45.8	73.1	78.1	70.4
Garrison														
Reach Inflow	10600	250	800	800	1300	2800	1800	600	450	530	390	260	260	360
Depletion	-335	-9	-1	-24	94	304	-110	-262	-154	12	2	-73	-67	-45
Reg Inflow	15803	536	1108	1173	1598	2913	2341	1292	1021	816	656	743	784	822
Evap	504	0	9	-10	-2	-29	14	98	126	123	107	72	-2	0
Release	13792	889	984	952	1170	1190	1230	1230	1041	922	893	1010	1199	1083
Stor Change	1506	-352	116	231	430	1752	1097	-35	-147	-229	-344	-338	-413	-261
Storage	*14972	14620	14735	14966	15397	17148	18246	18211	18064	17835	17491	17153	16740	16478
Elev feet	*1827.9	1826.6	1827.0	1827.9	1829.5	1835.5	1839.1	1839.0	1838.5	1837.8	1836.7	1835.5	1834.2	1833.3
Disch kcfs	*16.1	16.0	16.0	16.0	19.0	20.0	20.0	20.0	17.5	15.0	15.0	16.4	19.5	19.5
Ave Power MW		188	187	188	224	241	247	250	218	187	186	203	238	236
Ave Cap MW		521	519	522	528	545	566	573	571	569	566	561	555	550
Energy GWh	2027.9	126.1	139.2	135.3	166.9	173.3	184.0	185.6	157.3	139.4	134.3	150.7	177.1	158.9
Oahe														
Reach Inflow	2317	100	460	400	280	400	200	90	115	75	70	15	12	100
Depletion	135	7	22	17	22	38	38	14	-1	-9	-6	-5	-4	2
Reg Inflow	15961	981	1422	1336	1414	1552	1392	1306	1175	1007	969	1018	1211	1181
Evap	466	4	8	-11	-15	-28	15	80	118	108	96	79	8	5
Release	14931	904	1208	1062	1182	1245	1611	1718	1542	1037	858	789	968	806
Stor Change	565	72	207	284	247	335	-233	-492	-485	-138	15	149	235	370
Storage	*16790	16862	17068	17353	17599	17934	17701	17209	16724	16586	16601	16750	16985	17355
Elev feet	*1601.1	1601.4	1602.1	1603.1	1604.0	1605.1	1604.3	1602.6	1600.9	1600.4	1600.5	1601.0	1601.8	1603.1
Disch kcfs	*14.4	16.3	19.6	17.9	19.2	20.9	26.2	27.9	25.9	16.9	14.4	12.8	15.7	14.5
Ave Power MW		197	238	218	236	258	322	340	312	203	174	156	191	178
Ave Cap MW		677	681	684	689	694	695	688	680	674	672	675	678	683
Energy GWh	2200.7	132.7	177.4	157.1	175.8	186.0	239.8	253.0	225.0	151.4	125.0	115.8	142.3	119.6
Big Bend														
Reg Inflow	14932	905	1205	1063	1183	1241	1610	1718	1544	1041	859	789	968	807
Evap	106	0	1	3	3	3	19	24	21	15	10	5	1	0
Release	14812	905	1201	1074	1153	1254	1612	1666	1535	1022	853	787	942	806
Storage	*1675	1674	1677	1663	1690	1674	1653	1681	1668	1671	1667	1664	1689	1689
Elev feet	*1420.7	1420.7	1420.8	1420.5	1421.0	1420.7	1420.4	1420.8	1420.6	1420.7	1420.6	1420.6	1421.0	1421.0
Disch kcfs	*14.6	16.3	19.5	18.1	18.8	21.1	26.2	27.1	25.8	16.6	14.3	12.8	15.3	14.5
Ave Power MW		76	91	84	87	98	121	125	119	78	67	60	72	68
Ave Cap MW		509	508	508	508	507	504	504	504	509	510	511	509	510
Energy GWh	832.8	51.2	67.5	60.6	65.0	70.5	89.8	92.8	85.7	57.7	48.3	44.6	53.3	45.7
Fort Randall														
Reach Inflow	720	60	100	80	100	120	55	50	40	1	-0	15	35	65
Depletion	113	-1	-0	-0	5	26	46	33	11	-2	-2	-1	-1	-1
Reg Inflow	15423	966	1290	1157	1258	1331	1620	1686	1564	1038	855	799	987	873
Evap	119	1	2	-7	-2	-1	13	27	33	30	14	5	1	1
Release	14942	581	885	1123	1282	1323	1584	1693	1657	1653	1301	675	661	523
Stor Change	362	384	403	41	-22	10	22	-35	-127	-644	-460	119	324	348
Storage	*2599	2983	3385	3426	3404	3414	3436	3401	3274	2630	2169	2288	2613	2961
Elev feet	*1344.3	1349.8	1354.7	1355.2	1355.0	1355.1	1355.3	1354.9	1353.4	1344.8	1337.1	1339.3	1344.6	1349.5
Disch kcfs	*10.8	10.5	14.4	18.9	20.8	22.2	25.8	27.5	27.9	26.9	21.9	11.0	10.8	9.4
Ave Power MW		89	127	169	186	198	228	243	245	227	171	86	87	80
Ave Cap MW		354	372	381	381	381	381	381	379	362	328	316	335	354
Energy GWh	1558.3	59.7	94.5	121.4	138.3	142.4	169.8	181.1	176.2	168.9	123.4	63.7	64.8	54.0
Gavins Point														
Reach Inflow	1615	100	140	110	140	160	140	120	115	120	120	105	105	140
Depletion	129	-1	-0	5	3	25	51	25	-4	4	10	11	1	-1
Reg Inflow	16430	688	996	1226	1410	1449	1665	1786	1779	1771	1464	770	768	660
Evap	33	0	0	1	2	1	6	5	6	6	4	2	0	0
Release	16404	694	995	1226	1408	1446	1660	1771	1749	1765	1459	769	769	694
Stor Change	-6	-6	1	-0	0	2	-1	10	23	-0	1	-1	-0	-35
Storage	*333	327	328	327	328	329	329	338	362	362	363	362	361	327
Elev feet	*1206.2	1206.0	1206.0	1206.0	1206.0	1206.1	1206.1	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	*13.1	12.5	16.2	20.6	22.9	24.3	27.0	28.8	29.4	28.7	24.5	12.5	12.5	12.5
Ave Power MW		49	63	79	88	93	102	109	112	110	95	50	50	49
Ave Cap MW		126	125	125	125	125	125	125	127	127	127	127	127	126
Energy GWh	764.7	33.2	46.8	57.2	65.3	66.9	76.2	80.9	80.8	82.2	68.3	36.9	36.9	33.2
Sioux City														
Reach Inflow	2755	100	400	450	400	370	280	170	135	110	95	75	60	110
Depletion	255	-1	-0	4	14	56	114	71	10	-5	-4	-2	-1	-1
Reg Flow	18907	798	1377	1672	1785	1760	1820	1866	1873	1882	1594	845	830	805
Reg Flow kcfs		14.4	22.4	28.1	29.0	29.6	29.6	30.3	31.5	30.6	26.8	13.7	13.5	14.5
Total														
Reach Inflow	24242	910	2460	2380	3020	4950	2975	1380	1175	1216	1055	800	782	1140
Depletion	-151	-13	83	111	429	528	-193	-458	-286	-7	15	-125	-152	-82
Evap	1658	10	27	-29	-12	-53	110	316	400	352	301	212	15	10
Storage	*48746	48881	49790	50410	51198	53884	55107	54759	53967	52998	52232	52063	52157	52561
Ave Power MW		667	774	820	910	984	1118	1164	1105	870	757	652	742	717
Ave Cap MW		2391	2409	2426	2437	2460	2483	2484	2475	2455	2417	2403	2418	2437
Energy GWh	8205.2	448.2	575.9	590.3	677.2	708.3	832.1	866.4	795.6	646.9	545.1	484.8	552.4	481.9
Daily GWh		16.0	18.6	19.7	21.8	23.6	26.8	27.9	26.5	20.9	18.2	15.6	17.8	17.2

Date of Study: 02Feb2026

01Feb2026 / Lower Basic Condition / 15.7 MAF / Balanced
Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)
F-Sum: Sum of Forecasted Values. *: Previous Month's Data

	2026 *31Jan F-Sum	28Feb	31Mar	30Apr	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	2027 31Jan	28Feb
Fort Peck														
Reach Inflow	4419	225	364	351	560	715	325	245	240	304	304	264	248	274
Depletion	-298	-5	40	79	148	59	-154	-239	-83	42	39	-72	-98	-55
Reg Inflow	4717	230	324	272	412	656	479	484	323	262	265	336	346	329
Evap	395	3	7	-5	3	1	41	75	88	65	63	44	6	3
Release	4799	278	307	298	401	417	430	430	417	277	268	400	461	417
Stor Change	-477	-51	9	-20	8	238	7	-22	-181	-79	-66	-108	-121	-91
Storage	*12386	12335	12344	12324	12332	12571	12578	12556	12374	12295	12229	12121	12000	11909
Elev feet	*2221.7	2221.5	2221.5	2221.4	2221.4	2222.7	2222.8	2222.7	2221.7	2221.2	2220.9	2220.3	2219.6	2219.1
Disch kcfs	*5.0	5.0	5.0	5.0	6.5	7.0	7.0	7.0	7.0	4.5	4.5	6.5	7.5	7.5
Ave Power MW		67	68	68	88	94	95	95	94	61	61	87	100	99
Ave Cap MW		203	203	203	203	204	205	205	204	203	202	202	201	200
Energy GWh	781.1	45.3	50.3	48.6	65.2	68.0	70.5	70.5	68.0	45.3	43.7	64.8	74.1	66.7
Garrison														
Reach Inflow	7307	188	520	520	910	1820	1170	420	338	424	312	208	208	270
Depletion	-690	-15	19	-22	25	-77	-248	-260	-140	31	41	-25	-16	-4
Reg Inflow	12775	479	808	840	1268	2314	1849	1111	894	691	539	616	677	691
Evap	461	0	8	-10	-2	-28	13	90	115	112	98	66	-2	0
Release	13047	889	922	893	1109	1131	1168	1168	982	861	833	986	1107	1000
Stor Change	-733	-410	-123	-43	162	1211	668	-147	-203	-282	-393	-435	-428	-309
Storage	*14972	14563	14440	14397	14559	15770	16437	16290	16087	15804	15412	14977	14548	14239
Elev feet	*1827.9	1826.4	1825.9	1825.8	1826.4	1830.8	1833.1	1832.6	1831.9	1830.9	1829.5	1827.9	1826.4	1825.2
Disch kcfs	*16.1	16.0	15.0	15.0	18.0	19.0	19.0	19.0	16.5	14.0	14.0	16.0	18.0	18.0
Ave Power MW		187	175	175	209	224	228	229	199	169	168	190	210	208
Ave Cap MW		521	516	515	516	527	543	547	543	540	535	528	521	514
Energy GWh	1866.1	126.0	130.1	125.7	155.6	161.1	169.8	170.7	143.3	125.6	120.7	141.1	156.5	140.0
Oahe														
Reach Inflow	1327	75	253	200	140	200	110	58	86	56	52	11	9	75
Depletion	135	7	22	17	22	38	38	14	-1	-9	-6	-5	-4	2
Reg Inflow	14232	956	1157	1076	1212	1292	1240	1213	1087	926	892	993	1114	1073
Evap	413	4	8	-11	-14	-25	13	71	104	95	86	71	7	4
Release	15553	951	1415	1316	1452	1497	1664	1730	1507	823	533	812	999	855
Stor Change	-1734	0	-266	-229	-225	-179	-437	-588	-524	8	274	110	109	214
Storage	*16790	16790	16525	16295	16070	15891	15454	14866	14342	14350	14623	14733	14842	15055
Elev feet	*1601.1	1601.1	1600.2	1599.4	1598.6	1597.9	1596.3	1594.0	1591.9	1591.9	1593.0	1593.5	1593.9	1594.7
Disch kcfs	*14.4	17.1	23.0	22.1	23.6	25.1	27.1	28.1	25.3	13.4	8.9	13.2	16.2	15.4
Ave Power MW		207	276	264	279	295	314	321	285	151	102	151	186	177
Ave Cap MW		676	676	670	666	662	656	646	636	630	632	637	639	642
Energy GWh	2189.0	139.2	205.3	189.7	207.7	212.6	233.8	239.1	205.4	112.6	73.6	112.6	138.3	119.1
Big Bend														
Reg Inflow	15554	951	1411	1317	1452	1494	1664	1730	1509	827	533	812	999	855
Evap	106	0	1	3	3	3	19	24	21	15	10	5	1	0
Release	15433	952	1406	1328	1424	1505	1665	1679	1500	809	515	822	972	855
Storage	*1675	1674	1678	1664	1689	1675	1654	1681	1668	1671	1679	1663	1690	1690
Elev feet	*1420.7	1420.7	1420.8	1420.6	1421.0	1420.7	1420.4	1420.9	1420.6	1420.7	1420.8	1420.5	1421.0	1421.0
Disch kcfs	*14.6	17.1	22.9	22.3	23.2	25.3	27.1	27.3	25.2	13.2	8.7	13.4	15.8	15.4
Ave Power MW		80	106	104	107	117	125	126	116	62	41	63	74	72
Ave Cap MW		509	506	506	506	505	504	503	505	510	513	510	509	509
Energy GWh	866.1	53.8	78.6	74.5	79.8	84.1	92.7	93.5	83.8	45.8	29.4	46.7	55.0	48.4
Fort Randall														
Reach Inflow	429	45	55	40	50	60	30	32	30	0	-0	11	26	49
Depletion	113	-1	-0	-0	5	26	46	33	11	-2	-2	-1	-1	-1
Reg Inflow	15753	997	1448	1371	1478	1527	1649	1682	1520	826	514	830	1008	905
Evap	118	1	2	-7	-2	-1	13	27	33	29	13	6	1	1
Release	15276	610	1046	1334	1500	1525	1613	1685	1620	1595	799	704	687	558
Stor Change	360	386	400	43	-19	3	23	-30	-133	-798	-299	121	320	346
Storage	*2599	2985	3384	3428	3408	3411	3433	3403	3270	2472	2173	2294	2614	2959
Elev feet	*1344.3	1349.8	1354.7	1355.2	1355.0	1355.0	1355.3	1354.9	1353.4	1342.4	1337.1	1339.4	1344.6	1349.4
Disch kcfs	*10.8	11.0	17.0	22.4	24.4	25.6	26.2	27.4	27.2	25.9	13.4	11.4	11.2	10.1
Ave Power MW		93	149	199	217	227	232	242	239	217	105	89	91	86
Ave Cap MW		354	372	381	381	381	381	381	379	358	318	317	335	355
Energy GWh	1595.5	62.6	111.2	143.6	161.1	163.5	172.8	180.2	172.3	161.6	75.3	66.5	67.3	57.5
Gavins Point														
Reach Inflow	1041	75	77	55	70	80	77	78	86	90	90	79	79	105
Depletion	129	-1	-0	5	3	25	51	25	-4	4	10	11	1	-1
Reg Inflow	16188	689	1085	1382	1558	1578	1636	1737	1714	1684	930	767	769	659
Evap	33	0	0	1	2	1	6	5	6	6	4	2	0	0
Release	16161	694	1085	1380	1557	1577	1629	1722	1684	1679	924	768	769	694
Stor Change	-7	-6	-0	1	-0	-0	1	10	24	-0	3	-2	-0	-35
Storage	*333	327	327	328	328	327	328	338	362	362	364	362	362	326
Elev feet	*1206.2	1206.0	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.6	1207.5	1207.5	1206.0
Disch kcfs	*13.1	12.5	17.6	23.2	25.3	26.5	26.5	28.0	28.3	27.3	15.5	12.5	12.5	12.5
Ave Power MW		49	68	89	96	101	101	106	108	105	61	49	50	49
Ave Cap MW		126	125	125	125	125	125	125	127	127	127	127	127	126
Energy GWh	752.9	33.2	50.8	64.0	71.8	72.4	74.9	78.8	78.0	78.4	43.6	36.8	36.9	33.2
Sioux City														
Reach Inflow	1608	75	220	225	200	185	154	110	101	82	71	56	45	82
Depletion	255	-1	-0	4	14	56	114	71	10	-5	-4	-2	-1	-1
Reg Flow	17518	773	1281	1602	1736	1705	1670	1758	1775	1769	1039	818	815	777
Reg Flow kcfs		13.9	20.8	26.9	28.2	28.7	27.2	28.6	29.8	28.8	17.5	13.3	13.2	14.0
Total														
Reach Inflow	16131	682	1489	1391	1930	3060	1866	944	881	957	829	630	615	855
Depletion	-357	-14	79	82	217	128	-154	-356	-206	60	78	-95	-118	-59
Evap	1525	10	27	-29	-11	-49	105	293	368	322	274	193	14	9
Storage	*48746	48674	48698	48436	48386	49645	49884	49134	48103	46954	46480	46150	46056	46178
Ave Power MW		685	842	898	996	1058	1095	1119	1043	765	537	629	710	692
Ave Cap MW		2389	2398	2400	2397	2404	2413	2407	2393	2368	2327	2321	2332	2346
Energy GWh	8050.7	460.1	626.3	646.2	741.2	761.7	814.5	832.7	750.8	569.3	386.3	468.3	528.1	465.1
Daily GWh		16.4	20.2	21.5	23.9	25.4	26.3	26.9	25.0	18.4	12.9	15.1	17.0	16.6

Date of Study: 02Feb2026

01Feb2026 / Upper Basic Condition / 32.0 MAF / Balanced
Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)
F-Sum: Sum of Forecasted Values. *: Previous Month's Data

	2026 *31Jan F-Sum	28Feb	31Mar	30Apr	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	2027 31Jan	28Feb
Fort Peck														
Reach Inflow	8256	360	756	783	1080	1595	725	455	384	456	456	396	372	438
Depletion	-412	-26	86	76	277	155	-278	-384	-140	1	10	-64	-83	-42
Reg Inflow	8668	386	670	707	803	1440	1003	839	524	455	446	460	455	480
Evap	458	3	7	-5	3	1	47	87	102	76	74	52	7	4
Release	5809	278	307	357	478	506	523	523	506	400	387	492	553	500
Stor Change	2402	106	356	355	321	933	434	229	-83	-20	-15	-84	-106	-23
Storage	*12386	12492	12847	13202	13524	14457	14890	15120	15036	15016	15001	14917	14811	14788
Elev feet	*2221.7	2222.3	2224.2	2226.1	2227.8	2232.4	2234.5	2235.6	2235.2	2235.1	2235.0	2234.6	2234.1	2234.0
Disch kcfs	*5.0	5.0	5.0	6.0	7.8	8.5	8.5	8.5	8.5	6.5	6.5	8.0	9.0	9.0
Ave Power MW		68	68	83	107	119	121	122	122	94	94	115	129	129
Ave Cap MW		204	205	208	210	214	218	220	220	220	220	219	219	218
Energy GWh	995.5	45.4	50.8	59.4	79.9	85.8	90.1	90.8	88.1	69.8	67.6	85.4	95.9	86.5
Garrison														
Reach Inflow	14445	300	1080	1160	1755	4060	2610	780	540	636	468	312	312	432
Depletion	-568	-24	-71	-144	-30	418	-55	-225	-150	9	-22	-106	-102	-67
Reg Inflow	20788	601	1458	1653	2242	4148	3188	1527	1196	1043	877	897	959	999
Evap	539	0	9	-10	-2	-31	15	105	134	130	114	77	-2	0
Release	17486	889	1049	1190	1619	1696	1752	1752	1413	1168	1131	1077	1445	1305
Stor Change	2763	-288	400	473	626	2483	1421	-330	-351	-255	-368	-256	-485	-307
Storage	*14972	14684	15084	15557	16183	18666	20086	19756	19405	19150	18782	18526	18041	17735
Elev feet	*1827.9	1826.9	1828.3	1830.0	1832.2	1840.4	1844.7	1843.7	1842.7	1841.9	1840.8	1840.0	1838.5	1837.5
Disch kcfs	*16.1	16.0	17.1	20.0	26.3	28.5	28.5	28.5	23.8	19.0	19.0	17.5	23.5	23.5
Ave Power MW		188	200	236	312	347	358	361	301	241	240	221	292	290
Ave Cap MW		522	523	530	539	562	583	587	584	582	580	577	573	569
Energy GWh	2606.9	126.2	149.0	169.9	231.9	249.7	266.6	268.7	216.4	179.4	172.8	164.1	217.4	195.0
Oahe														
Reach Inflow	3394	140	690	620	434	580	280	122	155	101	94	20	17	140
Depletion	135	7	22	17	22	38	38	14	-1	-9	-6	-5	-4	2
Reg Inflow	20718	1021	1710	1787	2000	2237	1995	1860	1603	1279	1231	1091	1462	1443
Evap	531	5	8	-11	-16	-31	17	91	136	124	109	88	9	5
Release	18332	837	1107	997	1166	1305	2019	2035	1826	1474	1473	1346	1498	1251
Stor Change	1854	179	596	802	850	963	-41	-267	-359	-319	-350	-343	-45	187
Storage	*16790	16969	17565	18366	19216	20180	20138	19872	19513	19194	18844	18501	18457	18644
Elev feet	*1601.1	1601.8	1603.8	1606.5	1609.3	1612.2	1612.1	1611.3	1610.2	1609.2	1608.1	1607.0	1606.8	1607.4
Disch kcfs	*14.4	15.1	18.0	16.8	19.0	21.9	32.8	33.1	30.7	24.0	24.8	21.9	24.4	22.5
Ave Power MW		183	221	209	240	281	420	422	391	305	313	275	305	283
Ave Cap MW		678	686	697	711	726	733	731	727	720	715	709	706	707
Energy GWh	2800.2	123.1	164.2	150.2	178.6	202.2	312.6	314.3	281.5	226.9	225.4	204.9	226.6	189.9
Big Bend														
Reg Inflow	18330	838	1104	998	1166	1299	2019	2036	1827	1477	1472	1347	1498	1251
Evap	106	0	1	3	3	3	19	24	21	15	10	5	1	0
Release	18209	839	1099	1009	1138	1314	2017	1984	1819	1458	1451	1361	1471	1251
Storage	*1675	1673	1678	1664	1690	1672	1654	1681	1667	1671	1682	1663	1690	1690
Elev feet	*1420.7	1420.7	1420.8	1420.6	1421.0	1420.7	1420.4	1420.9	1420.6	1420.7	1420.9	1420.5	1421.0	1421.0
Disch kcfs	*14.6	15.1	17.9	16.9	18.5	22.1	32.8	32.3	30.6	23.7	24.4	22.1	23.9	22.5
Ave Power MW		71	83	79	86	102	150	148	140	110	113	103	111	104
Ave Cap MW		509	508	509	508	506	501	501	502	506	505	506	506	506
Energy GWh	1017.9	47.5	61.9	57.0	64.1	73.7	111.5	109.8	100.9	81.6	81.1	76.4	82.3	70.2
Fort Randall														
Reach Inflow	1046	84	150	124	155	174	77	68	54	1	-1	20	49	91
Depletion	113	-1	-0	-0	5	26	46	33	11	-2	-2	-1	-1	-1
Reg Inflow	19140	924	1238	1136	1295	1441	2048	2023	1860	1473	1448	1381	1529	1344
Evap	121	1	2	-7	-2	-1	13	27	33	30	15	5	1	1
Release	18656	537	837	1103	1319	1420	2025	2032	1952	2000	1936	1301	1201	996
Stor Change	363	386	399	40	-21	22	10	-36	-125	-557	-503	75	327	347
Storage	*2599	2985	3383	3423	3402	3425	3434	3398	3273	2716	2213	2288	2616	2963
Elev feet	*1344.3	1349.8	1354.7	1355.2	1354.9	1355.2	1355.3	1354.9	1353.4	1346.1	1337.9	1339.3	1344.6	1349.5
Disch kcfs	*10.8	9.7	13.6	18.5	21.4	23.9	32.9	33.0	32.8	32.5	32.5	21.2	19.5	17.9
Ave Power MW		82	120	166	191	212	289	290	286	274	254	161	156	151
Ave Cap MW		354	372	381	381	381	381	381	379	364	336	317	335	355
Energy GWh	1919.5	55.3	89.4	119.3	142.1	152.6	214.7	215.8	206.2	203.9	183.0	120.0	115.9	101.3
Gavins Point														
Reach Inflow	2291	140	210	170	217	232	196	162	155	162	162	142	147	196
Depletion	129	-1	-0	5	3	25	51	25	-4	4	10	11	1	-1
Reg Inflow	20792	688	1014	1268	1516	1611	2154	2168	2112	2158	2087	1475	1352	1187
Evap	33	0	0	1	2	1	6	5	6	6	4	2	0	0
Release	20766	694	1013	1267	1514	1607	2152	2152	2083	2152	2083	1474	1353	1222
Stor Change	-6	-7	1	-0	0	3	-3	11	24	0	0	-0	-1	-35
Storage	*333	326	327	327	327	331	327	338	362	362	363	362	361	327
Elev feet	*1206.2	1206.0	1206.0	1206.0	1206.0	1206.1	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	*13.1	12.5	16.5	21.3	24.6	27.0	35.0	35.0	35.0	35.0	35.0	24.0	22.0	22.0
Ave Power MW		49	64	81	93	102	124	124	127	127	127	93	86	85
Ave Cap MW		126	125	124	125	125	125	125	127	127	127	127	127	126
Energy GWh	933.9	33.2	47.6	58.1	69.4	73.7	92.0	92.3	91.1	94.6	91.6	68.8	64.0	57.3
Sioux City														
Reach Inflow	4014	140	600	698	620	537	392	230	182	149	128	101	84	154
Depletion	255	-1	-0	4	14	56	114	71	10	-5	-4	-2	-1	-1
Reg Flow	24507	838	1594	1961	2108	2087	2413	2311	2255	2306	2215	1605	1438	1377
Reg Flow kcfs		15.1	25.9	33.0	34.3	35.1	39.2	37.6	37.9	37.5	37.2	26.1	23.4	24.8
Total														
Reach Inflow	33446	1164	3486	3555	4261	7178	4280	1816	1471	1505	1308	992	981	1451
Depletion	-348	-45	35	-42	292	719	-85	-466	-274	-2	-14	-167	-189	-109
Evap	1787	10	27	-30	-13	-57	116	341	433	381	325	228	16	11
Storage	*48746	49129	50884	52539	54342	58731	60529	60165	59256	58109	56885	56257	55976	56147
Ave Power MW		641	756	853	1029	1163	1462	1467	1367	1151	1141	967	1078	1042
Ave Cap MW		2393	2420	2449	2474	2515	2541	2545	2538	2519	2482	2456	2466	2482
Energy GWh	10273.8	430.7	562.8	613.9	765.9	837.7	1087.5	1091.7	984.1	856.2	821.4	719.6	802.0	700.1
Daily GWh		15.4	18.2	20.5	24.7	27.9	35.1	35.2	32.8	27.6	27.4	23.2	25.9	25.0