

Date of Study: 01Mar2024

01Mar2024 / Basic Condition / 17.0 MAF / Balanced
Full Serv -0.5 kcfs 1st Half / Full Serv -4.0 kcfs 2nd Half / Nav End Date: Dec 01
Elevations & Storages are for Date Shown. Elevations in Local Project Datum (LPD)
Avg Discharge & Energy are Monthly Values

	2024											2025	
	29Feb	31Mar	30Apr	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
Fort Peck													
Elev feet	2230.4	2230.9	2230.4	2227.6	2226.9	2225.9	2224.7	2224.0	2224.1	2224.4	2223.7	2223.0	2222.7
Disch kcfs	5.4	5.0	8.4	13.7	11.9	9.0	9.0	6.8	4.5	4.5	8.0	8.5	8.5
Garrison													
Elev feet	1835.1	1834.6	1833.8	1834.4	1835.7	1835.3	1834.1	1833.0	1832.2	1831.1	1830.0	1828.8	1828.2
Disch kcfs	24.9	16.0	17.9	19.0	20.0	20.0	20.0	18.0	16.0	16.0	17.2	19.0	19.0
Oahe													
Elev feet	1603.6	1603.3	1602.7	1601.5	1600.7	1599.0	1596.8	1595.1	1594.8	1595.2	1596.0	1596.8	1597.9
Disch kcfs	10.8	21.1	25.1	27.6	28.5	29.2	29.5	25.9	17.0	13.9	12.8	15.8	15.1
Big Bend													
Elev feet	1420.6	1421.0	1420.8	1420.4	1421.0	1420.6	1420.7	1420.9	1420.5	1420.7	1420.8	1420.5	1420.4
Disch kcfs	12.4	20.6	25.3	27.8	27.9	29.2	29.1	25.4	17.1	13.6	12.6	16.1	15.1
Fort Randall													
Elev feet	1352.1	1354.8	1355.1	1355.3	1355.0	1355.1	1355.2	1353.3	1344.8	1337.4	1339.1	1344.9	1350.2
Disch kcfs	7.1	18.5	26.3	29.3	30.7	28.8	28.9	28.0	27.0	21.1	11.1	10.8	9.3
Gavins Point													
Elev feet	1206.6	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	13.0	20.6	29.3	32.4	33.8	30.3	30.0	29.5	29.1	23.8	12.5	12.5	12.5
System													
Storage KAF	53721	53837	53316	52604	52651	51850	50706	49665	48718	48152	47998	48098	48507
Energy GWh	8318	625	770	901	885	880	877	762	636	519	471	528	464
Ave Cap MW		2454	2449	2440	2437	2430	2416	2402	2382	2346	2334	2348	2368

01Mar2024 / Lower Basic Condition / 12.0 MAF / Balanced
Full Serv -0.9 kcfs 1st Half / Min Serv 2nd Half / Nav End Date: Nov 24

	2024											2025	
	29Feb	31Mar	30Apr	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
Fort Peck													
Elev feet	2230.4	2230.2	2228.8	2226.5	2225.9	2223.8	2221.7	2220.4	2219.9	2219.7	2218.6	2217.6	2216.8
Disch kcfs	5.4	5.0	8.7	12.2	9.0	9.0	9.0	6.8	4.5	4.5	7.5	8.0	8.0
Garrison													
Elev feet	1835.1	1833.9	1832.8	1832.9	1833.1	1832.4	1831.1	1829.8	1828.8	1827.6	1826.1	1824.5	1823.3
Disch kcfs	24.9	16.0	17.0	18.3	18.5	18.5	18.5	16.8	15.0	15.0	16.7	18.5	18.5
Oahe													
Elev feet	1603.6	1602.5	1600.8	1598.5	1596.3	1593.9	1591.4	1589.5	1589.5	1590.7	1591.3	1591.8	1592.6
Disch kcfs	10.8	23.2	26.9	30.0	31.1	28.7	28.4	24.5	14.3	10.0	13.2	16.3	16.1
Big Bend													
Elev feet	1420.6	1421.0	1420.8	1420.4	1421.0	1420.6	1420.7	1420.9	1420.5	1420.7	1420.8	1420.5	1420.4
Disch kcfs	12.4	22.7	27.1	30.2	30.6	28.7	28.0	24.0	14.4	9.7	13.0	16.6	16.1
Fort Randall													
Elev feet	1352.1	1354.8	1355.0	1355.3	1355.0	1355.1	1355.2	1353.2	1343.6	1337.5	1339.1	1344.9	1350.2
Disch kcfs	7.1	19.8	27.5	30.6	32.0	28.0	27.6	26.5	25.6	15.7	11.5	11.2	10.0
Gavins Point													
Elev feet	1206.6	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.6	1207.5	1207.5	1206.0
Disch kcfs	13.0	20.6	28.9	32.0	33.4	28.4	28.0	27.5	27.1	17.8	12.5	12.5	12.5
System													
Storage KAF	53721	53234	52193	51129	50462	49255	47885	46680	45599	45148	44793	44670	44772
Energy GWh	8022	658	788	910	877	838	822	708	571	413	461	517	459
Ave Cap MW		2448	2436	2419	2405	2392	2373	2357	2335	2298	2287	2297	2312

01Mar2024 / Upper Basic Condition / 22.7 MAF / Balanced
Full Serv -0.1 kcfs 1st Half / Full Serv -0.9 kcfs 2nd Half / Nav End Date: Dec 01

	2024											2025	
	29Feb	31Mar	30Apr	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
Fort Peck													
Elev feet	2230.4	2231.8	2232.3	2230.7	2230.6	2230.8	2230.2	2229.6	2229.5	2229.7	2229.8	2229.6	2229.8
Disch kcfs	5.4	5.0	8.7	14.0	16.5	8.6	8.0	7.0	6.0	6.0	7.0	8.0	8.0
Garrison													
Elev feet	1835.1	1835.0	1835.1	1836.5	1839.5	1839.8	1838.6	1837.5	1837.2	1836.6	1835.7	1834.6	1834.0
Disch kcfs	24.9	18.0	19.0	20.8	21.5	21.5	21.5	19.2	17.0	17.0	17.2	20.0	20.0
Oahe													
Elev feet	1603.6	1604.8	1605.2	1605.3	1605.8	1604.4	1602.3	1600.6	1600.1	1600.4	1601.2	1602.4	1604.0
Disch kcfs	10.8	18.2	23.0	25.1	26.2	31.1	31.6	28.0	19.4	15.7	12.1	14.8	13.8
Big Bend													
Elev feet	1420.6	1421.0	1420.8	1420.4	1421.0	1420.6	1420.6	1420.9	1420.5	1420.7	1420.7	1420.5	1420.4
Disch kcfs	12.4	17.7	23.2	25.3	25.7	31.1	31.2	27.5	19.5	15.4	11.9	15.1	13.9
Fort Randall													
Elev feet	1352.1	1354.8	1355.0	1355.3	1354.9	1355.1	1355.2	1353.3	1344.8	1337.4	1339.1	1344.8	1350.2
Disch kcfs	7.1	16.4	24.9	27.9	29.6	30.9	31.3	30.4	29.4	22.9	10.5	10.1	8.4
Gavins Point													
Elev feet	1206.6	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.4	1206.0
Disch kcfs	13.0	20.1	29.7	32.8	34.2	33.4	33.1	32.6	32.2	26.4	12.5	12.5	12.5
System													
Storage KAF	53721	54582	54843	54956	56014	55723	54626	53577	52660	52177	52246	52554	53256
Energy GWh	8629	595	754	889	900	949	946	836	719	587	463	531	461
Ave Cap MW		2462	2466	2469	2478	2477	2466	2454	2435	2401	2394	2410	2434

Date of Study: 01Mar2024

01Mar2024 / Basic Condition / 17.0 MAF / Balanced
Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)
F-Sum: Sum of Forecasted Values. *: Previous Month's Data

	2024 *29Feb F-Sum	31Mar	30Apr	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	2025 31Jan	28Feb
Fort Peck													
Reach Inflow	4990	430	420	600	950	440	220	240	320	380	330	300	360
Depletion	162	4	35	302	376	36	-188	-125	-42	-7	-74	-102	-53
Reg Inflow	4828	426	385	298	574	404	408	365	362	387	404	402	413
Evap	403	8	-6	3	1	43	77	89	66	65	46	6	3
Release	5900	307	500	843	710	553	553	402	277	268	492	523	472
Stor Change	-1474	111	-109	-548	-137	-192	-223	-126	19	54	-134	-127	-63
Storage	*14035	14146	14037	13489	13352	13160	12937	12811	12830	12884	12751	12624	12561
Elev feet	*2230.4	2230.9	2230.4	2227.6	2226.9	2225.9	2224.7	2224.0	2224.1	2224.4	2223.7	2223.0	2222.7
Disch kcfs	*5.4	5.0	8.4	13.7	11.9	9.0	9.0	6.8	4.5	4.5	8.0	8.5	8.5
Ave Power MW		56	93	147	129	98	97	73	49	49	86	91	91
Ave Cap MW		215	215	213	210	209	208	206	206	207	206	205	205
Energy GWh	772.0	41.6	67.0	109.7	92.9	72.7	72.3	52.3	36.2	35.1	63.9	67.6	60.8
Garrison													
Reach Inflow	6160	500	400	700	1400	800	370	330	440	350	250	260	360
Depletion	397	-18	4	202	588	237	-52	-79	-153	-133	-87	-70	-44
Reg Inflow	11637	828	827	1343	1555	1116	976	848	870	751	800	849	876
Evap	467	9	-11	-2	-30	13	92	117	114	100	67	-2	0
Release	13158	984	1067	1170	1190	1230	1230	1071	984	952	1057	1168	1055
Stor Change	-1988	-165	-229	176	395	-127	-346	-340	-228	-301	-325	-318	-180
Storage	*17031	16865	16636	16812	17206	17079	16733	16393	16165	15864	15540	15222	15042
Elev feet	*1835.1	1834.6	1833.8	1834.4	1835.7	1835.3	1834.1	1833.0	1832.2	1831.1	1830.0	1828.8	1828.2
Disch kcfs	*24.9	16.0	17.9	19.0	20.0	20.0	20.0	18.0	16.0	16.0	17.2	19.0	19.0
Ave Power MW		199	221	235	248	248	247	222	196	195	208	228	227
Ave Cap MW		555	552	552	557	558	555	550	545	541	537	531	527
Energy GWh	1951.9	147.9	159.5	174.7	178.3	184.7	183.9	159.5	146.1	140.6	154.9	169.6	152.3
Oahe													
Reach Inflow	1617	250	250	200	300	160	80	110	70	70	15	12	100
Depletion	148	22	17	25	38	50	20	0	-10	-7	-6	-4	2
Reg Inflow	14643	1238	1293	1338	1452	1340	1290	1195	1064	1029	1067	1184	1153
Evap	423	8	-11	-15	-26	14	74	108	99	88	73	7	4
Release	15803	1300	1495	1695	1696	1794	1815	1539	1046	825	785	973	840
Stor Change	-1583	-70	-191	-342	-217	-468	-599	-452	-81	116	209	204	309
Storage	*17489	17419	17228	16886	16669	16201	15603	15150	15069	15185	15393	15597	15906
Elev feet	*1603.6	1603.3	1602.7	1601.5	1600.7	1599.0	1596.8	1595.1	1594.8	1595.2	1596.0	1596.8	1597.9
Disch kcfs	*10.8	21.1	25.1	27.6	28.5	29.2	29.5	25.9	17.0	13.9	12.8	15.8	15.1
Ave Power MW		252	299	325	333	337	336	291	192	157	146	181	174
Ave Cap MW		692	686	682	676	670	661	651	645	645	649	653	658
Energy GWh	2210.9	187.7	215.0	241.6	239.7	251.1	250.1	209.9	142.8	112.9	108.3	134.6	117.2
Big Bend													
Reg Inflow	15800	1294	1495	1694	1697	1792	1815	1543	1048	829	782	973	839
Evap	106	1	3	3	3	19	24	21	15	10	5	1	0
Release	15703	1268	1506	1709	1662	1796	1788	1508	1053	810	773	989	840
Storage	*1666	1690	1675	1658	1690	1667	1670	1683	1662	1671	1675	1659	1657
Elev feet	*1420.6	1421.0	1420.8	1420.4	1421.0	1420.6	1420.7	1420.9	1420.5	1420.7	1420.8	1420.5	1420.4
Disch kcfs	*12.4	20.6	25.3	27.8	27.9	29.2	29.1	25.4	17.1	13.6	12.6	16.1	15.1
Ave Power MW		93	114	125	126	131	131	114	78	63	58	74	69
Ave Cap MW		493	490	487	487	486	486	489	496	499	500	497	498
Energy GWh	860.1	68.9	82.4	93.1	90.5	97.6	97.1	82.4	58.3	45.1	43.0	54.9	46.7
Fort Randall													
Reach Inflow	712	100	80	120	150	60	50	40	2	-0	15	35	60
Depletion	116	-0	-0	6	24	50	32	12	-2	-2	-2	-1	-1
Reg Inflow	16293	1363	1580	1820	1799	1795	1813	1538	1058	826	777	1024	899
Evap	118	2	-7	-2	-1	13	27	34	30	14	5	1	1
Release	16326	1136	1564	1803	1825	1773	1776	1664	1663	1258	680	665	519
Stor Change	-151	226	23	19	-24	9	9	-159	-634	-445	91	357	379
Storage	*3164	3390	3412	3432	3407	3416	3425	3266	2631	2186	2277	2634	3013
Elev feet	*1352.1	1354.8	1355.1	1355.3	1355.0	1355.1	1355.2	1353.3	1344.8	1337.4	1339.1	1344.9	1350.2
Disch kcfs	*7.1	18.5	26.3	29.3	30.7	28.8	28.9	28.0	27.0	21.1	11.1	10.8	9.3
Ave Power MW		162	233	259	270	255	255	246	229	166	86	88	80
Ave Cap MW		373	381	381	381	381	381	379	362	328	316	335	355
Energy GWh	1705.3	120.7	167.7	192.6	194.6	189.6	189.8	177.1	170.2	119.7	64.3	65.4	53.6
Gavins Point													
Reach Inflow	1780	180	190	210	210	160	120	120	130	120	100	100	140
Depletion	165	-1	6	5	27	66	37	3	3	9	11	1	-1
Reg Inflow	17935	1255	1745	1996	2012	1870	1861	1785	1794	1418	770	769	661
Evap	33	0	1	2	1	6	5	6	6	4	2	0	0
Release	17915	1267	1743	1995	2011	1864	1845	1755	1789	1413	769	769	694
Stor Change	-12	-13	1	-1	-1	0	11	24	-1	1	0	-0	-34
Storage	*340	327	328	327	327	327	338	362	361	362	362	362	328
Elev feet	*1206.6	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	*13.0	20.6	29.3	32.4	33.8	30.3	30.0	29.5	29.1	23.8	12.5	12.5	12.5
Ave Power MW		78	110	120	124	113	112	112	111	91	49	49	49
Ave Cap MW		125	125	125	125	125	125	127	127	127	127	127	126
Energy GWh	817.7	58.3	78.9	89.0	89.2	84.1	83.4	80.6	82.7	65.8	36.5	36.5	32.9
Sioux City													
Reach Inflow	1390	80	130	160	190	170	120	110	100	90	70	60	110
Depletion	281	-1	5	18	53	129	80	11	-6	-4	-2	-1	-1
Reg Flow	19025	1313	1868	2127	2149	1913	1885	1856	1896	1544	841	830	805
Reg Flow kcfs		21.3	31.4	34.6	36.1	31.1	30.7	31.2	30.8	25.9	13.7	13.5	14.5
Total													
Reach Inflow	16649	1540	1470	1990	3200	1790	960	950	1062	1010	780	767	1130
Depletion	1269	7	67	558	1106	568	-71	-178	-210	-144	-159	-178	-96
Evap	1549	29	-31	-12	-52	108	300	375	329	281	198	14	10
Storage	*53721	53837	53316	52604	52651	51850	50706	49665	48718	48152	47998	48098	48507
Ave Power MW		840	1070	1211	1230	1182	1178	1058	855	721	633	710	690
Ave Cap MW		2454	2449	2440	2437	2430	2416	2402	2382	2346	2334	2348	2368
Energy GWh	8317.9	625.0	770.5	900.6	885.3	879.7	876.6	761.7	636.2	519.2	470.9	528.5	463.7
Daily GWh		20.2	25.7	29.1	29.5	28.4	28.3	25.4	20.5	17.3	15.2	17.0	16.6

Date of Study: 01Mar2024

01Mar2024 / Lower Basic Condition / 12.0 MAF / Balanced
Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)
F-Sum: Sum of Forecasted Values. *: Previous Month's Data

	2024											2025	
	*29Feb	31Mar	30Apr	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
	F-Sum												
Fort Peck													
Reach Inflow	3544	280	273	420	618	286	154	180	256	304	264	240	270
Depletion	137	-1	32	122	201	85	-95	-61	2	10	-49	-75	-32
Reg Inflow	3407	281	241	298	417	201	249	241	254	294	313	315	302
Evap	390	8	-6	3	1	42	75	87	64	63	44	6	3
Release	5560	307	515	752	536	553	553	402	277	268	461	492	444
Stor Change	-2543	-35	-268	-457	-120	-394	-379	-247	-87	-37	-191	-183	-145
Storage	*14035	14000	13733	13276	13156	12761	12382	12135	12048	12011	11820	11637	11492
Elev feet	*2230.4	2230.2	2228.8	2226.5	2225.9	2223.8	2221.7	2220.4	2219.9	2219.7	2218.6	2217.6	2216.8
Disch kcfs	*5.4	5.0	8.7	12.2	9.0	9.0	9.0	6.8	4.5	4.5	7.5	8.0	8.0
Ave Power MW		56	95	130	98	97	96	71	48	47	78	83	82
Ave Cap MW		214	213	211	209	207	205	202	201	201	200	199	197
Energy GWh	716.9	41.5	68.6	96.9	70.3	72.1	71.2	51.3	35.4	34.2	58.2	61.7	55.4
Garrison													
Reach Inflow	4321	325	260	490	910	520	259	248	352	280	200	208	270
Depletion	187	21	10	135	318	120	-48	-59	-126	-100	-45	-28	-10
Reg Inflow	9672	615	695	1143	1128	953	861	746	755	647	682	723	724
Evap	449	9	-11	-2	-29	13	89	113	110	96	64	-2	0
Release	12497	984	1012	1123	1101	1138	1138	997	922	893	1027	1138	1027
Stor Change	-3274	-379	-305	23	56	-197	-365	-364	-277	-341	-409	-413	-303
Storage	*17031	16652	16347	16370	16426	16229	15863	15499	15222	14881	14472	14059	13756
Elev feet	*1835.1	1833.9	1832.8	1832.9	1833.1	1832.4	1831.1	1829.8	1828.8	1827.6	1826.1	1824.5	1823.3
Disch kcfs	*24.9	16.0	17.0	18.3	18.5	18.5	18.5	16.8	15.0	15.0	16.7	18.5	18.5
Ave Power MW		198	209	224	227	226	225	203	181	180	198	216	214
Ave Cap MW		554	548	547	547	546	542	536	531	526	519	512	505
Energy GWh	1826.1	147.6	150.6	166.6	163.3	168.5	167.5	146.0	134.5	129.3	147.1	160.9	144.0
Oahe													
Reach Inflow	935	138	125	100	150	88	52	83	52	53	11	9	75
Depletion	148	22	17	25	38	50	20	0	-10	-7	-6	-4	2
Reg Inflow	13302	1125	1116	1192	1213	1176	1170	1091	985	952	1034	1148	1100
Evap	396	8	-11	-14	-25	13	68	101	93	83	69	7	4
Release	15872	1429	1602	1842	1852	1763	1744	1457	877	595	814	1004	894
Stor Change	-2966	-312	-475	-635	-613	-601	-643	-467	15	273	150	138	203
Storage	*17489	17177	16703	16067	15454	14854	14210	13744	13759	14032	14183	14321	14523
Elev feet	*1603.6	1602.5	1600.8	1598.5	1596.3	1593.9	1591.4	1589.5	1589.5	1590.7	1591.3	1591.8	1592.6
Disch kcfs	*10.8	23.2	26.9	30.0	31.1	28.7	28.4	24.5	14.3	10.0	13.2	16.3	16.1
Ave Power MW		276	316	346	352	320	310	263	154	109	145	179	178
Ave Cap MW		690	679	670	658	646	634	622	617	620	625	628	632
Energy GWh	2155.3	205.3	227.7	257.2	253.6	237.9	230.4	189.5	114.5	78.4	108.0	133.3	119.5
Big Bend													
Reg Inflow	15868	1422	1602	1840	1853	1763	1745	1460	878	597	812	1003	893
Evap	106	1	3	3	3	19	24	21	15	10	5	1	0
Release	15772	1397	1613	1856	1818	1766	1719	1426	884	578	802	1020	894
Storage	*1666	1689	1675	1658	1690	1667	1670	1682	1662	1670	1675	1658	1657
Elev feet	*1420.6	1421.0	1420.8	1420.4	1421.0	1420.6	1420.7	1420.9	1420.5	1420.7	1420.8	1420.5	1420.4
Disch kcfs	*12.4	22.7	27.1	30.2	30.6	28.7	28.0	24.0	14.4	9.7	13.0	16.6	16.1
Ave Power MW		102	122	135	137	129	126	108	66	45	60	76	74
Ave Cap MW		492	488	485	485	487	487	490	498	502	500	496	497
Energy GWh	863.2	75.8	88.0	100.7	98.6	96.1	93.5	78.1	49.2	32.4	44.7	56.5	49.6
Fort Randall													
Reach Inflow	409	55	40	60	75	33	33	30	1	-0	11	26	45
Depletion	116	-0	-0	6	24	50	32	12	-2	-2	-2	-1	-1
Reg Inflow	16058	1446	1646	1907	1880	1741	1726	1446	889	591	803	1045	937
Evap	117	2	-7	-2	-1	13	27	34	29	13	6	1	1
Release	16088	1219	1634	1884	1902	1720	1695	1576	1572	935	707	690	553
Stor Change	-147	225	18	25	-21	8	4	-163	-712	-357	91	354	382
Storage	*3164	3389	3407	3431	3410	3418	3422	3259	2547	2190	2281	2634	3017
Elev feet	*1352.1	1354.8	1355.0	1355.3	1355.0	1355.1	1355.2	1353.2	1343.6	1337.5	1339.1	1344.9	1350.2
Disch kcfs	*7.1	19.8	27.5	30.6	32.0	28.0	27.6	26.5	25.6	15.7	11.5	11.2	10.0
Ave Power MW		174	243	270	281	247	244	233	215	123	90	91	85
Ave Cap MW		373	381	381	381	381	381	379	360	322	317	335	355
Energy GWh	1682.2	129.3	175.0	201.0	202.6	184.0	181.4	168.0	160.3	88.8	66.9	67.8	57.1
Gavins Point													
Reach Inflow	1102	99	95	105	105	88	78	90	97	90	75	75	105
Depletion	165	-1	6	5	27	66	37	3	3	9	11	1	-1
Reg Inflow	17018	1253	1721	1971	1988	1750	1738	1666	1672	1064	768	768	660
Evap	33	0	1	2	1	6	5	6	6	4	2	0	0
Release	16999	1265	1720	1970	1987	1744	1722	1636	1666	1057	768	769	694
Stor Change	-13	-13	1	-1	-1	0	11	24	-0	3	-2	-1	-34
Storage	*340	327	328	327	326	326	338	361	361	364	362	361	327
Elev feet	*1206.6	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.6	1207.5	1207.5	1206.0
Disch kcfs	*13.0	20.6	28.9	32.0	33.4	28.4	28.0	27.5	27.1	17.8	12.5	12.5	12.5
Ave Power MW		78	108	118	123	106	105	105	104	69	49	49	49
Ave Cap MW		125	125	125	125	125	125	127	127	127	127	127	126
Energy GWh	778.0	58.2	78.0	88.1	88.3	79.2	78.3	75.4	77.3	49.4	36.4	36.5	32.9
Sioux City													
Reach Inflow	861	44	65	80	95	93	78	83	75	68	52	45	83
Depletion	281	-1	5	18	53	129	80	11	-6	-4	-2	-1	-1
Reg Flow	17579	1275	1779	2023	2030	1720	1720	1709	1748	1168	814	815	777
Reg Flow kcfs		20.7	29.9	32.9	34.1	28.0	28.0	28.7	28.4	19.6	13.2	13.2	14.0
Total													
Reach Inflow	11173	940	858	1255	1953	1109	653	713	834	794	614	603	847
Depletion	1034	40	70	311	660	499	25	-95	-139	-93	-94	-108	-42
Evap	1492	29	-30	-11	-50	105	289	362	317	269	189	13	9
Storage	*53721	53234	52193	51129	50462	49255	47885	46680	45599	45148	44793	44670	44772
Ave Power MW		884	1094	1224	1218	1126	1105	984	768	573	620	694	682
Ave Cap MW		2448	2436	2419	2405	2392	2373	2357	2335	2298	2287	2297	2312
Energy GWh	8021.6	657.8	787.8	910.5	876.7	837.7	822.4	708.4	571.2	412.6	461.4	516.7	458.6
Daily GWh		21.2	26.3	29.4	29.2	27.0	26.5	23.6	18.4	13.8	14.9	16.7	16.4

Date of Study: 01Mar2024

01Mar2024 / Upper Basic Condition / 22.7 MAF / Balanced
Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)
F-Sum: Sum of Forecasted Values. *: Previous Month's Data

	2024											2025	
	*29Feb	31Mar	30Apr	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
	F-Sum												
Fort Peck													
Reach Inflow	6617	581	609	810	1377	638	286	288	384	456	396	360	432
Depletion	96	-33	-8	281	410	26	-172	-109	-31	-14	-89	-106	-60
Reg Inflow	6521	614	617	529	967	612	458	397	415	470	485	466	492
Evap	430	8	-6	3	1	45	83	96	71	70	49	7	4
Release	6199	307	515	863	983	528	492	418	369	357	430	492	444
Stor Change	-107	298	108	-337	-17	40	-117	-118	-25	43	6	-33	44
Storage	*14035	14334	14441	14104	14088	14127	14011	13893	13868	13911	13917	13884	13928
Elev feet	*2230.4	2231.8	2232.3	2230.7	2230.6	2230.8	2230.2	2229.6	2229.5	2229.7	2229.8	2229.6	2229.8
Disch kcfs	*5.4	5.0	8.7	14.0	16.5	8.6	8.0	7.0	6.0	6.0	7.0	8.0	8.0
Ave Power MW		56	97	153	161	95	89	78	67	67	77	88	88
Ave Cap MW		215	216	216	215	215	215	214	213	214	214	214	214
Energy GWh	814.5	41.7	69.5	113.8	116.0	70.9	66.1	56.1	49.5	47.9	57.7	65.8	59.5
Garrison													
Reach Inflow	8259	675	580	945	2030	1160	481	396	528	420	300	312	432
Depletion	225	-104	-99	115	804	320	-59	-106	-181	-161	-125	-110	-69
Reg Inflow	14210	1089	1125	1693	2177	1445	1032	937	1077	938	847	905	945
Evap	499	9	-11	-3	-31	14	98	125	121	107	72	-2	0
Release	14036	1107	1131	1277	1279	1322	1322	1145	1045	1012	1055	1230	1111
Stor Change	-325	-27	5	418	928	109	-388	-333	-89	-180	-280	-323	-166
Storage	*17031	17003	17009	17426	18355	18464	18075	17743	17654	17474	17194	16871	16706
Elev feet	*1835.1	1835.0	1835.1	1836.5	1839.5	1839.8	1838.6	1837.5	1837.2	1836.6	1835.7	1834.6	1834.0
Disch kcfs	*24.9	18.0	19.0	20.8	21.5	21.5	21.5	19.2	17.0	17.0	17.2	20.0	20.0
Ave Power MW		223	235	258	270	272	272	242	214	213	214	248	247
Ave Cap MW		556	556	560	568	575	573	569	566	564	561	557	553
Energy GWh	2123.5	166.2	169.5	192.0	194.2	202.7	202.1	174.5	159.1	153.6	159.6	184.3	165.7
Oahe													
Reach Inflow	2354	375	388	310	435	224	108	149	94	94	20	17	140
Depletion	148	22	17	25	38	50	20	0	-10	-7	-6	-4	2
Reg Inflow	16254	1479	1497	1553	1677	1496	1410	1310	1150	1113	1072	1249	1249
Evap	459	8	-11	-16	-28	15	80	117	107	95	80	8	5
Release	15661	1122	1367	1541	1561	1913	1942	1667	1192	931	746	911	769
Stor Change	134	349	142	28	144	-432	-611	-475	-149	86	247	329	475
Storage	*17489	17838	17980	18008	18152	17720	17109	16634	16485	16571	16818	17148	17623
Elev feet	*1603.6	1604.8	1605.2	1605.3	1605.8	1604.4	1602.3	1600.6	1600.1	1600.4	1601.2	1602.4	1604.0
Disch kcfs	*10.8	18.2	23.0	25.1	26.2	31.1	31.6	28.0	19.4	15.7	12.1	14.8	13.8
Ave Power MW		220	278	303	317	373	374	328	227	184	144	177	167
Ave Cap MW		695	696	698	699	697	688	679	672	671	675	680	687
Energy GWh	2261.3	163.4	199.8	225.4	228.4	277.7	278.1	236.5	169.1	132.2	107.1	131.5	112.1
Big Bend													
Reg Inflow	15659	1116	1367	1540	1562	1910	1942	1670	1194	937	742	911	768
Evap	106	1	3	3	3	19	24	21	15	10	5	1	0
Release	15562	1091	1379	1555	1527	1913	1916	1635	1199	917	734	926	770
Storage	*1666	1690	1675	1658	1690	1667	1669	1682	1662	1671	1675	1659	1657
Elev feet	*1420.6	1421.0	1420.8	1420.4	1421.0	1420.6	1420.6	1420.9	1420.5	1420.7	1420.5	1420.5	1420.4
Disch kcfs	*12.4	17.7	23.2	25.3	25.7	31.1	31.2	27.5	19.5	15.4	11.9	15.1	13.9
Ave Power MW		80	105	114	116	139	139	124	89	71	55	69	64
Ave Cap MW		496	491	490	489	485	484	487	494	498	500	498	499
Energy GWh	852.5	59.4	75.7	85.0	83.5	103.7	103.8	89.1	66.2	50.9	40.9	51.5	42.9
Fort Randall													
Reach Inflow	1038	150	124	186	217	84	67	54	3	-1	20	49	84
Depletion	116	-0	-0	6	24	50	32	12	-2	-2	-2	-1	-1
Reg Inflow	16479	1237	1497	1732	1732	1932	1958	1679	1205	935	744	976	852
Evap	118	2	-7	-2	-1	13	27	34	30	14	5	1	1
Release	16509	1010	1483	1713	1763	1902	1925	1807	1808	1365	645	624	466
Stor Change	-148	225	21	22	-31	17	6	-162	-633	-444	94	351	385
Storage	*3164	3390	3410	3432	3401	3418	3424	3263	2630	2187	2280	2631	3016
Elev feet	*1352.1	1354.8	1355.0	1355.3	1354.9	1355.1	1355.2	1353.3	1344.8	1337.4	1339.1	1344.8	1350.2
Disch kcfs	*7.1	16.4	24.9	27.9	29.6	30.9	31.3	30.4	29.4	22.9	10.5	10.1	8.4
Ave Power MW		145	221	246	262	273	276	266	248	180	82	82	72
Ave Cap MW		373	381	381	381	381	381	379	362	328	316	335	355
Energy GWh	1722.5	107.6	159.2	183.3	188.3	202.8	205.2	191.7	184.4	129.4	61.0	61.4	48.2
Gavins Point													
Reach Inflow	2551	270	295	326	304	224	162	162	176	162	135	140	196
Depletion	165	-1	6	5	27	66	37	3	3	9	11	1	-1
Reg Inflow	18889	1223	1769	2021	2037	2059	2051	1970	1985	1578	770	768	660
Evap	33	0	1	2	1	6	5	6	6	4	2	0	0
Release	18870	1236	1767	2020	2035	2054	2035	1940	1980	1572	769	769	694
Stor Change	-14	-13	1	-0	0	-1	11	24	-1	1	-1	-1	-35
Storage	*340	327	328	328	328	327	338	362	361	363	362	361	326
Elev feet	*1206.6	1206.0	1206.0	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.4	1206.0
Disch kcfs	*13.0	20.1	29.7	32.8	34.2	33.4	33.1	32.6	32.2	26.4	12.5	12.5	12.5
Ave Power MW		76	111	120	124	123	122	123	122	101	49	49	49
Ave Cap MW		125	125	125	125	125	125	127	127	127	127	127	126
Energy GWh	855.0	56.9	79.9	89.4	89.1	91.2	90.7	88.3	90.9	72.8	36.5	36.5	32.9
Sioux City													
Reach Inflow	1983	120	201	248	276	238	162	149	135	122	94	84	154
Depletion	281	-1	5	18	53	129	80	11	-6	-4	-2	-1	-1
Reg Flow	20573	1321	1962	2240	2258	2164	2118	2079	2121	1741	865	854	849
Reg Flow kcfs		21.5	33.0	36.4	37.9	35.2	34.4	34.9	34.5	29.3	14.1	13.9	15.3
Total													
Reach Inflow	22802	2171	2197	2824	4640	2568	1267	1197	1320	1253	966	962	1438
Depletion	1031	-116	-79	449	1356	640	-62	-189	-226	-179	-213	-221	-129
Evap	1645	29	-31	-12	-55	112	317	398	350	299	212	15	10
Storage	*53721	54582	54843	54956	56014	55723	54626	53577	52660	52177	52246	52554	53256
Ave Power MW		800	1047	1195	1249	1275	1271	1161	967	815	622	714	687
Ave Cap MW		2462	2466	2469	2478	2477	2466	2454	2435	2401	2394	2410	2434
Energy GWh	8629.2	595.2	753.6	888.9	899.5	948.9	945.9	836.1	719.1	586.8	462.7	530.9	461.4
Daily GWh		19.2	25.1	28.7	30.0	30.6	30.5	27.9	23.2	19.6	14.9	17.1	16.5