

Date of Study: 03Jun2024

01Jun2024 / Basic Condition / 21.0 MAF / Balanced
Full Serv 1st Half / Full Serv -1.1 kcfs 2nd Half / Nav End Date: Dec 01
Elevations & Storages are for Date Shown. Elevations in Local Project Datum (LPD)
Avg Discharge & Energy are Monthly Values

	2024								2025	
	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
Fort Peck										
Elev feet	2231.6	2230.7	2230.2	2229.3	2228.8	2228.8	2229.0	2228.1	2227.3	2226.8
Disch kcfs	11.4	15.2	8.5	8.0	6.0	4.0	4.0	8.0	8.5	8.5
Garrison										
Elev feet	1838.0	1841.4	1842.3	1840.9	1839.3	1838.0	1836.5	1835.3	1833.1	1831.5
Disch kcfs	19.6	22.0	22.0	22.0	20.5	19.0	19.0	17.9	24.0	24.0
Oahe										
Elev feet	1603.1	1603.0	1601.2	1598.7	1596.7	1596.3	1596.8	1597.7	1599.5	1601.4
Disch kcfs	17.7	26.1	31.3	32.9	29.1	20.2	16.1	12.9	16.0	15.5
Big Bend										
Elev feet	1420.2	1421.0	1420.6	1420.7	1420.9	1420.5	1420.7	1420.8	1420.5	1420.4
Disch kcfs	18.7	25.4	31.2	32.5	28.6	20.3	15.9	12.7	16.2	15.5
Fort Randall										
Elev feet	1355.4	1355.0	1355.1	1355.2	1353.2	1344.8	1337.4	1339.1	1344.9	1350.2
Disch kcfs	21.1	27.1	30.1	31.8	30.9	30.1	23.5	11.1	10.7	9.3
Gavins Point										
Elev feet	1206.0	1206.0	1206.0	1206.5	1207.5	1207.4	1207.5	1207.5	1207.5	1206.0
Disch kcfs	25.3	29.0	30.9	32.9	32.4	32.0	26.3	12.5	12.5	12.5
System										
Storage KAF	54950	55839	55501	54163	52899	51760	51014	50801	50855	51181
Energy GWh	6740	899	970	993	874	749	608	506	605	535
Ave Cap MW		2463	2459	2445	2431	2411	2376	2366	2380	2400

01Jun2024 / Lower Basic Condition / 17.5 MAF / Balanced
Full Serv -0.9 kcfs 1st Half / Full Serv -1.9 kcfs 2nd Half / Nav End Date: Dec 01

	2024								2025	
	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
Fort Peck										
Elev feet	2231.6	2229.7	2228.0	2226.3	2225.1	2224.7	2224.4	2223.6	2222.6	2221.8
Disch kcfs	11.4	15.2	8.5	8.0	6.0	4.0	4.0	6.5	7.5	7.5
Garrison										
Elev feet	1838.0	1840.0	1839.8	1837.9	1836.1	1834.8	1833.2	1831.6	1829.4	1827.6
Disch kcfs	19.6	22.0	22.0	22.0	19.5	17.0	17.0	16.7	21.5	21.5
Oahe										
Elev feet	1603.1	1602.2	1600.0	1597.4	1595.1	1594.3	1594.3	1594.8	1596.0	1597.3
Disch kcfs	17.7	28.1	32.0	32.8	29.0	19.8	16.1	13.4	16.4	16.4
Big Bend										
Elev feet	1420.2	1421.0	1420.6	1420.7	1420.9	1420.5	1420.7	1420.8	1420.5	1420.4
Disch kcfs	18.7	27.3	32.0	32.4	28.5	19.9	15.8	13.2	16.7	16.4
Fort Randall										
Elev feet	1355.4	1354.9	1355.1	1355.2	1353.3	1344.8	1337.4	1339.2	1344.9	1350.2
Disch kcfs	21.1	28.4	30.7	31.7	30.6	29.8	23.3	11.5	11.2	10.0
Gavins Point										
Elev feet	1206.0	1206.0	1206.0	1206.4	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	25.3	29.0	30.6	32.1	31.6	31.2	25.6	12.5	12.5	12.5
System										
Storage KAF	54950	54931	53932	52295	50811	49461	48525	48130	47972	48006
Energy GWh	6603	928	977	983	853	715	582	482	572	511
Ave Cap MW		2456	2446	2427	2408	2384	2345	2332	2341	2356

01Jun2024 / Upper Basic Condition / 25.1 MAF / FTPK -0.1, GARR 1.3, OAHE -1.4
Full Serv 1st Half / Full Serv 2nd Half / Nav End Date: Dec 01

	2024								2025	
	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
Fort Peck										
Elev feet	2231.6	2232.9	2233.6	2232.9	2232.4	2232.3	2232.5	2232.2	2231.7	2231.6
Disch kcfs	11.4	15.2	8.5	8.0	6.5	5.0	5.0	7.5	8.5	8.5
Garrison										
Elev feet	1838.0	1843.5	1845.7	1844.5	1843.1	1842.1	1840.8	1839.7	1838.0	1836.8
Disch kcfs	19.6	22.5	23.0	23.0	22.0	21.0	21.0	18.6	24.0	24.0
Oahe										
Elev feet	1603.1	1603.8	1602.6	1600.5	1599.1	1599.3	1600.2	1600.9	1602.3	1604.1
Disch kcfs	17.7	24.3	30.6	32.4	28.6	19.5	16.7	14.3	17.3	16.3
Big Bend										
Elev feet	1420.2	1421.0	1420.6	1420.7	1420.9	1420.5	1420.7	1420.7	1420.5	1420.4
Disch kcfs	18.7	23.5	30.6	31.9	28.1	19.6	16.4	14.1	17.5	16.3
Fort Randall										
Elev feet	1355.4	1354.9	1355.1	1355.1	1353.3	1344.8	1337.4	1339.1	1344.9	1350.2
Disch kcfs	21.1	25.9	29.6	31.4	30.5	29.5	24.0	12.6	12.2	10.3
Gavins Point										
Elev feet	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	25.3	29.0	31.2	33.2	32.6	32.0	27.4	14.6	14.6	14.6
System										
Storage KAF	54950	57237	57727	56611	55516	54593	53995	53866	53993	54473
Energy GWh	6937	876	976	1003	893	773	656	548	647	565
Ave Cap MW		2471	2476	2467	2456	2442	2410	2403	2418	2441

Date of Study: 03Jun2024

01Jun2024 / Basic Condition / 21.0 MAF / Balanced

Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)

F-Sum: Sum of Forecasted Values. *: Previous Month's Data

	2024								2025	
	*31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
	F-Sum									
Fort Peck										
Reach Inflow	3530	1100	500	200	225	290	330	290	275	320
Depletion	-179	376	36	-188	-125	-42	-7	-74	-102	-53
Reg Inflow	3709	724	464	388	350	332	337	364	377	373
Evap	420	1	45	82	94	70	69	48	6	3
Release	4246	904	522	492	357	246	238	492	523	472
Stor Change	-956	-181	-103	-186	-102	16	30	-176	-152	-103
Storage	*14288	14106	14004	13818	13716	13732	13763	13586	13434	13331
Elev feet	*2231.6	2230.7	2230.2	2229.3	2228.8	2228.8	2229.0	2228.1	2227.3	2226.8
Disch kcfs	*11.4	15.2	8.5	8.0	6.0	4.0	4.0	8.0	8.5	8.5
Ave Power MW		177	112	106	79	53	53	105	111	111
Ave Cap MW		216	214	214	213	212	213	212	211	210
Energy GWh	658.5	127.3	83.5	78.5	56.9	39.4	38.1	78.0	82.5	74.3
Garrison										
Reach Inflow	5990	2100	1300	440	380	500	390	260	260	360
Depletion	208	588	237	-52	-79	-153	-133	-87	-70	-44
Reg Inflow	10042	2370	1649	984	849	899	761	805	849	876
Evap	513	-32	15	102	129	124	107	71	-2	0
Release	11443	1309	1353	1353	1220	1168	1131	1101	1476	1333
Stor Change	-1914	1093	282	-470	-500	-393	-477	-367	-625	-457
Storage	*17898	18992	19273	18803	18304	17911	17434	17067	16442	15985
Elev feet	*1838.0	1841.4	1842.3	1840.9	1839.3	1838.0	1836.5	1835.3	1833.1	1831.5
Disch kcfs	*19.6	22.0	22.0	22.0	20.5	19.0	19.0	17.9	24.0	24.0
Ave Power MW		280	284	283	262	242	240	225	296	293
Ave Cap MW		574	581	580	576	571	566	560	552	544
Energy GWh	1749.1	201.7	211.0	210.6	188.8	179.9	172.8	167.2	220.3	196.8
Oahe										
Reach Inflow	686	225	130	60	78	52	47	10	9	75
Depletion	83	38	50	20	0	-10	-7	-6	-4	2
Reg Inflow	12035	1493	1433	1393	1309	1230	1185	1105	1483	1406
Evap	452	-27	14	76	111	101	90	75	8	4
Release	12074	1556	1922	2021	1734	1243	961	792	983	863
Stor Change	-492	-36	-503	-704	-536	-113	134	237	493	538
Storage	*17356	17319	16816	16112	15576	15462	15596	15833	16325	16864
Elev feet	*1603.1	1603.0	1601.2	1598.7	1596.7	1596.3	1596.8	1597.7	1599.5	1601.4
Disch kcfs	*17.7	26.1	31.3	32.9	29.1	20.2	16.1	12.9	16.0	15.5
Ave Power MW		327	386	399	349	242	194	157	196	193
Ave Cap MW		686	682	671	660	653	652	657	664	673
Energy GWh	1782.5	235.4	287.3	296.8	251.5	180.2	139.6	116.5	145.5	129.6
Big Bend										
Reg Inflow	12077	1556	1918	2022	1737	1244	967	789	982	862
Evap	99	3	19	24	21	15	10	5	1	0
Release	11965	1508	1921	1995	1703	1250	946	780	999	863
Storage	*1645	1690	1668	1670	1682	1662	1672	1675	1658	1657
Elev feet	*1420.2	1421.0	1420.6	1420.7	1420.9	1420.5	1420.7	1420.8	1420.5	1420.4
Disch kcfs	*18.7	25.4	31.2	32.5	28.6	20.3	15.9	12.7	16.2	15.5
Ave Power MW		114	139	144	128	92	73	58	74	71
Ave Cap MW		481	475	474	478	486	490	494	490	491
Energy GWh	652.8	82.1	103.5	107.2	92.2	68.7	52.4	43.4	55.3	47.9
Fort Randall										
Reach Inflow	204	80	20	20	20	1	-0	8	20	35
Depletion	111	24	50	32	12	-2	-2	-2	-1	-1
Reg Inflow	12061	1572	1875	1991	1712	1254	964	778	1018	897
Evap	125	-1	13	27	34	30	14	5	1	1
Release	12361	1610	1853	1954	1842	1852	1396	680	660	515
Stor Change	-424	-37	9	9	-163	-627	-446	92	357	381
Storage	*3441	3404	3413	3422	3259	2632	2186	2278	2635	3016
Elev feet	*1355.4	1355.0	1355.1	1355.2	1353.2	1344.8	1337.4	1339.1	1344.9	1350.2
Disch kcfs	*21.1	27.1	30.1	31.8	30.9	30.1	23.5	11.1	10.7	9.3
Ave Power MW		243	269	284	275	257	186	87	88	80
Ave Cap MW		381	381	381	379	362	328	316	335	355
Energy GWh	1293.6	174.8	200.4	211.0	197.9	191.1	133.9	65.0	65.6	53.9
Gavins Point										
Reach Inflow	1100	150	130	120	115	120	120	100	105	140
Depletion	156	27	66	37	3	3	9	11	1	-1
Reg Inflow	13368	1728	1905	2039	1957	1973	1568	770	768	662
Evap	30	1	6	5	6	6	4	2	0	0
Release	13337	1726	1899	2023	1928	1968	1562	769	769	694
Stor Change	1	1	-0	11	23	-1	2	-0	-1	-33
Storage	*327	328	327	338	362	361	363	362	361	328
Elev feet	*1206.0	1206.0	1206.0	1206.5	1207.5	1207.4	1207.5	1207.5	1207.5	1206.0
Disch kcfs	*25.3	29.0	30.9	32.9	32.4	32.0	26.3	12.5	12.5	12.5
Ave Power MW		107	113	120	121	120	100	48	48	48
Ave Cap MW		125	125	125	127	127	127	127	127	126
Energy GWh	603.3	77.4	84.4	89.1	86.9	89.4	71.6	36.0	36.0	32.3
Sioux City										
Reach Inflow	1355	350	270	160	130	110	90	75	60	110
Depletion	259	53	129	80	11	-6	-4	-2	-1	-1
Reg Flow	14467	2021	2032	2102	2048	2084	1699	846	830	805
Reg Flow kcfs		34.0	33.1	34.2	34.4	33.9	28.6	13.8	13.5	14.5
Total										
Reach Inflow	12865	4005	2350	1000	948	1073	977	743	729	1040
Depletion	638	1106	568	-71	-178	-210	-144	-159	-178	-96
Evap	1639	-55	112	316	395	345	294	207	15	10
Storage	*54950	55839	55501	54163	52899	51760	51014	50801	50855	51181
Ave Power MW		1248	1304	1335	1214	1006	845	680	814	796
Ave Cap MW		2463	2459	2445	2431	2411	2376	2366	2380	2400
Energy GWh	6739.7	898.7	970.1	993.2	874.2	748.7	608.5	506.2	605.4	534.9
Daily GWh		30.0	31.3	32.0	29.1	24.2	20.3	16.3	19.5	19.1

Date of Study: 03Jun2024

01Jun2024 / Lower Basic Condition / 17.5 MAF / Balanced
Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)
F-Sum: Sum of Forecasted Values. *: Previous Month's Data

	2024								2025	
	*31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
	F-Sum									
Fort Peck										
Reach Inflow	2537	715	325	140	169	232	264	232	220	240
Depletion	-15	201	85	-95	-61	2	10	-49	-75	-32
Reg Inflow	2552	514	240	235	230	230	254	281	295	272
Evap	402	1	44	79	91	67	65	46	6	3
Release	4036	904	522	492	357	246	238	400	461	417
Stor Change	-1886	-391	-326	-335	-217	-83	-50	-164	-172	-147
Storage	*14288	13896	13571	13235	13018	12935	12885	12721	12549	12401
Elev feet	*2231.6	2229.7	2228.0	2226.3	2225.1	2224.7	2224.4	2223.6	2222.6	2221.8
Disch kcfs	*11.4	15.2	8.5	8.0	6.0	4.0	4.0	6.5	7.5	7.5
Ave Power MW		176	111	104	78	52	52	83	96	95
Ave Cap MW		215	212	210	208	207	207	206	205	204
Energy GWh	616.0	126.9	82.8	77.5	55.9	38.6	37.3	62.0	71.1	63.9
Garrison										
Reach Inflow	4201	1365	845	308	285	400	312	208	208	270
Depletion	21	318	120	-48	-59	-126	-100	-45	-28	-10
Reg Inflow	8239	1906	1311	848	735	772	650	632	689	697
Evap	490	-32	14	97	123	118	102	68	-2	0
Release	10771	1309	1353	1353	1158	1045	1012	1025	1322	1194
Stor Change	-3022	628	-56	-602	-546	-391	-464	-462	-632	-498
Storage	*17898	18527	18471	17869	17323	16932	16468	16006	15374	14877
Elev feet	*1838.0	1840.0	1839.8	1837.9	1836.1	1834.8	1833.2	1831.6	1829.4	1827.6
Disch kcfs	*19.6	22.0	22.0	22.0	19.5	17.0	17.0	16.7	21.5	21.5
Ave Power MW		279	281	279	245	213	211	206	260	257
Ave Cap MW		572	576	572	565	558	552	545	536	527
Energy GWh	1624.8	201.0	209.0	207.8	176.6	158.6	152.2	153.0	193.8	172.9
Oahe										
Reach Inflow	426	112	72	39	59	39	35	8	7	56
Depletion	83	38	50	20	0	-10	-7	-6	-4	2
Reg Inflow	11113	1380	1374	1372	1235	1094	1054	1027	1329	1248
Evap	440	-27	14	75	109	98	87	72	7	4
Release	12300	1674	1967	2018	1725	1217	959	822	1009	909
Stor Change	-1627	-267	-606	-721	-599	-221	7	132	313	335
Storage	*17356	17089	16482	15762	15163	14942	14949	15081	15394	15729
Elev feet	*1603.1	1602.2	1600.0	1597.4	1595.1	1594.3	1594.3	1594.8	1596.0	1597.3
Disch kcfs	*17.7	28.1	32.0	32.8	29.0	19.8	16.1	13.4	16.4	16.4
Ave Power MW		350	392	395	344	234	190	159	196	198
Ave Cap MW		684	677	665	653	644	641	643	648	654
Energy GWh	1792.9	252.0	291.6	293.7	247.6	174.1	137.0	118.4	145.8	132.7
Big Bend										
Reg Inflow	12301	1674	1963	2019	1728	1218	964	819	1008	909
Evap	99	3	19	24	21	15	10	5	1	0
Release	12190	1625	1967	1992	1694	1224	942	812	1024	909
Storage	*1645	1690	1667	1670	1682	1662	1673	1675	1658	1657
Elev feet	*1420.2	1421.0	1420.6	1420.7	1420.9	1420.5	1420.7	1420.8	1420.5	1420.4
Disch kcfs	*18.7	27.3	32.0	32.4	28.5	19.9	15.8	13.2	16.7	16.4
Ave Power MW		122	142	144	127	91	72	61	76	75
Ave Cap MW		479	475	474	478	486	490	494	490	490
Energy GWh	664.6	88.2	105.8	107.0	91.7	67.4	52.2	45.2	56.7	50.4
Fort Randall										
Reach Inflow	127	40	11	13	15	1	-0	6	15	26
Depletion	111	24	50	32	12	-2	-2	-2	-1	-1
Reg Inflow	12209	1647	1913	1981	1699	1228	960	807	1039	935
Evap	125	-1	13	27	34	30	14	6	1	1
Release	12511	1688	1887	1946	1824	1832	1387	705	688	555
Stor Change	-427	-39	13	7	-158	-634	-441	97	350	379
Storage	*3441	3401	3414	3422	3263	2629	2188	2285	2635	3014
Elev feet	*1355.4	1354.9	1355.1	1355.2	1353.3	1344.8	1337.4	1339.2	1344.9	1350.2
Disch kcfs	*21.1	28.4	30.7	31.7	30.6	29.8	23.3	11.5	11.2	10.0
Ave Power MW		254	274	282	272	254	185	91	92	86
Ave Cap MW		381	381	381	379	362	328	317	335	355
Energy GWh	1309.1	183.0	203.9	210.1	196.1	189.1	133.1	67.5	68.4	58.0
Gavins Point										
Reach Inflow	749	75	72	78	86	90	90	75	79	105
Depletion	156	27	66	37	3	3	9	11	1	-1
Reg Inflow	13160	1728	1883	1989	1911	1923	1526	770	769	660
Evap	30	1	6	5	6	6	4	2	0	0
Release	13129	1726	1878	1974	1880	1918	1521	769	769	694
Stor Change	1	1	-1	10	25	-1	1	-0	-0	-34
Storage	*327	328	327	337	362	361	362	362	362	328
Elev feet	*1206.0	1206.0	1206.0	1206.4	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	*25.3	29.0	30.6	32.1	31.6	31.2	25.6	12.5	12.5	12.5
Ave Power MW		107	112	117	118	117	97	49	49	49
Ave Cap MW		125	125	125	127	127	127	127	127	126
Energy GWh	595.7	77.3	83.6	87.3	85.0	87.4	69.9	36.2	36.2	32.7
Sioux City										
Reach Inflow	859	175	148	104	97	83	68	56	45	83
Depletion	259	53	129	80	11	-6	-4	-2	-1	-1
Reg Flow	13763	1846	1891	1998	1968	2007	1634	827	815	777
Reg Flow kcfs		31.0	30.8	32.5	33.1	32.6	27.5	13.4	13.2	14.0
Total										
Reach Inflow	8899	2483	1472	682	711	844	769	585	574	780
Depletion	614	660	499	25	-95	-139	-93	-94	-108	-42
Evap	1585	-54	110	308	383	334	283	198	14	10
Storage	*54950	54931	53932	52295	50811	49461	48525	48130	47972	48006
Ave Power MW		1289	1313	1322	1185	961	808	648	769	760
Ave Cap MW		2456	2446	2427	2408	2384	2345	2332	2341	2356
Energy GWh	6603.2	928.3	976.8	983.4	852.9	715.2	581.7	482.3	572.0	510.6
Daily GWh		30.9	31.5	31.7	28.4	23.1	19.4	15.6	18.5	18.2

Date of Study: 03Jun2024

01Jun2024 / Upper Basic Condition / 25.1 MAF / FTPK -0.1, GARR 1.3, OAHE -1.4
 Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)
 F-Sum: Sum of Forecasted Values. *: Previous Month's Data

	2024								2025	
	*31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
	F-Sum									
Fort Peck										
Reach Inflow	4656	1595	725	260	270	348	396	348	330	384
Depletion	-144	410	26	-172	-109	-31	-14	-89	-106	-60
Reg Inflow	4800	1185	699	432	379	379	410	437	436	444
Evap	438	1	47	85	99	73	72	50	7	4
Release	4364	904	522	492	387	307	298	460	523	471
Stor Change	-2	279	131	-145	-107	-2	40	-73	-94	-31
Storage	*14288	14567	14698	14553	14446	14444	14484	14410	14317	14286
Elev feet	*2231.6	2232.9	2233.6	2232.9	2232.4	2232.3	2232.5	2232.2	2231.7	2231.6
Disch kcfs	*11.4	15.2	8.5	8.0	6.5	5.0	5.0	7.5	8.5	8.5
Ave Power MW		178	114	107	87	67	67	100	113	113
Ave Cap MW		217	218	218	217	217	217	217	216	216
Energy GWh	688.3	128.1	84.7	79.9	62.7	50.0	48.4	74.4	84.3	75.9
Garrison										
Reach Inflow	8082	3045	1885	572	456	600	468	312	312	432
Depletion	313	804	320	-59	-106	-181	-161	-125	-110	-69
Reg Inflow	12148	3100	2152	1123	974	1088	927	876	936	973
Evap	544	-33	15	106	136	131	114	76	-2	0
Release	11968	1339	1414	1414	1309	1291	1250	1142	1476	1333
Stor Change	-364	1793	722	-398	-471	-334	-437	-343	-538	-360
Storage	*17898	19692	20414	20016	19546	19211	18775	18432	17894	17534
Elev feet	*1838.0	1843.5	1845.7	1844.5	1843.1	1842.1	1840.8	1839.7	1838.0	1836.8
Disch kcfs	*19.6	22.5	23.0	23.0	22.0	21.0	21.0	18.6	24.0	24.0
Ave Power MW		287	299	300	285	271	270	238	303	301
Ave Cap MW		577	589	590	586	583	580	577	572	566
Energy GWh	1858.5	206.8	222.6	223.0	205.5	201.8	194.2	176.9	225.5	202.1
Oahe										
Reach Inflow	960	326	182	81	106	70	64	14	13	105
Depletion	83	38	50	20	0	-10	-7	-6	-4	2
Reg Inflow	12834	1620	1546	1475	1422	1371	1320	1155	1489	1436
Evap	471	-27	14	78	115	105	95	79	8	5
Release	12065	1445	1884	1990	1703	1200	995	879	1063	906
Stor Change	297	203	-352	-593	-396	66	230	197	418	525
Storage	*17356	17558	17206	16613	16217	16283	16513	16710	17128	17653
Elev feet	*1603.1	1603.8	1602.6	1600.5	1599.1	1599.3	1600.2	1600.9	1602.3	1604.1
Disch kcfs	*17.7	24.3	30.6	32.4	28.6	19.5	16.7	14.3	17.3	16.3
Ave Power MW		305	382	398	349	239	206	178	216	206
Ave Cap MW		688	687	679	670	667	669	673	679	687
Energy GWh	1807.8	219.6	284.2	295.9	251.0	177.7	148.0	132.1	160.7	138.7
Big Bend										
Reg Inflow	12067	1446	1880	1991	1706	1201	1000	875	1063	906
Evap	99	3	19	24	21	15	10	5	1	0
Release	11956	1398	1883	1964	1672	1207	978	869	1078	907
Storage	*1645	1690	1667	1670	1682	1661	1673	1675	1659	1657
Elev feet	*1420.2	1421.0	1420.6	1420.7	1420.9	1420.5	1420.7	1420.7	1420.5	1420.4
Disch kcfs	*18.7	23.5	30.6	31.9	28.1	19.6	16.4	14.1	17.5	16.3
Ave Power MW		106	137	142	126	89	75	65	80	75
Ave Cap MW		482	476	474	478	486	490	493	489	490
Energy GWh	652.9	76.5	101.6	105.6	90.6	66.5	54.1	48.3	59.6	50.3
Fort Randall										
Reach Inflow	287	116	28	27	27	1	-0	11	28	49
Depletion	111	24	50	32	12	-2	-2	-2	-1	-1
Reg Inflow	12135	1500	1844	1966	1689	1211	995	868	1106	956
Evap	125	-1	13	27	34	30	14	5	1	1
Release	12437	1539	1819	1931	1813	1812	1426	774	747	574
Stor Change	-426	-39	12	7	-158	-631	-445	89	358	380
Storage	*3441	3402	3414	3421	3263	2632	2188	2277	2634	3015
Elev feet	*1355.4	1354.9	1355.1	1355.1	1353.3	1344.8	1337.4	1339.1	1344.9	1350.2
Disch kcfs	*21.1	25.9	29.6	31.4	30.5	29.5	24.0	12.6	12.2	10.3
Ave Power MW		233	265	281	271	252	190	99	100	90
Ave Cap MW		381	381	381	379	362	328	316	335	355
Energy GWh	1302.6	167.8	197.3	209.1	195.4	187.6	136.9	74.0	74.3	60.2
Gavins Point										
Reach Inflow	1519	217	182	162	155	162	162	135	147	196
Depletion	156	27	66	37	3	3	9	11	1	-1
Reg Inflow	13859	1728	1921	2057	1969	1974	1635	899	897	778
Evap	30	1	6	5	6	6	4	2	0	0
Release	13828	1726	1916	2041	1940	1968	1630	898	898	811
Stor Change	1	1	-1	10	24	0	0	-0	-1	-33
Storage	*327	328	328	338	362	362	362	362	361	328
Elev feet	*1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	*25.3	29.0	31.2	33.2	32.6	32.0	27.4	14.6	14.6	14.6
Ave Power MW		108	115	121	122	121	104	57	57	56
Ave Cap MW		125	125	125	127	127	127	127	127	126
Energy GWh	627.2	77.6	85.2	90.0	87.6	89.7	74.8	42.2	42.2	37.9
Sioux City										
Reach Inflow	1886	507	378	216	176	148	122	101	84	154
Depletion	259	53	129	80	11	-6	-4	-2	-1	-1
Reg Flow	15485	2178	2157	2177	2106	2123	1794	1001	983	966
Reg Flow kcfs		36.6	35.1	35.4	35.4	34.5	30.2	16.3	16.0	17.4
Total										
Reach Inflow	17389	5807	3380	1318	1190	1330	1211	921	914	1320
Depletion	778	1356	640	-62	-189	-226	-179	-213	-221	-129
Evap	1707	-55	114	326	410	361	309	218	15	10
Storage	*54950	57237	57727	56611	55516	54593	53995	53866	53993	54473
Ave Power MW		1217	1311	1349	1240	1039	912	736	869	841
Ave Cap MW		2471	2476	2467	2456	2442	2410	2403	2418	2441
Energy GWh	6937.4	876.3	975.6	1003.5	892.8	773.2	656.4	547.9	646.6	565.1
Daily GWh		29.2	31.5	32.4	29.8	24.9	21.9	17.7	20.9	20.2