

Date of Study: 01Jul2024

01Jul2024 / Basic Condition / 24.6 MAF / Balanced
Full Serv -0.5 kcfs 2nd Half / Nav End Date: Dec 01
Elevations & Storages are for Date Shown. Elevations in Local Project Datum (LPD)
Avg Discharge & Energy are Monthly Values

	2024							2025	
	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
Fort Peck									
Elev feet	2230.2	2229.2	2228.4	2228.0	2228.3	2228.6	2228.7	2228.8	2229.1
Disch kcfs	13.7	8.5	8.0	6.0	4.0	4.0	5.0	5.5	5.5
Garrison									
Elev feet	1842.2	1842.3	1840.8	1839.5	1839.0	1838.1	1836.6	1834.8	1833.5
Disch kcfs	21.6	22.0	22.0	18.8	15.5	15.5	16.9	19.5	19.5
Oahe									
Elev feet	1603.3	1605.6	1604.6	1602.6	1601.6	1601.3	1601.8	1602.5	1603.4
Disch kcfs	22.8	11.9	26.6	28.5	19.7	16.7	13.3	16.4	16.1
Big Bend									
Elev feet	1420.8	1420.6	1420.7	1420.9	1420.5	1420.7	1420.8	1420.5	1420.4
Disch kcfs	22.7	11.7	26.1	27.9	19.8	16.4	13.1	16.7	16.1
Fort Randall									
Elev feet	1360.2	1358.1	1355.2	1353.3	1344.9	1337.4	1339.1	1344.9	1350.2
Disch kcfs	19.0	14.6	30.0	30.6	29.7	24.0	11.6	11.2	9.8
Gavins Point									
Elev feet	1206.9	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	26.0	16.8	31.4	32.1	31.5	26.8	13.0	13.0	13.0
System									
Storage KAF	56557	56864	55651	54460	53398	52654	52450	52481	52772
Energy GWh	4988	583	873	818	683	569	464	529	469
Ave Cap MW		2414	2377	2356	2342	2307	2302	2308	2326

01Jul2024 / Lower Basic Condition / 22.1 MAF / FTPK -0.9, GARR 0.3, OAHE 0.3
Full Serv -0.5 kcfs 2nd Half / Nav End Date: Dec 01

	2024							2025	
	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
Fort Peck									
Elev feet	2230.2	2228.3	2226.6	2225.6	2225.3	2225.1	2224.8	2224.7	2224.6
Disch kcfs	13.7	8.5	8.0	6.0	4.0	4.0	5.0	5.0	5.0
Garrison									
Elev feet	1842.2	1841.6	1839.6	1838.1	1837.4	1836.5	1834.7	1832.6	1830.8
Disch kcfs	21.6	22.0	22.0	18.0	14.0	14.0	16.6	19.0	19.0
Oahe									
Elev feet	1603.3	1605.3	1603.5	1601.2	1599.6	1598.9	1599.3	1599.9	1600.6
Disch kcfs	22.8	12.7	29.4	29.1	20.2	17.1	13.3	16.4	16.3
Big Bend									
Elev feet	1420.8	1420.6	1420.7	1420.9	1420.5	1420.7	1420.8	1420.5	1420.4
Disch kcfs	22.7	12.5	28.8	28.6	20.4	16.8	13.1	16.7	16.3
Fort Randall									
Elev feet	1360.2	1357.0	1355.2	1353.3	1344.9	1337.4	1339.2	1344.9	1350.2
Disch kcfs	19.0	16.5	30.9	31.1	30.1	24.4	11.5	11.2	9.9
Gavins Point									
Elev feet	1206.9	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.1
Disch kcfs	26.0	16.8	31.4	32.1	31.5	26.7	12.5	12.5	12.5
System									
Storage KAF	56557	56219	54625	53145	51808	50834	50451	50306	50343
Energy GWh	4980	603	906	817	674	557	455	512	456
Ave Cap MW		2408	2363	2342	2323	2286	2278	2281	2295

01Jul2024 / Upper Basic Condition / 27.2 MAF / Balanced
Full Serv -0.5 kcfs 2nd Half / Nav End Date: Dec 01

	2024							2025	
	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
Fort Peck									
Elev feet	2230.2	2230.2	2229.6	2229.4	2229.9	2230.6	2231.0	2231.5	2232.1
Disch kcfs	13.7	8.5	8.0	6.0	4.0	4.0	5.0	5.5	5.5
Garrison									
Elev feet	1842.2	1843.5	1842.4	1841.3	1840.9	1840.1	1838.7	1837.1	1836.0
Disch kcfs	21.6	22.0	22.0	19.5	17.0	17.0	17.8	20.5	20.5
Oahe									
Elev feet	1603.3	1606.0	1605.5	1604.0	1603.5	1603.7	1604.2	1604.8	1605.9
Disch kcfs	22.8	11.0	24.1	27.6	19.0	16.3	14.4	17.4	16.8
Big Bend									
Elev feet	1420.8	1420.5	1420.7	1420.9	1420.5	1420.7	1420.7	1420.5	1420.4
Disch kcfs	22.7	10.9	23.5	27.1	19.1	16.0	14.2	17.7	16.8
Fort Randall									
Elev feet	1360.2	1359.1	1355.1	1353.3	1344.9	1337.4	1339.1	1344.9	1350.2
Disch kcfs	19.0	12.9	29.1	29.9	29.0	23.6	12.8	12.3	10.7
Gavins Point									
Elev feet	1206.9	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.4	1206.0
Disch kcfs	26.0	16.8	31.4	32.1	31.5	27.0	14.8	14.8	14.8
System									
Storage KAF	56557	57631	56692	55711	54891	54366	54260	54382	54838
Energy GWh	5062	564	844	816	690	582	502	566	498
Ave Cap MW		2420	2391	2370	2359	2328	2321	2330	2350

Date of Study: 01Jul2024

01Jul2024 / Basic Condition / 24.6 MAF / Balanced

Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)

F-Sum: Sum of Forecasted Values. *: Previous Month's Data

	2024							2025	
	*30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
	F-Sum								
Fort Peck									
Reach Inflow	2445	400	220	250	330	350	300	275	320
Depletion	-555	36	-188	-125	-42	-7	-74	-102	-53
Reg Inflow	3000	364	408	375	372	357	374	377	373
Evap	415	45	81	93	70	69	48	6	3
Release	2806	522	492	357	246	238	307	338	305
Stor Change	-221	-202	-165	-75	57	51	18	32	64
Storage	*14013	13811	13646	13570	13627	13678	13696	13728	13792
Elev feet	*2230.2	2229.2	2228.4	2228.0	2228.3	2228.6	2228.7	2228.8	2229.1
Disch kcfs	*13.7	8.5	8.0	6.0	4.0	4.0	5.0	5.5	5.5
Ave Power MW		114	107	80	54	54	67	74	74
Ave Cap MW		214	212	211	212	212	212	212	213
Energy GWh	454.7	84.6	79.5	57.6	39.9	38.7	49.9	54.9	49.6
Garrison									
Reach Inflow	3600	1050	420	360	500	390	260	260	360
Depletion	-380	237	-52	-79	-153	-133	-87	-70	-44
Reg Inflow	6880	1408	964	829	899	761	646	664	709
Evap	550	15	102	129	125	109	73	-2	0
Release	9017	1353	1353	1116	953	922	1040	1199	1082
Stor Change	-2687	40	-490	-416	-179	-271	-467	-533	-373
Storage	*19245	19285	18795	18380	18201	17930	17463	16931	16557
Elev feet	*1842.2	1842.3	1840.8	1839.5	1839.0	1838.1	1836.6	1834.8	1833.5
Disch kcfs	*21.6	22.0	22.0	18.8	15.5	15.5	16.9	19.5	19.5
Ave Power MW		287	286	242	200	200	216	246	244
Ave Cap MW		582	580	576	573	571	566	559	552
Energy GWh	1400.8	213.3	212.4	174.5	149.0	143.7	160.8	183.2	163.9
Oahe									
Reach Inflow	539	130	70	100	70	70	15	9	75
Depletion	45	50	20	0	-10	-7	-6	-4	2
Reg Inflow	9520	1432	1403	1238	1033	999	1047	1212	1156
Evap	517	15	82	121	109	97	80	8	5
Release	8985	729	1636	1695	1211	993	815	1011	896
Stor Change	18	689	-315	-577	-287	-91	151	193	256
Storage	*17405	18094	17778	17201	16914	16823	16974	17168	17423
Elev feet	*1603.3	1605.6	1604.6	1602.6	1601.6	1601.3	1601.8	1602.5	1603.4
Disch kcfs	*22.8	11.9	26.6	28.5	19.7	16.7	13.3	16.4	16.1
Ave Power MW		140	310	328	226	191	153	190	187
Ave Cap MW		694	699	690	681	677	679	682	686
Energy GWh	1257.8	104.1	230.8	236.4	168.3	137.5	113.7	141.1	125.9
Big Bend									
Reg Inflow	8980	726	1630	1698	1212	998	812	1010	895
Evap	96	19	24	21	15	10	5	1	0
Release	8907	719	1604	1663	1218	976	805	1026	896
Storage	*1680	1667	1669	1683	1661	1674	1675	1658	1657
Elev feet	*1420.8	1420.6	1420.7	1420.9	1420.5	1420.7	1420.8	1420.5	1420.4
Disch kcfs	*22.7	11.7	26.1	27.9	19.8	16.4	13.1	16.7	16.1
Ave Power MW		43	91	97	71	59	48	60	58
Ave Cap MW		403	378	374	386	393	401	392	394
Energy GWh	384.6	31.9	67.4	70.2	52.7	42.6	35.6	44.9	39.3
Fort Randall									
Reach Inflow	231	70	50	40	2	-0	15	20	35
Depletion	87	50	32	12	-2	-2	-2	-1	-1
Reg Inflow	9034	725	1615	1693	1222	994	810	1046	930
Evap	127	14	28	34	30	14	5	1	1
Release	9759	899	1842	1820	1824	1426	711	691	546
Stor Change	-852	-188	-255	-161	-631	-446	93	354	382
Storage	*3868	3680	3425	3264	2633	2187	2280	2634	3016
Elev feet	*1360.2	1358.1	1355.2	1353.3	1344.9	1337.4	1339.1	1344.9	1350.2
Disch kcfs	*19.0	14.6	30.0	30.6	29.7	24.0	11.6	11.2	9.8
Ave Power MW		137	267	270	251	187	90	91	84
Ave Cap MW		396	382	379	362	328	316	335	355
Energy GWh	1007.2	101.7	198.7	194.3	186.5	134.6	66.9	67.9	56.6
Gavins Point									
Reach Inflow	1115	250	160	120	120	120	100	105	140
Depletion	129	66	37	3	3	9	11	1	-1
Reg Inflow	10733	1019	1948	1939	1943	1596	801	799	688
Evap	29	6	5	6	6	4	2	0	0
Release	10726	1035	1932	1910	1937	1592	799	799	722
Stor Change	-22	-22	11	23	0	0	-0	-0	-34
Storage	*349	327	338	362	362	362	362	362	327
Elev feet	*1206.9	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	*26.0	16.8	31.4	32.1	31.5	26.8	13.0	13.0	13.0
Ave Power MW		63	114	118	117	100	50	50	50
Ave Cap MW		125	125	127	127	127	127	127	126
Energy GWh	482.9	47.1	84.6	85.0	86.9	71.9	37.0	37.0	33.4
Sioux City									
Reach Inflow	1910	1000	340	130	110	90	70	60	110
Depletion	206	129	80	11	-6	-4	-2	-1	-1
Reg Flow	12430	1876	2178	2031	2054	1727	871	860	833
Reg Flow kcfs		30.5	35.4	34.1	33.4	29.0	14.2	14.0	15.0
Total									
Reach Inflow	9840	2900	1260	1000	1132	1020	760	729	1040
Depletion	-468	568	-71	-178	-210	-144	-159	-178	-96
Evap	1734	112	322	404	355	303	213	15	10
Storage	*56557	56864	55651	54460	53398	52654	52450	52481	52772
Ave Power MW		783	1174	1136	919	790	624	711	697
Ave Cap MW		2414	2377	2356	2342	2307	2302	2308	2326
Energy GWh	4988.0	582.6	873.3	818.0	683.4	569.0	464.0	529.0	468.7
Daily GWh		18.8	28.2	27.3	22.0	19.0	15.0	17.1	16.7

Date of Study: 01Jul2024

01Jul2024 / Lower Basic Condition / 22.1 MAF / FTPK -0.9, GARR 0.3, OAHE 0.3
Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)
F-Sum: Sum of Forecasted Values. *: Previous Month's Data

	2024							2025	
	*30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
	F-Sum								
Fort Peck									
Reach Inflow	1846	260	154	188	264	280	240	220	240
Depletion	-216	85	-95	-61	2	10	-49	-75	-32
Reg Inflow	2062	175	249	249	262	270	289	295	272
Evap	404	44	79	91	67	66	46	6	3
Release	2747	522	492	357	246	238	307	307	278
Stor Change	-1089	-391	-322	-199	-52	-34	-64	-19	-9
Storage	*14013	13622	13300	13101	13050	13016	12952	12933	12924
Elev feet	*2230.2	2228.3	2226.6	2225.6	2225.3	2225.1	2224.8	2224.7	2224.6
Disch kcfs	*13.7	8.5	8.0	6.0	4.0	4.0	5.0	5.0	5.0
Ave Power MW		113	106	79	53	53	66	66	66
Ave Cap MW		213	211	209	208	208	207	207	207
Energy GWh	439.8	84.4	78.9	57.0	39.4	38.1	49.0	48.9	44.2
Garrison									
Reach Inflow	2645	683	294	270	400	312	208	208	270
Depletion	-297	120	-48	-59	-126	-100	-45	-28	-10
Reg Inflow	5787	1158	834	720	772	650	552	543	558
Evap	539	15	100	126	122	107	71	-2	0
Release	8715	1353	1353	1071	861	833	1021	1168	1055
Stor Change	-3468	-210	-619	-478	-210	-290	-540	-623	-498
Storage	*19245	19035	18417	17939	17729	17439	16898	16275	15777
Elev feet	*1842.2	1841.6	1839.6	1838.1	1837.4	1836.5	1834.7	1832.6	1830.8
Disch kcfs	*21.6	22.0	22.0	18.0	14.0	14.0	16.6	19.0	19.0
Ave Power MW		286	284	231	180	179	210	237	235
Ave Cap MW		581	578	572	568	565	559	550	541
Energy GWh	1344.6	212.9	211.4	166.6	133.9	129.1	156.5	176.6	157.7
Oahe									
Reach Inflow	371	72	46	75	52	53	11	7	56
Depletion	45	50	20	0	-10	-7	-6	-4	2
Reg Inflow	9051	1374	1378	1174	923	892	1021	1179	1109
Evap	506	15	81	119	107	94	78	8	4
Release	9309	780	1806	1733	1245	1015	816	1009	907
Stor Change	-764	580	-509	-677	-429	-216	127	163	197
Storage	*17405	17985	17476	16799	16370	16154	16281	16444	16641
Elev feet	*1603.3	1605.3	1603.5	1601.2	1599.6	1598.9	1599.3	1599.9	1600.6
Disch kcfs	*22.8	12.7	29.4	29.1	20.2	17.1	13.3	16.4	16.3
Ave Power MW		149	340	332	230	192	150	186	186
Ave Cap MW		693	695	684	673	666	666	669	673
Energy GWh	1287.3	111.1	252.8	239.4	170.8	138.2	111.8	138.2	125.0
Big Bend									
Reg Inflow	9304	776	1800	1736	1246	1020	812	1008	906
Evap	96	19	24	21	15	10	5	1	0
Release	9231	769	1773	1702	1252	999	805	1024	907
Storage	*1680	1668	1670	1682	1661	1673	1675	1658	1657
Elev feet	*1420.8	1420.6	1420.7	1420.9	1420.5	1420.7	1420.8	1420.5	1420.4
Disch kcfs	*22.7	12.5	28.8	28.6	20.4	16.8	13.1	16.7	16.3
Ave Power MW		46	100	100	73	60	48	60	59
Ave Cap MW		402	373	373	385	392	401	392	394
Energy GWh	397.6	34.0	74.2	71.7	54.1	43.6	35.6	44.9	39.8
Fort Randall									
Reach Inflow	155	38	33	30	1	-0	11	15	26
Depletion	87	50	32	12	-2	-2	-2	-1	-1
Reg Inflow	9281	742	1767	1722	1256	1018	805	1039	932
Evap	126	14	28	34	30	14	6	1	1
Release	10008	1015	1897	1850	1852	1451	706	686	551
Stor Change	-853	-287	-157	-162	-626	-447	94	352	380
Storage	*3868	3581	3424	3262	2636	2189	2283	2635	3015
Elev feet	*1360.2	1357.0	1355.2	1353.3	1344.9	1337.4	1339.2	1344.9	1350.2
Disch kcfs	*19.0	16.5	30.9	31.1	30.1	24.4	11.5	11.2	9.9
Ave Power MW		153	274	274	254	190	89	91	85
Ave Cap MW		394	382	379	362	328	317	335	355
Energy GWh	1032.5	114.0	204.0	197.4	189.3	136.8	66.5	67.4	57.1
Gavins Point									
Reach Inflow	770	138	104	90	90	90	75	79	105
Depletion	129	66	37	3	3	9	11	1	-1
Reg Inflow	10642	1020	1947	1940	1943	1593	770	768	662
Evap	29	6	5	6	6	4	2	0	0
Release	10633	1035	1932	1910	1937	1588	769	769	694
Stor Change	-20	-21	10	24	-0	1	-0	-1	-33
Storage	*349	328	338	362	362	363	362	361	329
Elev feet	*1206.9	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.1
Disch kcfs	*26.0	16.8	31.4	32.1	31.5	26.7	12.5	12.5	12.5
Ave Power MW		63	114	118	117	100	48	48	48
Ave Cap MW		125	125	127	127	127	127	127	126
Energy GWh	478.6	47.1	84.6	85.0	86.9	71.7	35.6	35.6	32.1
Sioux City									
Reach Inflow	1199	550	221	97	83	68	52	45	83
Depletion	206	129	80	11	-6	-4	-2	-1	-1
Reg Flow	11627	1426	2059	1998	2026	1702	823	815	777
Reg Flow kcfs		23.2	33.5	33.6	33.0	28.6	13.4	13.2	14.0
Total									
Reach Inflow	6985	1740	851	750	890	802	598	574	780
Depletion	-46	499	25	-95	-139	-93	-94	-108	-42
Evap	1699	112	318	397	347	294	207	14	10
Storage	*56557	56219	54625	53145	51808	50834	50451	50306	50343
Ave Power MW		811	1218	1135	906	774	611	688	678
Ave Cap MW		2408	2363	2342	2323	2286	2278	2281	2295
Energy GWh	4980.3	603.4	905.9	816.9	674.3	557.4	454.9	511.6	455.8
Daily GWh		19.5	29.2	27.2	21.8	18.6	14.7	16.5	16.3

Date of Study: 01Jul2024

01Jul2024 / Upper Basic Condition / 27.2 MAF / Balanced
Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)
F-Sum: Sum of Forecasted Values. *: Previous Month's Data

	2024							2025	
	*30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
	F-Sum								
Fort Peck									
Reach Inflow	3056	580	286	300	396	420	360	330	384
Depletion	-554	26	-172	-109	-31	-14	-89	-106	-60
Reg Inflow	3610	554	458	408	427	434	449	436	444
Evap	423	45	82	95	71	70	50	7	4
Release	2806	522	492	357	246	238	307	338	305
Stor Change	381	-12	-116	-44	110	126	92	91	135
Storage	*14013	14001	13885	13841	13951	14076	14169	14260	14394
Elev feet	*2230.2	2230.2	2229.6	2229.4	2229.9	2230.6	2231.0	2231.5	2232.1
Disch kcfs	*13.7	8.5	8.0	6.0	4.0	4.0	5.0	5.5	5.5
Ave Power MW		114	108	81	54	54	68	75	75
Ave Cap MW		214	214	213	214	214	215	215	216
Energy GWh	459.2	85.0	80.1	58.1	40.3	39.1	50.5	55.7	50.4
Garrison									
Reach Inflow	4624	1522	546	432	600	468	312	312	432
Depletion	-491	320	-59	-106	-181	-161	-125	-110	-69
Reg Inflow	8015	1798	1097	929	1026	867	736	756	807
Evap	565	15	103	132	128	113	75	-2	0
Release	9419	1353	1353	1160	1045	1012	1097	1260	1139
Stor Change	-1968	430	-359	-364	-147	-257	-436	-503	-332
Storage	*19245	19675	19316	18952	18805	18548	18112	17609	17277
Elev feet	*1842.2	1843.5	1842.4	1841.3	1840.9	1840.1	1838.7	1837.1	1836.0
Disch kcfs	*21.6	22.0	22.0	19.5	17.0	17.0	17.8	20.5	20.5
Ave Power MW		288	288	255	222	221	231	262	260
Ave Cap MW		584	584	581	579	577	574	568	563
Energy GWh	1477.8	214.3	214.3	183.3	165.0	159.2	171.6	195.1	174.9
Oahe									
Reach Inflow	738	182	94	135	94	94	20	13	105
Depletion	45	50	20	0	-10	-7	-6	-4	2
Reg Inflow	10116	1484	1427	1313	1150	1113	1111	1277	1241
Evap	528	15	83	123	112	100	83	8	5
Release	8825	676	1481	1641	1170	971	886	1070	930
Stor Change	763	793	-136	-451	-133	42	142	199	306
Storage	*17405	18198	18062	17611	17478	17520	17663	17861	18168
Elev feet	*1603.3	1606.0	1605.5	1604.0	1603.5	1603.7	1604.2	1604.8	1605.9
Disch kcfs	*22.8	11.0	24.1	27.6	19.0	16.3	14.4	17.4	16.8
Ave Power MW		130	283	321	222	190	169	204	198
Ave Cap MW		694	702	695	690	688	690	694	698
Energy GWh	1250.1	96.7	210.5	231.1	164.9	136.8	125.5	151.8	132.9
Big Bend									
Reg Inflow	8820	674	1474	1644	1171	976	882	1070	929
Evap	96	19	24	21	15	10	5	1	0
Release	8747	671	1443	1611	1176	954	876	1086	930
Storage	*1680	1663	1670	1682	1662	1673	1675	1658	1657
Elev feet	*1420.8	1420.5	1420.7	1420.9	1420.5	1420.7	1420.7	1420.5	1420.4
Disch kcfs	*22.7	10.9	23.5	27.1	19.1	16.0	14.2	17.7	16.8
Ave Power MW		40	82	95	69	58	52	64	61
Ave Cap MW		405	382	375	388	394	399	390	393
Energy GWh	378.5	30.0	61.0	68.1	51.0	41.8	38.6	47.4	40.7
Fort Randall									
Reach Inflow	319	98	67	54	2	-1	20	28	49
Depletion	87	50	32	12	-2	-2	-2	-1	-1
Reg Inflow	8961	708	1471	1654	1181	971	885	1114	978
Evap	127	14	28	34	30	14	5	1	1
Release	9687	796	1788	1777	1781	1405	786	758	594
Stor Change	-853	-102	-345	-157	-630	-448	93	354	382
Storage	*3868	3766	3421	3264	2634	2186	2279	2633	3015
Elev feet	*1360.2	1359.1	1355.1	1353.3	1344.9	1337.4	1339.1	1344.9	1350.2
Disch kcfs	*19.0	12.9	29.1	29.9	29.0	23.6	12.8	12.3	10.7
Ave Power MW		122	260	264	245	184	99	100	92
Ave Cap MW		397	384	379	362	328	316	335	355
Energy GWh	998.8	90.6	193.5	189.9	182.3	132.8	73.8	74.4	61.5
Gavins Point									
Reach Inflow	1530	350	216	162	162	162	135	147	196
Depletion	129	66	37	3	3	9	11	1	-1
Reg Inflow	11068	1020	1947	1939	1943	1611	911	909	788
Evap	29	6	5	6	6	4	2	0	0
Release	11062	1035	1932	1910	1937	1606	910	910	822
Stor Change	-22	-21	10	23	0	1	-0	-2	-34
Storage	*349	328	338	361	361	363	362	361	327
Elev feet	*1206.9	1206.0	1206.5	1207.5	1207.5	1207.5	1207.5	1207.4	1206.0
Disch kcfs	*26.0	16.8	31.4	32.1	31.5	27.0	14.8	14.8	14.8
Ave Power MW		63	114	118	117	101	56	56	56
Ave Cap MW		125	125	127	127	127	127	127	126
Energy GWh	497.9	47.1	84.6	85.0	86.9	72.5	42.0	42.0	37.7
Sioux City									
Reach Inflow	2637	1400	459	176	148	122	94	84	154
Depletion	206	129	80	11	-6	-4	-2	-1	-1
Reg Flow	13489	2276	2297	2076	2092	1769	1006	995	977
Reg Flow kcfs		37.0	37.4	34.9	34.0	29.7	16.4	16.2	17.6
Total									
Reach Inflow	12904	4132	1669	1258	1403	1265	942	914	1320
Depletion	-578	640	-62	-189	-226	-179	-213	-221	-129
Evap	1767	113	326	411	362	310	220	15	10
Storage	*56557	57631	56692	55711	54891	54366	54260	54382	54838
Ave Power MW		758	1134	1133	928	809	675	761	741
Ave Cap MW		2420	2391	2370	2359	2328	2321	2330	2350
Energy GWh	5062.3	563.7	844.0	815.5	690.4	582.2	502.0	566.3	498.2
Daily GWh		18.2	27.2	27.2	22.3	19.4	16.2	18.3	17.8