

Date of Study: 02Aug2024

01Aug2024 / Basic Condition / 23.9 MAF / FTPK -0.9, GARR 0.3, OAHE 0.3
 Full Serv -0.5 kcfs 2nd Half / Nav End Date: Dec 01
 Elevations & Storages are for Date Shown. Elevations in Local Project Datum (LPD)
 Avg Discharge & Energy are Monthly Values

	2024							2025	
	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb	
Fort Peck									
Elev feet	2229.0	2227.3	2226.4	2226.4	2226.4	2226.5	2226.8	2227.3	
Disch kcfs	9.0	9.0	6.6	4.0	4.0	5.0	5.5	5.5	
Garrison									
Elev feet	1842.1	1840.3	1839.0	1838.6	1837.9	1836.2	1834.4	1833.0	
Disch kcfs	22.0	22.0	18.4	14.0	14.0	17.8	19.5	19.5	
Oahe									
Elev feet	1605.4	1604.2	1602.1	1600.8	1600.1	1600.9	1601.7	1602.9	
Disch kcfs	11.9	27.4	28.5	19.6	16.6	12.8	15.7	15.0	
Big Bend									
Elev feet	1420.7	1420.6	1420.9	1420.5	1420.7	1420.8	1420.5	1420.4	
Disch kcfs	12.1	27.0	27.9	19.7	16.4	12.6	16.0	15.0	
Fort Randall									
Elev feet	1355.9	1355.2	1353.3	1344.9	1337.4	1339.1	1344.9	1350.2	
Disch kcfs	18.2	27.8	30.5	29.6	23.9	11.1	10.8	9.2	
Gavins Point									
Elev feet	1206.3	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0	
Disch kcfs	20.2	29.0	32.1	31.5	26.8	12.5	12.5	12.5	
System									
Storage KAF	56495	55142	53831	52667	51850	51659	51748	52134	
Energy GWh	4513	907	853	692	575	478	537	470	
Ave Cap MW		2464	2446	2426	2388	2379	2389	2408	

01Aug2024 / Lower Basic Condition / 22.8 MAF / FTPK -1.2, GARR 0.5, OAHE 0.4
 Full Serv -0.5 kcfs 2nd Half / Nav End Date: Dec 01

	2024							2025	
	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb	
Fort Peck									
Elev feet	2229.0	2226.7	2225.2	2224.6	2224.2	2223.9	2223.9	2224.0	
Disch kcfs	9.0	9.0	6.6	4.0	4.0	5.0	5.0	5.0	
Garrison									
Elev feet	1842.1	1840.0	1838.5	1837.7	1836.7	1834.9	1832.6	1830.8	
Disch kcfs	22.0	22.0	18.0	14.0	14.0	16.5	19.5	19.5	
Oahe									
Elev feet	1605.4	1603.8	1601.2	1599.4	1598.4	1598.8	1599.5	1600.4	
Disch kcfs	11.9	28.9	30.1	21.4	18.2	13.4	16.3	16.1	
Big Bend									
Elev feet	1420.7	1420.7	1420.9	1420.5	1420.7	1420.7	1420.5	1420.4	
Disch kcfs	12.1	28.4	29.6	21.5	17.9	13.2	16.5	16.1	
Fort Randall									
Elev feet	1355.9	1355.1	1353.3	1344.9	1337.4	1339.2	1344.9	1350.2	
Disch kcfs	18.2	29.0	32.0	31.2	25.6	11.5	11.2	10.0	
Gavins Point									
Elev feet	1206.3	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0	
Disch kcfs	20.2	29.3	33.0	32.6	28.0	12.5	12.5	12.5	
System									
Storage KAF	56495	54823	53191	51696	50588	50198	50069	50148	
Energy GWh	4621	932	878	724	602	472	537	477	
Ave Cap MW		2461	2439	2414	2371	2360	2367	2382	

01Aug2024 / Upper Basic Condition / 25.1 MAF / FTPK -1.3, GARR 0.4, OAHE 0.5
 Full Serv -0.5 kcfs 2nd Half / Nav End Date: Dec 01

	2024							2025	
	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb	
Fort Peck									
Elev feet	2229.0	2227.4	2226.6	2226.8	2227.2	2227.7	2228.3	2229.1	
Disch kcfs	9.0	9.0	6.6	4.0	4.0	5.0	5.5	5.5	
Garrison									
Elev feet	1842.1	1840.6	1839.5	1839.2	1838.7	1837.4	1835.9	1835.0	
Disch kcfs	22.0	22.0	18.7	15.0	15.0	17.2	19.5	19.5	
Oahe									
Elev feet	1605.4	1604.5	1602.7	1601.9	1601.7	1602.5	1603.5	1605.0	
Disch kcfs	11.9	26.2	27.6	18.9	15.8	12.1	14.9	13.8	
Big Bend									
Elev feet	1420.7	1420.7	1420.9	1420.5	1420.7	1420.7	1420.5	1420.4	
Disch kcfs	12.1	25.8	27.1	19.0	15.6	11.9	15.1	13.8	
Fort Randall									
Elev feet	1355.9	1355.1	1353.3	1344.9	1337.4	1339.1	1344.9	1350.2	
Disch kcfs	18.2	27.0	29.9	28.9	23.2	10.5	10.1	8.4	
Gavins Point									
Elev feet	1206.3	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0	
Disch kcfs	20.2	29.0	32.1	31.5	26.7	12.5	12.5	12.5	
System									
Storage KAF	56495	55337	54214	53276	52691	52707	53007	53672	
Energy GWh	4439	888	843	690	572	464	526	455	
Ave Cap MW		2467	2451	2433	2399	2393	2407	2430	

Date of Study: 02Aug2024

01Aug2024 / Basic Condition / 23.9 MAF / FTPK -0.9, GARR 0.3, OAHE 0.3
Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)
F-Sum: Sum of Forecasted Values. *: Previous Month's Data

	2024						2025	
	*31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
	F-Sum							
Fort Peck								
Reach Inflow	1820	120	180	270	300	300	300	350
Depletion	-591	-188	-125	-42	-7	-74	-102	-53
Reg Inflow	2411	308	305	312	307	374	402	403
Evap	363	80	92	68	67	47	6	3
Release	2379	553	391	246	238	307	338	305
Stor Change	-332	-326	-178	-2	2	19	58	94
Storage	*13761	13435	13258	13256	13258	13278	13335	13429
Elev feet	*2229.0	2227.3	2226.4	2226.4	2226.4	2226.5	2226.8	2227.3
Disch kcfs	*9.0	9.0	6.6	4.0	4.0	5.0	5.5	5.5
Ave Power MW		117	85	52	52	65	71	71
Ave Cap MW		212	210	209	209	209	210	210
Energy GWh	373.5	87.0	61.1	38.7	37.4	48.2	53.0	48.0
Garrison								
Reach Inflow	2240	270	300	450	370	250	250	350
Depletion	-618	-52	-79	-153	-133	-87	-70	-44
Reg Inflow	5267	876	811	849	741	636	654	699
Evap	532	101	128	124	109	73	-2	0
Release	7518	1353	1095	861	833	1095	1199	1083
Stor Change	-2784	-577	-412	-136	-201	-532	-543	-384
Storage	*19198	18621	18209	18074	17873	17342	16799	16415
Elev feet	*1842.1	1840.3	1839.0	1838.6	1837.9	1836.2	1834.4	1833.0
Disch kcfs	*22.0	22.0	18.4	14.0	14.0	17.8	19.5	19.5
Ave Power MW		285	237	181	180	227	246	244
Ave Cap MW		579	574	572	570	565	557	550
Energy GWh	1163.1	212.1	170.9	134.6	129.9	168.9	182.8	163.7
Oahe								
Reach Inflow	381	50	90	70	60	10	11	90
Depletion	-5	20	0	-10	-7	-6	-4	2
Reg Inflow	7913	1384	1213	941	900	1091	1214	1171
Evap	498	81	120	109	96	79	8	5
Release	8165	1685	1695	1207	991	784	968	835
Stor Change	-749	-383	-602	-375	-187	228	238	331
Storage	*18041	17658	17056	16681	16495	16722	16961	17292
Elev feet	*1605.4	1604.2	1602.1	1600.8	1600.1	1600.9	1601.7	1602.9
Disch kcfs	*11.9	27.4	28.5	19.6	16.6	12.8	15.7	15.0
Ave Power MW		347	357	245	206	159	197	190
Ave Cap MW		696	687	678	672	673	678	683
Energy GWh	1238.7	258.5	256.9	182.1	148.5	118.4	146.6	127.5
Big Bend								
Reg Inflow	8166	1680	1698	1208	996	781	968	834
Evap	77	24	21	15	10	5	1	0
Release	8104	1660	1663	1214	975	774	984	835
Storage	*1673	1669	1682	1661	1673	1675	1659	1658
Elev feet	*1420.7	1420.6	1420.9	1420.5	1420.7	1420.8	1420.5	1420.4
Disch kcfs	*12.1	27.0	27.9	19.7	16.4	12.6	16.0	15.0
Ave Power MW		118	122	88	73	57	72	68
Ave Cap MW		470	469	478	482	487	482	484
Energy GWh	434.7	87.7	87.9	65.3	52.7	42.2	53.4	45.4
Fort Randall								
Reach Inflow	202	50	40	2	0	15	35	60
Depletion	37	32	12	-2	-2	-2	-1	-1
Reg Inflow	8270	1675	1693	1218	994	778	1019	894
Evap	113	28	34	30	14	6	1	1
Release	8631	1712	1816	1820	1424	681	664	514
Stor Change	-473	-65	-157	-631	-444	91	353	379
Storage	*3486	3421	3264	2633	2189	2280	2633	3012
Elev feet	*1355.9	1355.2	1353.3	1344.9	1337.4	1339.1	1344.9	1350.2
Disch kcfs	*18.2	27.8	30.5	29.6	23.9	11.1	10.8	9.2
Ave Power MW		241	261	244	183	85	86	77
Ave Cap MW		382	379	362	328	317	335	355
Energy GWh	859.2	179.3	188.3	181.3	131.6	63.0	63.8	51.9
Gavins Point								
Reach Inflow	845	140	120	125	120	100	100	140
Depletion	63	37	3	3	9	11	1	-1
Reg Inflow	9471	1794	1938	1943	1597	770	768	661
Evap	23	5	6	6	4	2	0	0
Release	9455	1786	1908	1937	1593	769	769	694
Stor Change	-7	3	24	0	0	-0	-1	-33
Storage	*335	338	362	362	362	362	361	328
Elev feet	*1206.3	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	*20.2	29.0	32.1	31.5	26.8	12.5	12.5	12.5
Ave Power MW		111	123	122	104	50	50	50
Ave Cap MW		126	127	127	127	127	127	126
Energy GWh	443.4	82.2	88.3	90.4	74.8	37.1	37.1	33.5
Sioux City								
Reach Inflow	955	350	150	110	95	75	65	110
Depletion	77	80	11	-6	-4	-2	-1	-1
Reg Flow	10363	2042	2049	2054	1734	846	835	805
Reg Flow kcfs		33.2	34.4	33.4	29.1	13.8	13.6	14.5
Total								
Reach Inflow	6443	980	880	1027	945	750	761	1100
Depletion	-1036	-71	-178	-210	-144	-159	-178	-96
Evap	1606	320	400	351	299	211	15	10
Storage	*56495	55142	53831	52667	51850	51659	51748	52134
Ave Power MW		1219	1185	931	799	642	721	699
Ave Cap MW		2464	2446	2426	2388	2379	2389	2408
Energy GWh	4512.6	906.9	853.5	692.4	575.1	477.9	536.8	470.0
Daily GWh		29.3	28.4	22.3	19.2	15.4	17.3	16.8

Date of Study: 02Aug2024

01Aug2024 / Lower Basic Condition / 22.8 MAF / FTPK -1.2, GARR 0.5, OAHE 0.4
Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)
F-Sum: Sum of Forecasted Values. *: Previous Month's Data

	2024						2025	
	*31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
	F-Sum							
Fort Peck								
Reach Inflow	1418	84	135	216	240	240	240	262
Depletion	-301	-95	-61	2	10	-49	-75	-32
Reg Inflow	1719	179	196	214	230	289	315	295
Evap	358	80	91	67	65	46	6	3
Release	2321	553	391	246	238	307	307	278
Stor Change	-960	-454	-285	-99	-73	-64	1	14
Storage	*13761	13307	13022	12923	12849	12786	12787	12801
Elev feet	*2229.0	2226.7	2225.2	2224.6	2224.2	2223.9	2223.9	2224.0
Disch kcfs	*9.0	9.0	6.6	4.0	4.0	5.0	5.0	5.0
Ave Power MW		117	85	52	52	64	64	64
Ave Cap MW		211	208	207	207	206	206	206
Energy GWh	362.0	87.0	61.0	38.4	37.1	47.7	47.7	43.1
Garrison								
Reach Inflow	1733	189	225	360	296	200	200	262
Depletion	-417	-48	-59	-126	-100	-45	-28	-10
Reg Inflow	4504	791	717	732	634	544	535	550
Evap	527	101	127	122	107	71	-2	0
Release	7410	1353	1071	861	833	1014	1196	1083
Stor Change	-3433	-662	-481	-251	-307	-540	-659	-533
Storage	*19198	18536	18055	17804	17498	16957	16298	15765
Elev feet	*1842.1	1840.0	1838.5	1837.7	1836.7	1834.9	1832.6	1830.8
Disch kcfs	*22.0	22.0	18.0	14.0	14.0	16.5	19.5	19.5
Ave Power MW		286	232	181	180	210	244	241
Ave Cap MW		579	573	569	566	560	551	542
Energy GWh	1143.3	212.5	167.3	134.5	129.6	155.9	181.3	162.2
Oahe								
Reach Inflow	281	33	68	52	45	8	8	67
Depletion	-5	20	0	-10	-7	-6	-4	2
Reg Inflow	7705	1366	1167	923	885	1011	1205	1148
Evap	490	81	119	107	93	77	8	4
Release	8677	1774	1791	1313	1082	821	1002	894
Stor Change	-1462	-489	-744	-497	-291	113	196	250
Storage	*18041	17552	16808	16311	16021	16133	16329	16579
Elev feet	*1605.4	1603.8	1601.2	1599.4	1598.4	1598.8	1599.5	1600.4
Disch kcfs	*11.9	28.9	30.1	21.4	18.2	13.4	16.3	16.1
Ave Power MW		365	375	264	222	164	201	199
Ave Cap MW		696	684	672	664	664	667	671
Energy GWh	1303.0	271.5	269.9	196.2	160.0	122.2	149.3	134.0
Big Bend								
Reg Inflow	8677	1769	1794	1314	1089	818	1001	893
Evap	77	24	21	15	10	5	1	0
Release	8616	1748	1759	1320	1066	811	1018	894
Storage	*1673	1670	1683	1661	1674	1675	1658	1657
Elev feet	*1420.7	1420.7	1420.9	1420.5	1420.7	1420.7	1420.5	1420.4
Disch kcfs	*12.1	28.4	29.6	21.5	17.9	13.2	16.5	16.1
Ave Power MW		124	129	95	80	59	74	72
Ave Cap MW		469	468	476	480	487	482	483
Energy GWh	460.7	92.0	92.7	70.7	57.4	44.2	55.2	48.5
Fort Randall								
Reach Inflow	146	33	30	1	0	11	26	45
Depletion	37	32	12	-2	-2	-2	-1	-1
Reg Inflow	8725	1745	1778	1324	1087	812	1043	937
Evap	113	28	34	30	14	5	1	1
Release	9080	1783	1903	1920	1523	705	690	554
Stor Change	-468	-66	-159	-626	-450	101	351	382
Storage	*3486	3420	3261	2635	2184	2285	2636	3018
Elev feet	*1355.9	1355.1	1353.3	1344.9	1337.4	1339.2	1344.9	1350.2
Disch kcfs	*18.2	29.0	32.0	31.2	25.6	11.5	11.2	10.0
Ave Power MW		250	273	256	195	87	89	83
Ave Cap MW		381	379	362	328	317	335	355
Energy GWh	899.8	186.0	196.5	190.4	140.1	65.0	66.1	55.8
Gavins Point								
Reach Inflow	620	91	90	94	90	75	75	105
Depletion	63	37	3	3	9	11	1	-1
Reg Inflow	9687	1813	1994	2010	1672	770	768	661
Evap	23	5	6	6	4	2	0	0
Release	9671	1804	1964	2004	1668	769	769	694
Stor Change	-8	3	24	-0	0	-0	-1	-34
Storage	*335	338	362	362	362	362	361	328
Elev feet	*1206.3	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	*20.2	29.3	33.0	32.6	28.0	12.5	12.5	12.5
Ave Power MW		111	126	125	108	50	50	50
Ave Cap MW		126	127	127	127	127	127	126
Energy GWh	452.5	82.9	90.6	93.3	78.0	37.1	37.1	33.5
Sioux City								
Reach Inflow	681	228	112	83	71	56	49	83
Depletion	77	80	11	-6	-4	-2	-1	-1
Reg Flow	10305	1937	2065	2093	1787	827	818	777
Reg Flow kcfs		31.5	34.7	34.0	30.0	13.4	13.3	14.0
Total								
Reach Inflow	4878	657	660	806	742	590	598	825
Depletion	-546	25	-95	-139	-93	-94	-108	-42
Evap	1587	319	398	347	294	206	14	10
Storage	*56495	54823	53191	51696	50588	50198	50069	50148
Ave Power MW		1253	1219	972	836	635	721	710
Ave Cap MW		2461	2439	2414	2371	2360	2367	2382
Energy GWh	4621.3	931.9	878.0	723.5	602.2	472.2	536.6	477.0
Daily GWh		30.1	29.3	23.3	20.1	15.2	17.3	17.0

Date of Study: 02Aug2024

01Aug2024 / Upper Basic Condition / 25.1 MAF / FTPK -1.3, GARR 0.4, OAHE 0.5
Values in 1000 acre-ft Except as Indicated. Elevations in Local Project Datum (LPD)
F-Sum: Sum of Forecasted Values. *: Previous Month's Data

	2024						2025	
	*31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	28Feb
	F-Sum							
Fort Peck								
Reach Inflow	2196	156	216	324	360	360	360	420
Depletion	-579	-172	-109	-31	-14	-89	-106	-60
Reg Inflow	2775	328	325	355	374	449	466	480
Evap	365	80	92	68	67	47	6	3
Release	2379	553	391	246	238	307	338	305
Stor Change	31	-306	-158	40	68	94	121	171
Storage	*13761	13455	13297	13337	13406	13500	13621	13792
Elev feet	*2229.0	2227.4	2226.6	2226.8	2227.2	2227.7	2228.3	2229.1
Disch kcfs	*9.0	9.0	6.6	4.0	4.0	5.0	5.5	5.5
Ave Power MW		117	85	52	52	65	72	72
Ave Cap MW		212	210	210	210	211	211	212
Energy GWh	375.5	87.2	61.3	38.8	37.6	48.6	53.5	48.5
Garrison								
Reach Inflow	2715	351	360	540	444	300	300	420
Depletion	-811	-59	-106	-181	-161	-125	-110	-69
Reg Inflow	5935	964	899	966	843	724	744	795
Evap	537	101	129	125	110	74	-2	0
Release	7620	1353	1111	922	893	1059	1199	1083
Stor Change	-2222	-490	-341	-81	-159	-409	-454	-289
Storage	*19198	18708	18368	18287	18128	17719	17265	16977
Elev feet	*1842.1	1840.6	1839.5	1839.2	1838.7	1837.4	1835.9	1835.0
Disch kcfs	*22.0	22.0	18.7	15.0	15.0	17.2	19.5	19.5
Ave Power MW		286	242	195	194	222	248	247
Ave Cap MW		580	576	574	572	569	563	558
Energy GWh	1186.6	212.7	174.1	144.8	139.9	164.8	184.7	165.7
Oahe								
Reach Inflow	519	67	122	94	81	14	15	126
Depletion	-5	20	0	-10	-7	-6	-4	2
Reg Inflow	8153	1401	1257	1027	980	1063	1219	1207
Evap	503	82	121	110	97	81	8	5
Release	7786	1614	1642	1163	941	746	916	764
Stor Change	-137	-294	-506	-246	-58	236	294	439
Storage	*18041	17747	17240	16994	16936	17172	17466	17905
Elev feet	*1605.4	1604.5	1602.7	1601.9	1601.7	1602.5	1603.5	1605.0
Disch kcfs	*11.9	26.2	27.6	18.9	15.8	12.1	14.9	13.8
Ave Power MW		334	347	238	198	153	189	176
Ave Cap MW		697	690	682	679	681	686	693
Energy GWh	1190.4	248.1	250.0	176.8	142.6	114.0	140.6	118.3
Big Bend								
Reg Inflow	7787	1609	1645	1164	947	742	916	763
Evap	77	24	21	15	10	5	1	0
Release	7727	1589	1611	1170	927	734	931	765
Storage	*1673	1669	1683	1661	1671	1675	1659	1657
Elev feet	*1420.7	1420.7	1420.9	1420.5	1420.7	1420.7	1420.5	1420.4
Disch kcfs	*12.1	25.8	27.1	19.0	15.6	11.9	15.1	13.8
Ave Power MW		113	118	85	70	54	68	62
Ave Cap MW		471	470	479	483	488	484	486
Energy GWh	415.1	84.1	85.3	63.1	50.2	40.0	50.7	41.7
Fort Randall								
Reach Inflow	277	67	54	2	0	20	49	84
Depletion	37	32	12	-2	-2	-2	-1	-1
Reg Inflow	7968	1622	1654	1175	946	744	980	848
Evap	113	28	33	30	14	5	1	1
Release	8326	1659	1777	1774	1380	646	623	467
Stor Change	-471	-65	-157	-629	-448	92	356	380
Storage	*3486	3420	3264	2635	2187	2279	2635	3015
Elev feet	*1355.9	1355.1	1353.3	1344.9	1337.4	1339.1	1344.9	1350.2
Disch kcfs	*18.2	27.0	29.9	28.9	23.2	10.5	10.1	8.4
Ave Power MW		233	256	237	177	80	80	70
Ave Cap MW		381	379	362	328	317	335	355
Energy GWh	827.7	173.4	184.0	176.5	127.4	59.6	59.7	47.1
Gavins Point								
Reach Inflow	1153	189	162	169	162	135	140	196
Depletion	63	37	3	3	9	11	1	-1
Reg Inflow	9467	1794	1940	1943	1593	770	768	659
Evap	23	5	6	6	4	2	0	0
Release	9452	1786	1910	1937	1588	769	769	694
Stor Change	-9	3	24	0	1	-1	-1	-35
Storage	*335	338	362	362	363	362	361	326
Elev feet	*1206.3	1206.5	1207.5	1207.5	1207.5	1207.5	1207.5	1206.0
Disch kcfs	*20.2	29.0	32.1	31.5	26.7	12.5	12.5	12.5
Ave Power MW		110	123	122	104	50	50	50
Ave Cap MW		126	127	127	127	127	127	126
Energy GWh	443.3	82.2	88.4	90.4	74.6	37.1	37.1	33.5
Sioux City								
Reach Inflow	1298	472	202	148	128	101	91	154
Depletion	77	80	11	-6	-4	-2	-1	-1
Reg Flow	10703	2164	2103	2092	1762	872	861	849
Reg Flow kcfs		35.2	35.3	34.0	29.6	14.2	14.0	15.3
Total								
Reach Inflow	8158	1303	1116	1278	1175	930	955	1400
Depletion	-1218	-62	-189	-226	-179	-213	-221	-129
Evap	1618	320	402	354	303	214	15	10
Storage	*56495	55337	54214	53276	52691	52707	53007	53672
Ave Power MW		1193	1171	928	795	624	707	677
Ave Cap MW		2467	2451	2433	2399	2393	2407	2430
Energy GWh	4438.6	887.8	843.0	690.3	572.3	464.1	526.2	454.8
Daily GWh		28.6	28.1	22.3	19.1	15.0	17.0	16.2