The regulation forecast is subject to change daily as actual events occur.
Forecasted release reductions or increases are subject to change based on forecasted temperature and river conditions
and releases may be adjusted during winter freeze-in period. Intrasystem regulation may also require release adjustments.

REGULATION FORECAST: 11/25/20

		FTPK				GARR				OAHE				BEND				FTRA				GAPT				SYSTEM				
		24EL	24ID	24OD	24GE	24EL	24ID	24OD	24GE	24EL	24ID	24OD	24GE	24EL	24ID	24OD	24GE	24EL	24ID	24OD	24GE	24EL	24ID	24OD	24GE	GE	SG	DSG		
W	25	2237.2	6.9	6.0	1.87	1838.9	14.2	13.0	3.78	1606.8	14.0	17.5	5.28	1420.8	17.5	20.5	2.36	1337.6	20.9	20.0	3.73	1207.0	29.4	28.0	1.98	18.98	56362	-14	25	W
T	26	2237.2	6.8	6.0	1.87	1838.9	14.0	13.0	3.78	1606.8	14.0	13.5	4.09	1420.7	14.2	16.5	1.91	1337.6	18.1	17.0	3.19	1207.1	26.0	25.0	1.99	16.82	56354	-8	26	T
F	27	2237.2	6.7	6.0	1.87	1838.9	13.8	13.0	3.78	1606.8	13.9	17.5	5.28	1420.5	16.6	20.5	2.35	1337.9	20.0	14.0	2.65	1207.1	22.6	22.0	1.95	17.87	56346	-8	27	F
	28	**2237.2**	**6.6**	**8.0**	**2.48**	**1838.9**	**13.6**	**13.0**	**3.78**	**1606.8**	**13.8**	**14.5**	**4.38**	**1420.7**	**15.0**	**9.0**	**1.05**	**1337.8**	**12.4**	**13.0**	**2.47**	**1207.2**	**19.4**	**19.0**	**1.70**	**15.86**	**56343**	**-3**	**28**	
	29	**2237.2**	**6.6**	**8.0**	**2.48**	**1838.9**	**13.4**	**13.0**	**3.78**	**1606.8**	**13.8**	**12.5**	**3.79**	**1421.0**	**12.8**	**5.5**	**0.65**	**1337.6**	**8.0**	**13.0**	**2.46**	**1207.2**	**17.3**	**17.0**	**1.52**	**14.68**	**56339**	**-4**	**29**	
M	30	2237.2	6.5	8.0	2.48	1838.9	13.3	13.0	3.78	1606.8	13.7	12.5	3.79	1420.9	12.5	15.5	1.80	1337.6	13.2	13.0	2.46	1207.1	16.4	17.0	1.52	15.82	56322	-17	30	M
T	1	2237.1	6.4	8.0	2.48	1838.9	13.5	13.0	3.78	1606.8	13.7	12.5	3.79	1420.8	12.5	15.5	1.79	1337.7	14.8	13.0	2.46	1207.1	16.1	17.0	1.52	15.82	56311	-11	1	T
W	2	2237.1	6.4	10.5	3.25	1838.9	13.9	16.0	4.63	1606.8	13.8	12.5	3.79	1420.7	12.5	15.5	1.79	1337.8	15.8	13.0	2.47	1207.0	16.1	17.0	1.52	17.45	56291	-20	2	W
T	3	2237.0	6.3	10.5	3.25	1838.9	14.4	16.0	4.63	1606.8	14.9	12.5	3.79	1420.6	12.5	15.5	1.79	1337.9	15.8	13.0	2.47	1206.9	16.0	17.0	1.52	17.44	56274	-17	3	T
F	4	2237.0	6.3	10.5	3.25	1838.8	14.8	16.0	4.63	1606.8	16.1	12.5	3.79	1420.5	12.5	15.5	1.79	1338.0	15.8	13.0	2.46	1206.8	16.0	17.0	1.52	17.43	56262	-12	4	F
	5	**2236.9**	**6.2**	**10.5**	**3.25**	**1838.8**	**15.4**	**16.0**	**4.63**	**1606.8**	**16.5**	**10.5**	**3.19**	**1420.7**	**10.9**	**3.0**	**0.36**	**1337.8**	**7.1**	**13.0**	**2.46**	**1206.7**	**16.0**	**17.0**	**1.52**	**15.40**	**56259**	**-3**	**5**	
	6	**2236.9**	**6.2**	**10.5**	**3.25**	**1838.8**	**16.1**	**16.0**	**4.63**	**1606.9**	**16.6**	**8.5**	**2.58**	**1421.0**	**8.9**	**1.0**	**0.12**	**1337.4**	**3.2**	**13.5**	**2.54**	**1206.6**	**16.0**	**17.0**	**1.52**	**14.64**	**56252**	**-7**	**6**	
M	7	2236.9	6.1	10.5	3.25	1838.8	16.8	16.0	4.63	1606.9	16.6	15.0	4.54	1420.8	13.7	18.0	2.08	1337.4	13.4	13.5	2.53	1206.6	16.2	17.0	1.52	18.54	56230	-22	7	M
T	8	2236.8	6.1	10.5	3.25	1838.8	17.1	16.0	4.63	1606.9	16.6	15.0	4.54	1420.7	15.0	18.0	2.08	1337.5	16.6	14.0	2.62	1206.5	16.4	17.0	1.52	18.63	56218	-12	8	T
W	9	2236.8	6.0	10.5	3.25	1838.8	17.1	16.0	4.63	1606.9	16.6	15.0	4.54	1420.6	15.0	18.0	2.07	1337.6	18.3	14.0	2.63	1206.5	16.7	17.0	1.52	18.63	56209	-9	9	W
T	10	2236.7	6.0	10.5	3.24	1838.8	17.1	16.0	4.63	1606.9	16.6	15.0	4.54	1420.5	15.0	18.0	2.07	1337.8	18.3	14.0	2.63	1206.5	16.9	17.0	1.52	18.63	56200	-9	10	T
F	11	2236.7	5.9	10.5	3.24	1838.8	17.1	16.0	4.63	1606.9	16.6	15.0	4.54	1420.4	15.0	18.0	2.07	1338.0	18.3	14.0	2.64	1206.5	17.0	17.0	1.52	18.63	56193	-7	11	F
	12	**2236.6**	**5.9**	**10.5**	**3.24**	**1838.8**	**17.1**	**16.0**	**4.63**	**1606.9**	**16.6**	**13.0**	**3.94**	**1420.7**	**13.4**	**5.0**	**0.59**	**1337.8**	**9.2**	**14.0**	**2.64**	**1206.5**	**17.0**	**17.0**	**1.52**	**16.55**	**56192**	**-1**	**12**	
	13	**2236.6**	**5.8**	**10.5**	**3.24**	**1838.8**	**17.0**	**16.0**	**4.63**	**1606.9**	**16.5**	**11.0**	**3.34**	**1421.0**	**11.4**	**2.5**	**0.30**	**1337.4**	**4.9**	**14.0**	**2.63**	**1206.5**	**17.0**	**17.0**	**1.52**	**15.65**	**56188**	**-4**	**13**	
M	14	2236.5	5.8	10.5	3.24	1838.8	17.0	16.0	4.63	1606.9	16.5	17.0	5.13	1420.9	15.8	20.0	2.30	1337.5	15.3	14.0	2.62	1206.5	17.0	17.0	1.52	19.44	56167	-21	14	M
T	15	2236.5	5.8	10.5	3.24	1838.8	17.0	16.0	4.63	1606.9	16.5	17.0	5.13	1420.8	17.0	20.0	2.30	1337.6	18.6	14.5	2.72	1206.5	17.0	17.0	1.52	19.53	56154	-13	15	T
W	16	2236.4	5.8	10.5	3.24	1838.8	17.0	16.0	4.63	1606.9	16.5	17.0	5.13	1420.6	17.0	20.0	2.30	1337.8	20.3	14.5	2.72	1206.5	17.3	17.0	1.52	19.53	56143	-11	16	W
T	17	2236.4	5.7	10.5	3.24	1838.8	17.0	16.0	4.63	1606.9	16.5	17.0	5.13	1420.5	17.0	20.0	2.29	1338.0	20.3	14.5	2.73	1206.5	17.4	17.0	1.52	19.54	56134	-9	17	T
F	18	2236.3	5.7	10.5	3.24	1838.8	17.0	16.0	4.63	1606.9	16.5	17.0	5.13	1420.4	17.0	20.0	2.29	1338.3	20.3	14.5	2.74	1206.5	17.5	17.0	1.52	19.54	56125	-9	18	F

Project:
24EL Midnight Elevation (NGVD29)
24ID Daily Average Inflow (kcfs)
24OD Daily Average Release (kcfs)
24GE Daily Power Generation (1000 MWh)

System:
GE Daily Power Generation (1000 MWh)
SG Midnight Storage (kaf)
DSG Daily Storage Change (kaf)

Units:
kcfs thousand cubic feet per second
MWh megawatt hour
kaf thousand acre-feet

The midnight elevation (24EL) will be shown in color when a reservoir enters one of the following zones.
1234.5 Exclusive Flood Control Zone (24EL)
1234.5 Surcharge Zone (24EL)

The daily average release (24OD) will be shown in color when a project's releases exceed the available power plant capacity.
34.5